



Revised Total Coliform Rule (RTCR) Level 2 Assessment Form

Complete the assessment, correct all sanitary defects and return all pages of this form (including any additional/supporting documentation), **WITHIN 30 DAYS** of triggering an assessment.

PWS ID#:		PWS Name:		Date of Assessment:	
Compliance Period:	Month/Quarter		Year	Regulating Agency: ADEQ MCESD PDEQ	

Indicate the Grade of Certified Operator(s) Required by the PWS:	Treatment:	1	2	3	4
	Distribution:	1	2	3	4

Level 2 Assessment

- An assessment is an evaluation to identify the possible presence of **sanitary defects**, defects in distribution system coliform monitoring practices, and (when possible) the likely reason that the system triggered the assessment.
- The minimum elements of any assessment include the review and identification of:
 - *Events that happened that could create impaired water quality*
 - *Changes in distribution system Operation & Maintenance that may affect distributed water quality, including water storage*
 - *Source and treatment considerations that bear on distributed water quality*
 - *Existing water quality monitoring data (e.g., coliforms, disinfectant residuals, water quality parameters, etc.)*
 - *Inadequacies in sample sites, sampling protocol, and sample processing*
- A Level 2 assessment
 - Provides a more detailed examination of the system (including the system's monitoring and operational practices) than a Level 1 assessment does, through the use of more comprehensive investigation and review of available information, additional internal and external resources, and other relevant practices.
 - Will likely include field investigations, additional sampling and additional inspections of facilities beyond those performed in a Level 1 assessment.

The level of effort and resources required to implement the Level 2 assessments will be commensurate with a more comprehensive investigation, a higher level review of available information, and may involve the engagement of additional parties and expertise.

INSTRUCTIONS: Complete each Section on the form. Then check the associated box, below, when completed.

Section A: Assessment (evaluate and identify any issues that could be an issue or sanitary defect)

Section B: Description of Occurrence (provide an explanation if any issues were identified)

Section C: Corrective Action (provide proposed corrective action(s) if any issues were identified in Section B)

Section D: Compliance History (provide the information requested)

Microbiological Sample Siting Plan (MSSP): Attach a copy of the current MSSP to the Level 2 Assessment form.



Revised Total Coliform Rule (RTCR) Level 2 Assessment Form

Complete the assessment, correct all sanitary defects and return all pages of this form (including any additional/supporting documentation), **WITHIN 30 DAYS** of triggering an assessment.

Section A - Assessment

- a) Review and evaluate all elements contained under each sub-section (1-7).
- b) Check any that are found to apply.
- c) For each sub-section indicate the overall findings by checking **only one box** for either:
 - **Issue(s) identified**, if any potential causes of contamination were identified (any boxes were checked)
 - **No issues**, if no potential causes of contamination were identified
 - **NA****, if the section is not applicable to the PWS

1. General/Overall System

No issues Issue(s) identified NA**

Have any of the following occurred in general, or at sample sites prior to collecting bacteria samples?

Low/inadequate disinfectant residual Firefighting event/flushing/sheared hydrant Pressure loss/inadequate pressure (<20 psi) Signs of vandalism/forced entry Visible indicators of unsanitary conditions Water quality parameters/indicators out of range	Sample station not secured to deter unauthorized access Issue(s) identified during the seasonal system's most recent start-up procedures (if applicable) Atypical events that could affect distributed water quality or indicate that distributed water quality was impaired Other:
--	--

2. Sampling Sites

No issues Issue(s) identified NA**

Unclean or unsuitable sample tap Hot water intrusion MSSP has not been reviewed by Regulatory Agency Premise Treatment Devices not operational (if applicable)	Change in conditions at sample site There were recent plumbing changes/construction nearby Other:
---	---

3. Sampling Protocol

No issues Issue(s) identified NA**

Improper sample container Aerator was not removed (if present) Sampler error Inadequate tap flushing Aseptic techniques were NOT used	Improper hold time/storage temperature Auto sensing faucet/swivel-type faucet Sample was taken at a site not specified in MSSP Other:
--	---

4. Treatment Process

No issues Issue(s) identified NA**

Interruption in treatment and/or power loss Treatment added and/or changed Change in flow rates The system was required to perform disinfection after correcting deficiencies in the past 12 month. When/Which disinfection procedure:	Turbidity measurements out of range (<i>surface water system</i>) Recent installation/repair Inadequate disinfection Operations & maintenance (O&M) procedures not followed Filters/Treatment operated beyond capacity Other:
--	--



Revised Total Coliform Rule (RTCR) Level 2 Assessment Form

Complete the assessment, correct all sanitary defects and return all pages of this form (including any additional/supporting documentation), **WITHIN 30 DAYS** of triggering an assessment.

5. Distribution System	No issues	Issue(s) identified	NA**
Power loss Standing water/debris in valve vault/box Low disinfection residuals Pump or valve failure Pressure loss/inadequate pressure (<20 psi) Improper control of surges Main breaks and/or leaks Unprotected cross connection Improper connection of new/repaired/renovated lines or connections		Flushing of fire hydrants or blow-offs Improper maintenance of air-relief/air-vacuum valves Installation of new mains or construction activity Improper operation of pumps Improper/Unauthorized use of hydrants Improper operation of isolation valves resulting in breakage Known recent backflow incident(s) Failure to install backflow prevention device(s) Failure to test backflow prevention device(s) Other:	
6. Storage Tanks	No issues	Issue(s) identified	NA**
Improper maintenance practices Signs of vandalism/forced entry Presence of dead animals/insects Signs of animal activity Recent facility maintenance; When: Incorrect operation of level control valves, altitude valves, and related appurtenances		Hatch not sealed Low disinfectant residuals Deterioration, rust, holes, or other breaches in vent, overflow pipe, access hatch, screens, ladders, etc. Improper disinfection conducted after maintenance/inspection Other:	
7. SOURCES (Address each type of source)			
Well	No issues	Issue(s) identified	NA**
Defective/damaged well cap/well seal Crack in well slab Missing/damaged grout seal Damaged pitless adaptor Floodwater/run-off inundation Changes in available source water Source water spills near well head Standing water around well head Improper disinfection after maintenance (if applicable)		New source added Damaged well casing Damaged/unscreened vent Unprotected opening in pump/pump assembly Use of previously inactive well/source Well is <u>not</u> structurally sound Stream flow rates/reservoir level higher of lower than normal Signs of animal activity Other:	
Surface Water Intake (List any issues in Section B)	No issues	Issue(s) identified	NA**
Supply Spring	No issues	Issue(s) identified	NA**
Potential source of contamination Infiltration of surface run-off Improper development/poorly maintained spring box Signs of animal activity/tampering		Rapid snowmelt Heavy rainfall Source water turnover occurred Other:	
Interconnect (Consecutive Connection)	No issues	Issue(s) identified	NA**
Checked interconnection Signs of animal activity/tampering		Other:	



Revised Total Coliform Rule (RTCR) Level 2 Assessment Form

Complete the assessment, correct all sanitary defects and return all pages of this form (including any additional/supporting documentation), **WITHIN 30 DAYS** of triggering an assessment.

Section B - Issue Description Use this space to describe the event and provide additional information on potential causes of contamination identified during the assessment. Include corresponding dates with your findings (attach additional pages if needed). Include dates of sample collection, disinfection, flushing, photographs showing system components, etc., with your findings.

Check if PWS did not find any causes for the contamination.

Section C - Corrective Action Taken or to be Taken Use this space to describe corrective actions completed, a proposed timetable for any corrective actions not already completed, and any interim measures the PWS plans to implement prior to the completion of any corrective actions, including specific milestone dates for doing so (attach additional pages if needed). Include photographs showing system components. Failure to meet milestone dates is subject to enforcement and public notice provisions.

**Failure to meet any milestone date(s) is/are subject to enforcement and public notice provisions.
The PWS must notify the regulatory agency as each milestone is met.**

Section D - Compliance History

1. Was the PWS required to complete a Level 1 or 2 Assessment in the last 12 months?	Yes	No
If "Yes": Was the source of contamination identified?	Yes	No
Were any Sanitary Defects identified?	Yes	No
2. Was the PWS required by the regulatory agency during the last survey, inspection or other communication to address any issue(s)?	Yes	No
If "Yes": Date issue was identified:		
Were all corrective actions completed?	Yes	No
If "No": Describe the issue and indicate your plan and a proposed timetable for any corrective actions (attach additional pages if needed).		



Revised Total Coliform Rule (RTCR) Level 2 Assessment Form

Complete the assessment, correct all sanitary defects and return all pages of this form (including any additional/supporting documentation), **WITHIN 30 DAYS** of triggering an assessment.

Certified Operator (print name):	Signature:
Certification Number:	Certification Expiration Date:
Sample Collector(s) (Check if same as Certified Operator):	
Sample Collector(s):	Sample Collector(s):

Certification: I certify under penalty of law that I am the person authorized to fill out this form, and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Print

Name: _____ Title: _____

Signature: _____ Date: _____

Phone #: _____ Email: _____

Submit the completed form to the system's regulatory agency and copy ADEQ

Arizona Department of Environmental Quality
Drinking Water Monitoring and Protection Unit
1110 W. Washington St., Mail Code 5415 B-2
Phoenix, AZ 85007
Fax: 602-771-4634
RTCR@azdeq.gov

Maricopa County Environmental Services Department
Safe Drinking Water Program
1001 N Central Avenue, Suite 250
Phoenix, AZ 85004
Desk: 602.506.6935 | Fax: 602.372.0866
sdwquestions@mail.maricopa.gov

Arizona Department of Environmental Quality
Southern Regional Office
400 W. Congress, Suite 433
Tucson, AZ 85701
Phone: 520-770-3126 | Fax: 520-628-6745
RTCR@azdeq.gov

Pima County Department of Environmental Quality
Drinking Water Program
33 N. Stone Ave., Suite 700
Tucson, AZ 85701
Phone: 520-724-7400 | Fax: 520-838-7432