

LOW LEVEL HYDROSTATIC TESTING (PEI RP 1200)

Facility N	ame:	Facilit	y ID Numbe	er: 0-0	Facili	Facility Address: Testing				g Date:		
Name of	Tester(s)	ADEC				-Certification #						
IF TESTIN	IG ACCORDING TO CO			UFACTURER'S IG DATA IN A				-		RER'S TESTING	G PROTOCOL,	
COMPLETE ONE COLUMN PER CONTAIN												
Sump Ty	20	☐ STP sump		☐ STP sump		☐ STP sump		☐ STP sump		☐ STP sump		
Sump light Sump Identification		□ UDC sump		□ UDC sump		□ UDC sump		□ UDC sump		☐ UDC sump		
		☐ Transition sump		☐ Transition sump		☐ Transition sump		☐ Transition sump		☐ Transition sump		
Manufacturer												
Model												
Construction Type		☐ Single Wall		☐ Single Wall		☐ Single Wall		☐ Single Wall		☐ Single Wall		
		☐ Double Wall		☐ Double Wall		☐ Double Wall		☐ Double Wall		☐ Double Wall		
Sump Construction Material												
	Liquid and debris removed from sump?	☐ Yes	□ No	☐ Yes	□ No	☐ Yes	□No	□ Ye	s 🗆 No	☐ Yes	□ No	
NO.	Inspection for Damage	: examine all pe	enetration fitti	ngs, conducts, ju	unction boxes,	caps and risers	(if present), an	d sidewall se	ams for defects, o	damage, or impr	operly	
PECT	installed components. Visual inspection for					1		l		l		
VISUAL INSPECTION	damage performed?	☐ Yes	□ No	☐ Yes	□ No	☐ Yes	□ No	□ Ye	s 🗆 No	☐ Yes	□ No	
	COMMENTS regarding											
	visual inspection Result of											
	Visual Inspection	☐ PASS	☐ FAIL	☐ PASS	☐ FAIL	□ PASS	☐ FAIL	□ PAS	S 🗆 FAIL	□ PASS	☐ FAIL	
When tested, electronic sensor connected to EMS, stand-alone sensor or mechanical float device shuts down appropriate STP, dispenser or product as required?		☐ Yes	□ No	□ Yes	□ No	□ Yes	□ No	□Ye	es 🗆 No	□ Yes	□ No	
HYDROSTATIC TESTING START	Is water level a minimum of 4" above the point the sensor activates?	☐ Yes	□ No	☐ Yes	□ No	☐ Yes	□ No	□Ye	es 🗆 No	☐ Yes	□ No	
	Depth of water at START of hydrostatic test (measure in 1/16" increments)		/16 inches		/16 inches		/16 inches		/16 inches		/16 inches	
Start Time (Hour:Minute)												
End Time	(Hour:Minute)											
Duration of Test (in minutes)												
HYDROSTATIC TESTING END	Depth of water (bottom containment sump to to water) at END of hydro (measure in 1/16" incr	op of static test		/16 inches	ir	/16	incl	/16 hes	/1 inche		/16 inches	
	Measured change in water level	/16 inches		/16 inches		/16 inches		/16 inches			/16 inches	
	Did the water level change 1/8" or greater?	□ Yes □ No		□ Yes □ No		☐ Yes ☐ No		□ Yes □ No		☐ Yes ☐ No		
	0	eria: If the water level changes 1/8 inches or greater, the corrostatic			e containment sump fails the integrity tes							
	Result of Hydrostatic				□ P/	ASS FAIL	□ PASS	□ FAIL □ PASS □ FAIL		AIL DPA	. □ PASS □ FAIL	
INTEGRI	Test TY TEST PASS/FAIL CRITE	RIA: 1) Must na										
INTEGRITY TEST RESULTS:		□ PASS	☐ FAIL	□ PASS	☐ FAIL	□ PASS	□ FAIL	□ PAS	S □ FAIL	☐ PASS	□ FAIL	
COMME				,.55		,.03			-	,		
	ded Photo Documentation											

- identification of the sump being tested
- time and depth of water at start of hydrostatic test
- time and depth of water at end of hydrostatic test
- condition of sump prior to testing
- issues discovered during visual inspection