

Individual Industrial Reclaimed Water Permit No. R102439  
 Place ID No. 3453, LTF No. 64613  
**Saddle Mountain Unified School District #90**  
**Ruth Fisher School**

## I. FACILITY INFORMATION

### Name and Location

Name of Permittee:	Saddle Mountain Unified School District #90
Mailing Address:	38201 W. Indian School Road Tonopah, Arizona, 85345
Facility name and location:	Ruth Fisher School 38201 W. Indian School Road Tonopah, Arizona, 85345

### Facility Description

Up to 63,500 gallons per day (gpd) of a blend of Class A+ reclaimed water produced by the Ruth Fisher School Wastewater Treatment Plant (WWTP) and brine reject water from the water treatment plant may be used for irrigation of 23 acres of turf and landscape (two baseball fields, a football field, a soccer field, and twenty-three grass and tree areas) at Ruth Fisher School. Additionally, the fire loop for the school complex may use the blended reclaimed water for fire suppression. A series of cross connection tests were performed to ensure no cross connections in the fire suppression system.

## II. COMPLIANCE WITH AQUIFER WATER QUALITY STANDARDS

### Monitoring and Reporting Requirements

The monitoring requirements for this facility are specified in Table I of this permit and the APP for the Ruth Fisher School (APP No. P-102439). Routine discharge monitoring is required for the Individual Industrial Reclaimed Water Permit for both volume (daily) and quality (daily for fecal coliform, and monthly for TDS and total nitrogen).

## III. ADMINISTRATIVE INFORMATION

### Public Notice (A.A.C. R18-9-705(F)(1))

The public notice is the vehicle for informing all interested parties and members of the general public of the contents of a draft permit or other significant action with respect to a permit or application. The basic intent of this requirement is to ensure that all interested parties have an opportunity to comment on significant actions of the permitting agency with respect to a permit application or permit. This permit will be public noticed in a local newspaper after a pre-notice review by the applicant and other affected agencies.

### Public Comment Period (A.A.C. R18-9-705(F)(1))

The reuse program rules require that permits be public noticed in a newspaper of general circulation within the area affected by the facility or activity and provide a minimum of 30 calendar days for interested parties to respond in writing to ADEQ.

**Public Hearing (A.A.C. R18-9-705(F)(2))**

A public hearing may be requested in writing by any interested party. The request should state the nature of the issues proposed to be raised during the hearing. A public hearing will be held if the Director determines there is a significant amount of interest expressed during the 30-day public comment period, or if significant new issues arise that were not considered during the permitting process.

**IV. ADDITIONAL INFORMATION**

Additional information relating to this proposed permit may be obtained from:

Arizona Department of Environmental Quality  
Water Quality Division - APP Unit  
Attn: Marcy Mullins  
1110 W. Washington St., Mail Code: 5415B-3  
Phoenix, Arizona 85007  
Phone: (602) 771- 4464