

**Public Record - Summary Information on Underground Storage Tanks (USTs)
Arizona Department of Environmental Quality (ADEQ)**

Report Period: October 1, 2016 - September 30, 2017

General Information:

Total Number of UST Facilities: 2238
Total Number of Open USTs: 6220

Summary Information for On-Site UST Inspections:

Number of UST Facilities Inspected: 964
Percent Significant Compliance¹: 69%

Summary Information for Leaking UST (LUST) Releases²:

Number of Confirmed LUST Releases: 66 (at 65 facilities)

Summary Information for Release Sources and Causes:

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problems		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	34	52%													34	52%
Piping	12	18%													12	18%
Dispenser	13	20%													13	20%
Submersible Turbine Pump		0%														0%
Delivery Problem		0%														0%
Other	7	11%													7	11%
Totals	66	100%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	66	100%

¹ Percent compliance measures significant compliance with Arizona's UST regulatory requirements based on an on-site compliance inspection. Significant or major violations, such as non-compliance with the presence or operational capability of release detection, corrosion protection, overfill or spill prevention equipment would result in issuance of a Notice of Violation.

² Release, source and cause information is based on data associated with 66 LUST releases reported during this reporting period. All open LUST release case files, 581 releases (at 333 facilities) to date, are tracked in the Azurite database and are managed by ADEQ case managers within the UST-LUST Section.

To obtain more information on UST inspection and compliance issues, please call (602) 771-0391. To obtain more information on the LUST issues, please call (602) 771-4341.