

**Public Record – Summary Information on Underground Storage Tanks (USTs)  
Arizona Department of Environmental Quality (ADEQ)**

**Report Period: October 1, 2015 – September 30, 2016**

**General Information:**

Total Number of UST Facilities: 2,308  
Total Number of Open USTs: 6,416

**Summary Information for On-Site UST Inspections:**

Number of UST Facilities Inspected: 823  
Percent Significant Compliance<sup>1</sup>: 86%

**Summary Information for Leaking UST (LUST) Releases<sup>2</sup>:**

Number of Confirmed LUST Releases: 87 (at 57 facilities)

**Summary Information for Release Sources and Causes:**

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problems		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	31	36							3	10					28	90
Piping	22	25					1	5							21	95
Dispenser	33	38					1	2							32	98
Submersible Turbine Pump	1	1													1	100
Delivery Problem																
Other																
Totals	87	100		xxxx		xxxx	2	xxxx	3	xxxx		xxxx		xxxx	82	xxxx

<sup>1</sup> Percent compliance measures significant compliance with Arizona's UST regulatory requirements based on an on-site compliance inspection. Significant or major violations, such as non-compliance with the presence or operational capability of release detection, corrosion protection, overfill or spill prevention equipment would result in issuance of a Notice of Violation.

<sup>2</sup> Release, source and cause information is based on data associated with the 87 LUST releases reported during this reporting period. All open LUST release case files, 661 to date, are tracked in the Azurite database and are managed by ADEQ case managers within the LUST Section.

To obtain more information on UST inspection and compliance issues, please call (602) 771-4196. To obtain more information on LUST issues, please call (602) 771-4341.