

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**Tierra Linda HOA Water Company**  
**PWS 10-411**

**Has Levels of Arsenic Above Drinking Water Standards**

Our water system Tierra Linda HOA Water Company recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor of the presence of drinking water contaminants. Testing results we received on May 3, 2021 show that our system exceeds the standard, or maximum contaminant level (MCL), for arsenic. The standard for arsenic is 10 parts per billion (ppb). The average level of arsenic over the last year has been 11 ppb.

**What should I do?**

**You do not need to use an alternative (e.g. bottled) water supply.** However, if you have specific health concerns, consult your doctor.

**What does this mean?**

This is not an immediate risk. If it had been you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with circulatory system, and many have an increased risk of getting cancer.

**What is being done?**

Tierra Linda HOA Water Company is currently working with the Arizona Corporation Commission to install arsenic removal treatment. We anticipate resolving the problem within the next 18 months.

For more information, please contact Jason Long at 520-431-7723 or [jason@longwatermanagement.com](mailto:jason@longwatermanagement.com)

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by Tierra Linda HOA Water Company. Public Water System ID#: AZ-04-10411 Date distributed: 5/15/2021.