

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**CITRUS PARK WATER 14 107**  
**Has Levels of Arsenic Above Drinking Water Standards**

Our water system Citrus Park recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor of the presence of drinking water contaminants. Testing results we received on April 14 2021 show that our system exceeds the standard, or maximum contaminant level (MCL), for arsenic. The standard for arsenic is 10 parts per billion (ppb). The average level of arsenic over the last year has been 17 ppb.

**What should I do?**

**You do not need to use an alternative (e.g. bottled) water supply.** However, if you have specific health concerns, consult your doctor.

**What does this mean?**

This is not an immediate risk. If it had been you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with circulatory system, and many have an increased risk of getting cancer.

**What is being done?**

We are seeking Federal funds to help with a new well and an arsenic filter system. We anticipate resolving the problem within one year.

For more information, please contact Citrus Park Water at 928 341 9685 or 4743 E 30<sup>th</sup> Pl, Yuma AZ 85365].

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by Citrus Park Water Public Water System ID#: AZ-04 14 107 Date distributed: April 29 2021.

Any ADEQ translation or communication in a language other than English is unofficial and not binding on the State of Arizona.

Cualquier traducción o comunicado de ADEQ en un idioma diferente al inglés no es oficial y no sujetará al Estado de Arizona a ninguna obligación jurídica"