

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
BOUSE WORLEY WATER SYSTEM PWS # AZ0415038
Has Levels of Arsenic Above Drinking Water Standards

Our water system Bouse Worley Water System recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor of the presence of drinking water contaminants. Testing results we received on (date results were received from lab) show that our system exceeds the standard, or maximum contaminant level (MCL), for arsenic. The standard for arsenic is 10 parts per billion (ppb), or 10 mg/L. The average level of arsenic over the last year has been 11ppb (11 mg/L).

What should I do?

You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with circulatory system, and many have an increased risk of getting cancer.

What is being done?

(Describe corrective action. We currently have received a grant for engineering of an updated well and needed filtration system.) We anticipate resolving the problem within (Estimated time frame. The next 18 months. Until this is complete BDWID will continue to provide r/o water at the Bouse RV Park).

For more information, please contact [name of contact Cindy Clewell] at [phone number 928-851-1120] or [mailing address PO Box 334 Bouse, AZ 85325].

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Bouse Worley Water System. Public Water System ID#: AZ-04-15-038. Date distributed: 10-25-2019

Any ADEQ translation or communication in a language other than English is unofficial and not binding on the State of Arizona.

Cualquier traducción o comunicado de ADEQ en un idioma diferente al inglés no es oficial y no sujetará al Estado de Arizona a ninguna obligación jurídica"