

If Routine Sample Is:	And	Any Repeat Sample Is:	Action: What do the sample results mean?	MCL Violation?
TC+ EC-	&	TC+ EC-	1. <b>Conduct a Level 1 or Level 2 Assessment.</b> Contact the state for help determining which type of assessment is required.	No MCL violation
TC+ EC-	&	TC+ EC?	<ol style="list-style-type: none"> <li>1. <b>Notify the regulatory agency within 24 hours of receiving sample results.</b></li> <li>2. <b>Conduct a Level 2 Assessment.</b></li> <li>3. <b>Issue a Tier 1, Boil Water Advisory, Public Notice (PN)</b></li> </ol>	<i>E. coli</i> MCL violation
TC+ EC-	&	TC+ EC+	<ol style="list-style-type: none"> <li>1. <b>Notify the regulatory agency within 24 hours of receiving sample results.</b></li> <li>2. <b>Conduct a Level 2 Assessment.</b></li> <li>3. <b>Issue a Tier 1, Boil Water Advisory, Public Notice (PN)</b></li> </ol>	<i>E. coli</i> MCL violation
TC+ EC-	&	Any or all repeat samples missing	1. <b>Conduct a Level 1 or Level 2 Assessment.</b> Contact the regulatory agency for help determining which type of assessment is required.	No MCL violation
TC+ EC+	&	TC+	<ol style="list-style-type: none"> <li>1. <b>Notify the regulatory agency within 24 hours of receiving sample results.</b></li> <li>2. <b>Conduct a Level 2 Assessment.</b></li> <li>3. <b>Issue a Tier 1, Boil Water Advisory, Public Notice (PN)</b></li> </ol>	<i>E. coli</i> MCL violation
TC+ EC+	&	Any or all repeat samples missing	<ol style="list-style-type: none"> <li>1. <b>Notify the regulatory agency within 24 hours of receiving sample results.</b></li> <li>2. <b>Conduct a Level 2 Assessment.</b></li> <li>3. <b>Issue a Tier 1, Boil Water Advisory, Public Notice (PN)</b></li> </ol>	<i>E. coli</i> MCL violation