



4401 S. Tucson Estates Parkway  
Tucson, Arizona 85735  
520.791.2544 Phone  
520.791.5260 Fax

26 April 2017

Water Quality Compliance 5415B-1  
Arizona Department of Environmental Quality  
1110 West Washington Street  
Tucson, AZ 85735  
RE: Public School Lead Screening Program

Enclosed are the results for Work Order L170431, received by the laboratory on 03/28/2017 12:45. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michael E. Dew  
Lab Manager

Tucson Water Quality Lab  
4401 S. Tucson Estates Pkwy.  
Tucson, AZ 85735  
(520) 837-2455

Arizona Department of Environmental Quality  
1110 West Washington Street  
Phoenix AZ, 85007

Project: Public School Lead Screening Program  
Project Number: P01210  
Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
04/26/2017 10:38

#### ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Main dr 137	L170431-01	Aqueous	03/21/2017 11:23	03/28/2017 12:45
Main dr 60	L170431-02	Aqueous	03/21/2017 11:27	03/28/2017 12:45
East #216	L170431-03	Aqueous	03/21/2017 11:32	03/28/2017 12:45
East Dr 201	L170431-04	Aqueous	03/21/2017 11:34	03/28/2017 12:45
Activity Dr 105	L170431-05	Aqueous	03/21/2017 11:38	03/28/2017 12:45
South DR 187	L170431-06	Aqueous	03/21/2017 11:42	03/28/2017 12:45
Library Dr 99	L170431-07	Aqueous	03/21/2017 11:55	03/28/2017 12:45
Library 98	L170431-08	Aqueous	03/21/2017 12:00	03/28/2017 12:45
Main bldg 116A	L170431-09	Aqueous	03/21/2017 10:25	03/28/2017 12:45
Wellness 152	L170431-10	Aqueous	03/21/2017 10:33	03/28/2017 12:45
Main Dr 261B	L170431-11	Aqueous	03/21/2017 12:57	03/28/2017 12:45
Main bldg Dr #1	L170431-12	Aqueous	03/21/2017 09:30	03/28/2017 12:45
Main bldg Dr 76	L170431-13	Aqueous	03/21/2017 09:40	03/28/2017 12:45
MPR-DRC 1B	L170431-14	Aqueous	03/21/2017 09:50	03/28/2017 12:45
Locker room Dr 84	L170431-15	Aqueous	03/21/2017 09:59	03/28/2017 12:45
Locker room 149	L170431-16	Aqueous	03/21/2017 10:03	03/28/2017 12:45
West bldg Dr-133	L170431-17	Aqueous	03/21/2017 10:06	03/28/2017 12:45
W bldg #144	L170431-18	Aqueous	03/21/2017 10:10	03/28/2017 12:45
Library Dr 83	L170431-19	Aqueous	03/21/2017 10:15	03/28/2017 12:45

Tucson Water Quality Laboratory



Michael E. Dew, Lab Manager

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
4401 S. Tucson Estates Pkwy.  
Tucson, AZ 85735  
(520) 837-2455

Arizona Department of Environmental Quality  
1110 West Washington Street  
Phoenix AZ, 85007

Project: Public School Lead Screening Program  
Project Number: P01210  
Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
04/26/2017 10:38

**Main dr 137**  
**L170431-01 (Aqueous)**

**Sampled:**  
03/21/2017 11:23

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	<b>Reported:</b> 04/26/2017 10:38
---	--	--------------------------------------

**Main dr 60**  
**L170431-02 (Aqueous)**

**Sampled:**  
 03/21/2017 11:27

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

**Tucson Water Quality Lab**  
**4401 S. Tucson Estates Pkwy.**  
**Tucson, AZ 85735**  
**(520) 837-2455**

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**East #216**  
**L170431-03 (Aqueous)**

**Sampled:**  
 03/21/2017 11:32

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**East Dr 201**  
**L170431-04 (Aqueous)**

**Sampled:**  
 03/21/2017 11:34

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

<b>LEAD</b>	<b>0.00146</b>	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Activity Dr 105**  
**L170431-05 (Aqueous)**

**Sampled:**  
 03/21/2017 11:38

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	<b>Reported:</b> 04/26/2017 10:38
---	--	--------------------------------------

**South DR 187**  
**L170431-06 (Aqueous)**

**Sampled:**  
 03/21/2017 11:42

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Library Dr 99**  
**L170431-07 (Aqueous)**

**Sampled:**  
 03/21/2017 11:55

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

<b>LEAD</b>	<b>0.00175</b>	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Library 98**  
**L170431-08 (Aqueous)**

**Sampled:**  
 03/21/2017 12:00

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

<b>LEAD</b>	<b>0.0119</b>	0.00100	mg/L	1	BD71804	04/17/2017	04/18/2017	EPA 200.8
-------------	---------------	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Main bldg 116A**  
**L170431-09 (Aqueous)**

**Sampled:**  
 03/21/2017 10:25

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Wellness 152**  
**L170431-10 (Aqueous)**

**Sampled:**  
 03/21/2017 10:33

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
4401 S. Tucson Estates Pkwy.  
Tucson, AZ 85735  
(520) 837-2455

Arizona Department of Environmental Quality  
1110 West Washington Street  
Phoenix AZ, 85007

Project: Public School Lead Screening Program  
Project Number: P01210  
Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
04/26/2017 10:38

**Main Dr 261B**  
**L170431-11 (Aqueous)**

**Sampled:**  
03/21/2017 12:57

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

<b>LEAD</b>	<b>0.00271</b>	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	<b>Reported:</b> 04/26/2017 10:38
---	--	--------------------------------------

**Main bldg Dr #1**  
**L170431-12 (Aqueous)**

**Sampled:**  
 03/21/2017 9:30

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8	
------	----	---------	------	---	---------	------------	------------	-----------	--

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Main bldg Dr 76**  
**L170431-13 (Aqueous)**

**Sampled:**  
 03/21/2017 9:40

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**MPR-DRC 1B**  
**L170431-14 (Aqueous)**

**Sampled:**  
 03/21/2017 9:50

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Locker room Dr 84**  
**L170431-15 (Aqueous)**

**Sampled:**  
 03/21/2017 9:59

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Locker room 149**  
**L170431-16 (Aqueous)**

**Sampled:**  
 03/21/2017 10:03

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**West bldg Dr-133**  
**L170431-17 (Aqueous)**

**Sampled:**  
 03/21/2017 10:06

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**W bldg #144**  
**L170431-18 (Aqueous)**

**Sampled:**  
 03/21/2017 10:10

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

<b>LEAD</b>	<b>0.00231</b>	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

**Tucson Water Quality Lab**  
**4401 S. Tucson Estates Pkwy.**  
**Tucson, AZ 85735**  
**(520) 837-2455**

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

**Library Dr 83**  
**L170431-19 (Aqueous)**

**Sampled:**  
 03/21/2017 10:15

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

**Tucson Water Quality Laboratory**

**Total Metals by ICPMS**

LEAD	ND	0.00100	mg/L	1	BD71407	04/14/2017	04/14/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

### Total Metals by ICPMS - Quality Control

#### Tucson Water Quality Laboratory

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Matrix Spike (BD71407-MS1)		Source: L170433-01		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.00974	0.00101	mg/L	0.0101	0.000554	90.9	70-130			
Matrix Spike (BD71407-MS2)		Source: L170433-11		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.00919	0.00101	mg/L	0.0101	5.70E-5	90.4	70-130			
Matrix Spike (BD71407-MS3)		Source: L170435-04		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.00916	0.00101	mg/L	0.0101	5.10E-5	90.2	70-130			
Matrix Spike (BD71407-MS4)		Source: L170435-14		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0139	0.00101	mg/L	0.0101	0.00471	91.4	70-130			
Matrix Spike (BD71407-MS5)		Source: L170428-07		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0121	0.00101	mg/L	0.0101	3.60E-5	120	70-130			

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

### Total Metals by ICPMS - Quality Control

#### Tucson Water Quality Laboratory

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Matrix Spike (BD71407-MS6)		Source: L170431-01		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.00976	0.00101	mg/L	0.0101	0.000433	92.3	70-130			
Matrix Spike (BD71407-MS7)		Source: L170431-11		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0120	0.00101	mg/L	0.0101	0.00271	91.6	70-130			
Matrix Spike (BD71407-MS8)		Source: L170444-03		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0108	0.00101	mg/L	0.0101	0.00128	94.7	70-130			
Matrix Spike (BD71407-MS9)		Source: L170444-13		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0106	0.00101	mg/L	0.0101	0.00107	94.7	70-130			
Matrix Spike Dup (BD71407-MSD1)		Source: L170433-01		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.00998	0.00101	mg/L	0.0101	0.000554	93.4	70-130	2.49	10	

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

### Total Metals by ICPMS - Quality Control

#### Tucson Water Quality Laboratory

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Matrix Spike Dup (BD71407-MSD2)		Source: L170433-11		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.00916	0.00101	mg/L	0.0101	5.70E-5	90.2	70-130	0.308	10	
Matrix Spike Dup (BD71407-MSD3)		Source: L170435-04		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.00914	0.00101	mg/L	0.0101	5.10E-5	90.0	70-130	0.243	10	
Matrix Spike Dup (BD71407-MSD4)		Source: L170435-14		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0139	0.00101	mg/L	0.0101	0.00471	90.8	70-130	0.429	10	
Matrix Spike Dup (BD71407-MSD5)		Source: L170428-07		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0122	0.00101	mg/L	0.0101	3.60E-5	121	70-130	0.581	10	
Matrix Spike Dup (BD71407-MSD6)		Source: L170431-01		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.00973	0.00101	mg/L	0.0101	0.000433	92.0	70-130	0.290	10	

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*



Tucson Water Quality Lab  
 4401 S. Tucson Estates Pkwy.  
 Tucson, AZ 85735  
 (520) 837-2455

Arizona Department of Environmental Quality  
 1110 West Washington Street  
 Phoenix AZ, 85007

Project: Public School Lead Screening Program  
 Project Number: P01210  
 Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
 04/26/2017 10:38

### Total Metals by ICPMS - Quality Control

#### Tucson Water Quality Laboratory

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Matrix Spike Dup (BD71407-MSD7)		Source: L170431-11		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0119	0.00101	mg/L	0.0101	0.00271	90.9	70-130	0.576	10	
Matrix Spike Dup (BD71407-MSD8)		Source: L170444-03		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0109	0.00101	mg/L	0.0101	0.00128	95.0	70-130	0.316	10	
Matrix Spike Dup (BD71407-MSD9)		Source: L170444-13		Prepared & Analyzed: 04/14/2017						
Batch BD71407 - EPA 200.7/200.8										
LEAD	0.0107	0.00101	mg/L	0.0101	0.00107	94.9	70-130	0.209	10	
Blank (BD71804-BLK1)				Prepared: 04/17/2017 Analyzed: 04/18/2017						
Batch BD71804 - EPA 200.7/200.8										
LEAD	ND	0.00100	mg/L							
LCS (BD71804-BS1)				Prepared: 04/17/2017 Analyzed: 04/18/2017						
Batch BD71804 - EPA 200.7/200.8										
LEAD	0.00955	0.00100	mg/L	0.0100		95.5	85-115			

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
4401 S. Tucson Estates Pkwy.  
Tucson, AZ 85735  
(520) 837-2455

Arizona Department of Environmental Quality  
1110 West Washington Street  
Phoenix AZ, 85007

Project: Public School Lead Screening Program

Project Number: P01210

Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
04/26/2017 10:38

### Total Metals by ICPMS - Quality Control

### Tucson Water Quality Laboratory

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	--------------------	-------	----------------	------------------	------	----------------	-----	--------------	-------

**Matrix Spike (BD71804-MS1)**

**Source: L170418-01**

Prepared: 04/17/2017 Analyzed: 04/18/2017

#### **Batch BD71804 - EPA 200.7/200.8**

LEAD	0.00938	0.00100	mg/L	0.0100	0.000226	91.5	70-130			
------	---------	---------	------	--------	----------	------	--------	--	--	--

**Matrix Spike Dup (BD71804-MSD1)**

**Source: L170418-01**

Prepared: 04/17/2017 Analyzed: 04/18/2017

#### **Batch BD71804 - EPA 200.7/200.8**

LEAD	0.00937	0.00100	mg/L	0.0100	0.000226	91.5	70-130	0.0640	10	
------	---------	---------	------	--------	----------	------	--------	--------	----	--

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Tucson Water Quality Lab  
4401 S. Tucson Estates Pkwy.  
Tucson, AZ 85735  
(520) 837-2455

Arizona Department of Environmental Quality	Project: Public School Lead Screening Program	
1110 West Washington Street	Project Number: P01210	<b>Reported:</b>
Phoenix AZ, 85007	Project Manager: Water Quality Compliance 5415B-1	04/26/2017 10:38

Certified Analyses included in this Report

Analyte	Certifications
---------	----------------

Code	Description	Number	Expires
------	-------------	--------	---------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

**Tucson Water Quality Lab**  
**4401 S. Tucson Estates Pkwy.**  
**Tucson, AZ 85735**  
**(520) 837-2455**

Arizona Department of Environmental Quality  
1110 West Washington Street  
Phoenix AZ, 85007

Project: Public School Lead Screening Program  
Project Number: P01210  
Project Manager: Water Quality Compliance 5415B-1

**Reported:**  
04/26/2017 10:38

### Notes and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the reporting limit
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference

---

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

### Items for Project Manager Review

LabNumber	Analysis	Analyte	Exception
-----------	----------	---------	-----------

---

E

# TUCSON WATER CHAIN OF CUSTODY

Page 1 of 2

Page 30 of 31

<b>LOGIN ID:</b> <u>L170431</u> <b>CLIENT:</b> ADEQ <b>PROJECT NAME/FREQUENCY:</b> Public School Lead Screening Program <b>PROJECT #:</b> P01210 <b>SAMPLING DATE:</b> <u>03-21-17</u> <b>SAMPLED BY:</b> print full name <u>TUSD ERNIE GAUVIN</u> <i>10:16 3-21-17</i> signature <u>[Signature]</u>				PRESERVATIVE		(HNO3 added in lab)			PROPERTY NAME	ADDRESS	PROPERTY TYPE	COMMENTS			
NUMBER OF CONTAINERS	Pb (200.8)	COMPLIANCE (Y / N)													
SAMPLE #	TIME	LOCATION	SITE		CPMS										
-01	11:23	Main dr 137	01	1	X	N	WHITE ES	2315 W CANADA ST	TUSD	water fountain	mens RR				
-02	11:27	Main dr 60	02	1	X	N	↓	↓			dr water fountain				
-03	11:32	East #216	03	1	X	N					water fountain	Rm #27			
-04	11:34	East DR 201	04	1	X	N					water fountain	Rm #20			
-05	11:38	Activity DR 105	05	1	X	N					water fountain	jeanitor 105			
-06	11:42	South DR 187	06	1	X	N					water fountain	RR 187			
-07	11:56.5	Library DR 97	07	1	X	N					water fountain	girl RR 202			
-08	12:00	Library 98	08	1	X	N					↓	↓	↓	↓	sink in corridor 201
-09	10:25	main bldg 116A	01	1	X	N	ROSE ES	710 W Michigan Dr		water fountain					
-10	10:33	Wellness 152	02	1	X	N	↓	↓		water fountain					
-11	12:57	main DR 216B	03	1	X	N	↓	↓		water fountain					
-12	09:30	main bldg dr #1	01	1	X	N	Hollinger ES K8	150 W AJO Way		water fountain	Rm #210				
-13	09:40	main bldg DR 76	02	1	X	N	↓	↓		water fountain	Rm 305				
-14	09:50	MPR-DR CIB	03	1	X	N	↓	↓		water fountain	Rm C-1				
-15	09:59	locker room DR 84	04	1	X	N	↓	↓		water fountain	locker				
<b>COMMENTS:</b> CONTACT: TINA COOK 225-4673															
SIGNATURE				DATE/TIME				SIGNATURE				DATE/TIME			
RELINQUISHED BY: <u>[Signature]</u>				03-28-17 10:53				RECEIVED BY: <u>[Signature]</u>				10:27 03/28/2017			
RELINQUISHED BY: <u>[Signature]</u>				03-28-17 12:50				RECEIVED BY: <u>[Signature]</u>				03-28-17 10:54			
RELINQUISHED BY: <u>[Signature]</u>								RECEIVED BY: <u>[Signature]</u>				3-28-17 12:45			

3/29/17

24.6°C

## TUCSON WATER CHAIN OF CUSTODY

Page 2 of 2

Page 31 of 31

<b>LOGIN ID:</b> <u>L176431</u> <b>CLIENT: ADEQ</b> <u>3-28-17</u> <b>PROJECT NAME/FREQUENCY:</b> Public School Lead Screening Program <b>PROJECT #:</b> P01210 <b>SAMPLING DATE:</b> <u>03-21-2017</u> <b>SAMPLED BY:</b> print full name <u>TUSD Ernie Gauvin</u> signature				PRESERVATIVE		(HNO3 added in lab)				PROPERTY NAME	ADDRESS	PROPERTY TYPE	COMMENTS		
NUMBER OF CONTAINERS		Pb (200.8)	COMPLIANCE (Y/N)												
SAMPLE #	TIME	LOCATION	SITE			CPMS									
16-04	10:03	locker rm 149	05	1		X	N	Hollinger K-8	150 W AJO WAY	TUSD	water fountain				
17-02	10:06	west bldg DR-133	06	1		X	N	↓	↓	↓	water fountain, classroom M-5				
18-03	10:10	W bldg #144	07	1		X	N	↓	↓	↓	water fountain, classroom M-1				
19-04	10:15	library DR 83	08	1		X	N	↓	↓	↓	water fountain				
-05															
-06															
-07															
-08															
-09															
-10															
-11															
-12															
-13															
-14															
-15															
COMMENTS:				CONTACT: TINA COOK 225-4673											
SIGNATURE				DATE/TIME				SIGNATURE				DATE/TIME			
RELINQUISHED BY: <u>[Signature]</u>				03-28-17 10:53				RECEIVED BY: <u>[Signature]</u>				10:27 03/28/2017			
RELINQUISHED BY: <u>[Signature]</u>				03-28-17 12:50				RECEIVED BY: <u>[Signature]</u>				03-28-17 10:54			
RELINQUISHED BY: <u>[Signature]</u>								RECEIVED BY: <u>[Signature]</u>				3-28-17 12:45			

24.6°C