



4401 S. Tucson Estates Parkway
Tucson, Arizona 85735
520.791.2544 Phone
520.791.5260 Fax

18 April 2017

Water Quality Compliance 5415B-1
Arizona Department of Environmental Quality
1110 West Washington Street
Tucson, AZ 85735
RE: Public School Lead Screening Program

Enclosed are the results for Work Order L170442, received by the laboratory on 03/28/2017 15:38. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michael E. Dew
Lab Manager

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
1110 West Washington Street
Phoenix AZ, 85007

Project: Public School Lead Screening Program
Project Number: P01210
Project Manager: Water Quality Compliance 5415B-1

Reported:
04/18/2017 10:05

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
M Rm M117	L170442-01	Aqueous	03/21/2017 07:00	03/28/2017 15:38
Rm 115 RR	L170442-02	Aqueous	03/21/2017 07:05	03/28/2017 15:38
N. Hallway DF	L170442-03	Aqueous	03/21/2017 07:30	03/28/2017 15:38
N. Hallway DF	L170442-04	Aqueous	03/21/2017 11:15	03/28/2017 15:38
M 202 DF 217A	L170442-05	Aqueous	03/21/2017 07:45	03/28/2017 15:38
M 202 DF 217A	L170442-06	Aqueous	03/21/2017 07:50	03/28/2017 15:38
Library DF	L170442-07	Aqueous	03/21/2017 08:00	03/28/2017 15:38
Library DF 155	L170442-08	Aqueous	03/21/2017 08:15	03/28/2017 15:38
Main ofc	L170442-09	Aqueous	03/21/2017 08:45	03/28/2017 15:38
Main DF #21	L170442-10	Aqueous	03/21/2017 08:55	03/28/2017 15:38
Fine Arts	L170442-11	Aqueous	03/21/2017 09:15	03/28/2017 15:38
Fine Arts	L170442-12	Aqueous	03/21/2017 09:30	03/28/2017 15:38
Science Rm 106	L170442-13	Aqueous	03/21/2017 10:00	03/28/2017 15:38
Science Rm 104	L170442-14	Aqueous	03/21/2017 10:15	03/28/2017 15:38
Interscholastic	L170442-15	Aqueous	03/21/2017 10:30	03/28/2017 15:38
Interscholastic 512	L170442-16	Aqueous	03/21/2017 10:50	03/28/2017 15:38
Central Plant	L170442-17	Aqueous	03/21/2017 11:00	03/28/2017 15:38
Central Plant	L170442-18	Aqueous	03/21/2017 11:35	03/28/2017 15:38
Gymnasium DF G113	L170442-19	Aqueous	03/21/2017 11:45	03/28/2017 15:38
Aero Tech DF 407	L170442-20	Aqueous	03/21/2017 11:45	03/28/2017 15:38
N Gym F-361	L170442-21	Aqueous	03/21/2017 11:50	03/28/2017 15:38
N Gym DF 360	L170442-22	Aqueous	03/21/2017 12:00	03/28/2017 15:38
Stadium Door	L170442-23	Aqueous	03/21/2017 15:15	03/28/2017 15:38
Central Plant	L170442-24	Aqueous	03/22/2017 06:30	03/28/2017 15:38
Cafeteria Dining	L170442-25	Aqueous	03/22/2017 06:40	03/28/2017 15:38
Cafeteria	L170442-26	Aqueous	03/22/2017 06:45	03/28/2017 15:38

Tucson Water Quality Laboratory



Michael E. Dew, Lab Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
1110 West Washington Street
Phoenix AZ, 85007

Project: Public School Lead Screening Program
Project Number: P01210
Project Manager: Water Quality Compliance 5415B-1

Reported:
04/18/2017 10:05

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
East Wing	L170442-27	Aqueous	03/22/2017 07:00	03/28/2017 15:38
East Wing sink	L170442-28	Aqueous	03/22/2017 07:30	03/28/2017 15:38
Main (ELKAY)	L170442-29	Aqueous	03/22/2017 07:45	03/28/2017 15:38
Main Health ofc	L170442-30	Aqueous	03/22/2017 07:28	03/28/2017 15:38
Main Library	L170442-31	Aqueous	03/22/2017 08:30	03/28/2017 15:38
Main Library	L170442-32	Aqueous	03/22/2017 08:45	03/28/2017 15:38
East Stadium	L170442-33	Aqueous	03/22/2017 09:15	03/28/2017 15:38
East Stadium	L170442-34	Aqueous	03/22/2017 09:45	03/28/2017 15:38
W. Stadium	L170442-35	Aqueous	03/22/2017 10:00	03/28/2017 15:38
W. Stadium	L170442-36	Aqueous	03/22/2017 10:15	03/28/2017 15:38
West Gym	L170442-37	Aqueous	03/22/2017 10:30	03/28/2017 15:38
West Gym	L170442-38	Aqueous	03/22/2017 10:45	03/28/2017 15:38
Vocational Bldg	L170442-39	Aqueous	03/22/2017 10:45	03/28/2017 15:38
Vocational Bldg	L170442-40	Aqueous	03/22/2017 09:06	03/28/2017 15:38
Tech Bldg Lobby	L170442-41	Aqueous	03/22/2017 11:30	03/28/2017 15:38
Cherry Locker #1	L170442-42	Aqueous	03/22/2017 11:50	03/28/2017 15:38
Cherry Locker	L170442-43	Aqueous	03/22/2017 11:55	03/28/2017 15:38

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
1110 West Washington Street
Phoenix AZ, 85007

Project: Public School Lead Screening Program
Project Number: P01210
Project Manager: Water Quality Compliance 5415B-1

Reported:
04/18/2017 10:05

M Rm M117
L170442-01RE1 (Aqueous)

Sampled:
03/21/2017 7:00

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00134	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality	Project: Public School Lead Screening Program	
1110 West Washington Street	Project Number: P01210	Reported:
Phoenix AZ, 85007	Project Manager: Water Quality Compliance 5415B-1	04/18/2017 10:05

Rm 115 RR
L170442-02 (Aqueous)

Sampled:
03/21/2017 7:05

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8	
------	----	---------	------	---	---------	------------	------------	-----------	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

N. Hallway DF
L170442-03 (Aqueous)

Sampled:
 03/21/2017 7:30

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
1110 West Washington Street
Phoenix AZ, 85007

Project: Public School Lead Screening Program
Project Number: P01210
Project Manager: Water Quality Compliance 5415B-1

Reported:
04/18/2017 10:05

N. Hallway DF
L170442-04 (Aqueous)

Sampled:
03/21/2017 11:15

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

M 202 DF 217A
L170442-05 (Aqueous)

Sampled:
 03/21/2017 7:45

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00124	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

M 202 DF 217A
L170442-06 (Aqueous)

Sampled:
 03/21/2017 7:50

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality	Project: Public School Lead Screening Program	Reported:
1110 West Washington Street	Project Number: P01210	04/18/2017 10:05
Phoenix AZ, 85007	Project Manager: Water Quality Compliance 5415B-1	

Library DF
L170442-07 (Aqueous)

Sampled:
03/21/2017 8:00

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8		
------	----	---------	------	---	---------	------------	------------	-----------	--	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Library DF 155
L170442-08 (Aqueous)

Sampled:
 03/21/2017 8:15

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Main ofc
L170442-09 (Aqueous)

Sampled:
 03/21/2017 8:45

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

Main DF #21
L170442-10 (Aqueous)

Sampled:
 03/21/2017 8:55

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Fine Arts
L170442-11 (Aqueous)

Sampled:
 03/21/2017 9:15

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Fine Arts
L170442-12 (Aqueous)

Sampled:
 03/21/2017 9:30

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00586	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Science Rm 106
L170442-13RE1 (Aqueous)

Sampled:
 03/21/2017 10:00

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.0535	0.00500	mg/L	5	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	---------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Science Rm 104
L170442-14RE1 (Aqueous)

Sampled:
 03/21/2017 10:15

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.0514	0.00500	mg/L	5	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	---------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

Interscholastic
L170442-15 (Aqueous)

Sampled:
 03/21/2017 10:30

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00230	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Interscholastic 512
L170442-16 (Aqueous)

Sampled:
 03/21/2017 10:50

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Central Plant
L170442-17 (Aqueous)

Sampled:
 03/21/2017 11:00

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00371	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Central Plant
L170442-18 (Aqueous)

Sampled:
 03/21/2017 11:35

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00332	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

Gymnasium DF G113
L170442-19 (Aqueous)

Sampled:
03/21/2017 11:45

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8	
------	----	---------	------	---	---------	------------	------------	-----------	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Aero Tech DF 407
L170442-20 (Aqueous)

Sampled:
 03/21/2017 11:45

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

N Gym F-361
L170442-21 (Aqueous)

Sampled:
 03/21/2017 11:50

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00127	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	-------------------------------

N Gym DF 360
L170442-22 (Aqueous)

Sampled:
03/21/2017 12:00

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8	
------	----	---------	------	---	---------	------------	------------	-----------	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Stadium Door
L170442-23 (Aqueous)

Sampled:
 03/21/2017 15:15

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Central Plant
L170442-24 (Aqueous)

Sampled:
 03/22/2017 6:30

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Cafeteria Dining
L170442-25 (Aqueous)

Sampled:
 03/22/2017 6:40

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
1110 West Washington Street
Phoenix AZ, 85007

Project: Public School Lead Screening Program
Project Number: P01210
Project Manager: Water Quality Compliance 5415B-1

Reported:
04/18/2017 10:05

Cafeteria
L170442-26 (Aqueous)

Sampled:
03/22/2017 6:45

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00175	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

East Wing
L170442-27 (Aqueous)

Sampled:
 03/22/2017 7:00

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

East Wing sink
L170442-28 (Aqueous)

Sampled:
 03/22/2017 7:30

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00117	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Main (ELKAY)
L170442-29 (Aqueous)

Sampled:
 03/22/2017 7:45

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Main Health ofc
L170442-30 (Aqueous)

Sampled:
 03/22/2017 7:28

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Main Library
L170442-31 (Aqueous)

Sampled:
 03/22/2017 8:30

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

Main Library
L170442-32 (Aqueous)

Sampled:
03/22/2017 8:45

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8		
------	----	---------	------	---	---------	------------	------------	-----------	--	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

East Stadium
L170442-33 (Aqueous)

Sampled:
 03/22/2017 9:15

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00127	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

East Stadium
L170442-34 (Aqueous)

Sampled:
 03/22/2017 9:45

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

W. Stadium
L170442-35 (Aqueous)

Sampled:
03/22/2017 10:00

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8	
------	----	---------	------	---	---------	------------	------------	-----------	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

W. Stadium
L170442-36 (Aqueous)

Sampled:
 03/22/2017 10:15

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	0.00192	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
-------------	----------------	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

West Gym
L170442-37 (Aqueous)

Sampled:
03/22/2017 10:30

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8	
------	----	---------	------	---	---------	------------	------------	-----------	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

West Gym
L170442-38 (Aqueous)

Sampled:
 03/22/2017 10:45

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

Vocational Bldg
L170442-39 (Aqueous)

Sampled:
 03/22/2017 10:45

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8	
------	----	---------	------	---	---------	------------	------------	-----------	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Vocational Bldg
L170442-40 (Aqueous)

Sampled:
 03/22/2017 9:06

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Tech Bldg Lobby
L170442-41 (Aqueous)

Sampled:
 03/22/2017 11:30

Analyte	Result	Reporting		Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
		Limit								

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

Cherry Locker #1
L170442-42 (Aqueous)

Sampled:
03/22/2017 11:50

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8	
------	----	---------	------	---	---------	------------	------------	-----------	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality 1110 West Washington Street Phoenix AZ, 85007	Project: Public School Lead Screening Program Project Number: P01210 Project Manager: Water Quality Compliance 5415B-1	Reported: 04/18/2017 10:05
---	--	--------------------------------------

Cherry Locker
L170442-43 (Aqueous)

Sampled:
 03/22/2017 11:55

Analyte	Result	Reporting			Batch	Prepared	Analyzed	Method	Notes
		Limit	Units	Dilution					

Tucson Water Quality Laboratory

Total Metals by ICPMS

LEAD	ND	0.00100	mg/L	1	BD71002	04/07/2017	04/07/2017	EPA 200.8
------	----	---------	------	---	---------	------------	------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Total Metals by ICPMS - Quality Control

Tucson Water Quality Laboratory

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Matrix Spike (BD71002-MS1)		Source: L170441-01		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.0102	0.00101	mg/L	0.0101	0.000600	95.2	70-130			
Matrix Spike (BD71002-MS2)		Source: L170441-11		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.00997	0.00101	mg/L	0.0101	0.000562	93.1	70-130			
Matrix Spike (BD71002-MS3)		Source: L170442-03		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.00996	0.00101	mg/L	0.0101	0.000342	95.2	70-130			
Matrix Spike (BD71002-MS5)		Source: L170442-23		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.00980	0.00101	mg/L	0.0101	0.000176	95.3	70-130			
Matrix Spike (BD71002-MS6)		Source: L170442-33		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.0106	0.00101	mg/L	0.0101	0.00127	92.3	70-130			

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
1110 West Washington Street
Phoenix AZ, 85007

Project: Public School Lead Screening Program
Project Number: P01210
Project Manager: Water Quality Compliance 5415B-1

Reported:
04/18/2017 10:05

Total Metals by ICPMS - Quality Control

Tucson Water Quality Laboratory

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Matrix Spike (BD71002-MS7)		Source: L170442-43		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.0102	0.00101	mg/L	0.0101	0.000767	93.5	70-130			
Matrix Spike (BD71002-MS8)		Source: L170442-13RE1		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.0631	0.00500	mg/L	0.0100	0.0535	95.2	70-130			
Matrix Spike Dup (BD71002-MSD1)		Source: L170441-01		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.0102	0.00101	mg/L	0.0101	0.000600	94.9	70-130	0.297	10	
Matrix Spike Dup (BD71002-MSD2)		Source: L170441-11		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.00993	0.00101	mg/L	0.0101	0.000562	92.7	70-130	0.376	10	
Matrix Spike Dup (BD71002-MSD3)		Source: L170442-03		Prepared & Analyzed: 04/07/2017						
Batch BD71002 - EPA 200.7/200.8										
LEAD	0.00995	0.00101	mg/L	0.0101	0.000342	95.1	70-130	0.0913	10	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
 4401 S. Tucson Estates Pkwy.
 Tucson, AZ 85735
 (520) 837-2455

Arizona Department of Environmental Quality
 1110 West Washington Street
 Phoenix AZ, 85007

Project: Public School Lead Screening Program
 Project Number: P01210
 Project Manager: Water Quality Compliance 5415B-1

Reported:
 04/18/2017 10:05

Total Metals by ICPMS - Quality Control

Tucson Water Quality Laboratory

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	--------------------	-------	----------------	------------------	------	----------------	-----	--------------	-------

Matrix Spike Dup (BD71002-MSD5)

Source: L170442-23

Prepared & Analyzed: 04/07/2017

Batch BD71002 - EPA 200.7/200.8

LEAD	0.00978	0.00101	mg/L	0.0101	0.000176	95.1	70-130	0.206	10	
------	---------	---------	------	--------	----------	------	--------	-------	----	--

Matrix Spike Dup (BD71002-MSD6)

Source: L170442-33

Prepared & Analyzed: 04/07/2017

Batch BD71002 - EPA 200.7/200.8

LEAD	0.0106	0.00101	mg/L	0.0101	0.00127	91.9	70-130	0.296	10	
------	--------	---------	------	--------	---------	------	--------	-------	----	--

Matrix Spike Dup (BD71002-MSD7)

Source: L170442-43

Prepared & Analyzed: 04/07/2017

Batch BD71002 - EPA 200.7/200.8

LEAD	0.0102	0.00101	mg/L	0.0101	0.000767	93.4	70-130	0.0890	10	
------	--------	---------	------	--------	----------	------	--------	--------	----	--

Matrix Spike Dup (BD71002-MSD8)

Source: L170442-13RE1

Prepared & Analyzed: 04/07/2017

Batch BD71002 - EPA 200.7/200.8

LEAD	0.0630	0.00500	mg/L	0.0100	0.0535	94.8	70-130	0.0634	10	
------	--------	---------	------	--------	--------	------	--------	--------	----	--

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality	Project: Public School Lead Screening Program	
1110 West Washington Street	Project Number: P01210	Reported:
Phoenix AZ, 85007	Project Manager: Water Quality Compliance 5415B-1	04/18/2017 10:05

Certified Analyses included in this Report

Analyte	Certifications
---------	----------------

Code	Description	Number	Expires
------	-------------	--------	---------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Tucson Water Quality Lab
4401 S. Tucson Estates Pkwy.
Tucson, AZ 85735
(520) 837-2455

Arizona Department of Environmental Quality
1110 West Washington Street
Phoenix AZ, 85007

Project: Public School Lead Screening Program
Project Number: P01210
Project Manager: Water Quality Compliance 5415B-1

Reported:
04/18/2017 10:05

Notes and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the reporting limit
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Items for Project Manager Review

LabNumber	Analysis	Analyte	Exception
-----------	----------	---------	-----------

TUCSON WATER CHAIN OF CUSTODY

Page 1 of 3

LOGIN ID: <u>L170442</u> CLIENT: ADEQ PROJECT NAME/FREQUENCY: Public School Lead Screening Program PROJECT #: P01210 SAMPLING DATE: <u>03-21-2017</u> SAMPLED BY: print full name <u>CELIO ECHENIQUE</u> signature _____				PRESERVATIVE		(HNO3 added in lab)			PROPERTY NAME	ADDRESS	PROPERTY TYPE	COMMENTS			
NUMBER OF CONTAINERS	Pb (200.8)	COMPLIANCE (Y / N)													
SAMPLE #	TIME	LOCATION	SITE		CPMS										
-01	07:00	M Rm M117	01	1	X	N	CATALINA MAGNET HS	3645 E Pima St	TUSD	sink					
-02	07:05	Rm 115 RR	02	1	X	N				sink FR-232					
-03	07:30	N-Hallway df	03	1	X	N				drinking fountain					
-04	11:15	N-Hallway df	04	1	X	N				drinking fountain					
-05	07:45	M-202 df 217A	05	1	X	N				sink, df 217A					
-06	07:50	M-202 df 217A	06	1	X	N				sink, RR					
-07	08:00	library df	07	1	X	N				drinking fountain					
-08	08:15	library df 155	08	1	X	N				sink RR					
-09	08:45	main ofc	09	1	X	N				sink by df #21					
-10	08:55	main df #21	10	1	X	N				drinking fountain					
-11	09:15	Fine Arts	11	1	X	N				drinking fountain					
-12	09:30	Fine Arts	12	1	X	N				RR sink					
-13	10:00	Science Rm 104	13	1	X	N				sink 104A					
-14	10:15	Science Rm 104	14	1	X	N				sink df 101B					
-15	10:30	Interscholastic	15	1	X	N				sink df 501					
COMMENTS: CONTACT: TINA COOK 225-4673															
SIGNATURE				DATE/TIME				SIGNATURE				DATE/TIME			
RELINQUISHED BY:				03-28-17 15:22				RECEIVED BY:				03-28-17 12:08			
RELINQUISHED BY:								RECEIVED BY:				03/28/17 15:38			
RELINQUISHED BY:								RECEIVED BY:							

24.3°C

TUCSON WATER CHAIN OF CUSTODY

Page 2 of 3

LOGIN ID: <u>L170442</u> CLIENT: ADEQ PROJECT NAME/FREQUENCY: Public School Lead Screening Program PROJECT #: P01210 SAMPLING DATE: <u>03-21-2017</u> SAMPLED BY: print full name <u>CELIO ECHENIQUE</u> signature				PRESERVATIVE	NUMBER OF CONTAINERS	Pb (200.8)	COMPLIANCE (Y / N)	PROPERTY NAME	ADDRESS	PROPERTY TYPE	COMMENTS				
SAMPLE #	TIME	LOCATION	SITE		CPMS										
16- 01	10:50	Interscholastic ⁵¹²	16	1	X	N	Catalina Magnet HS	3645 E Pima St	TVSD		sink RR				
17- 02	11:00	Central Plant	17	1	X	N					drinking fountain df 592				
18- 03	11:35	Central Plant	18	1	X	N					sink Hand Room				
19- 04	11:45	Gymnasium ^{df 6113}	19	1	X	N					drinking faucet df 6113				
20- 05	11:45	Aero Tech df 407	20	1	X	N					drinking fountain df 407				
21- 06	11:50	N-Gym f-361A	21	1	X	N					drinking fountain, door				
22- 07	12:00	N-Gym df 360	22	1	X	N					sink df 360				
23- 08	15:15	Stadium door	23	1	X	N					sink f-514				
24- 09	06:30	Central Plant	01	1	X	N	Tucson Magnet HS	400 N. 2ND AVE			Sink				
25- 10	06:40	cafeteria dining	02	1	X	N					drinking fountain				
26- 11	06:45	cafeteria	03	1	X	N					kitchen sink				
27- 12	07:00	east wing	04	1	X	N					drinking fountain				
28- 13	07:30	east wing sink	05	1	X	N					sink / m RR				
29- 14	07:45	main (ELKAY)	06	1	X	N					drinking fountain				
30- 15	07:28	main Hlth ofc	07	1	X	N					drinking fountain				
COMMENTS:				CONTACT: TINA COOK 225-4673											
SIGNATURE				DATE/TIME				SIGNATURE				DATE/TIME			
RELINQUISHED BY:								RECEIVED BY:				03-28-17 12:08			
RELINQUISHED BY:								RECEIVED BY:				03/28/17 1538			
RELINQUISHED BY:								RECEIVED BY:							

03-28-17
11:44
Collection Date 3/22/17
3/24/17

TUCSON WATER CHAIN OF CUSTODY

Page 3 of 3

Page 55 of 55

LOGIN ID: L170442 CLIENT: ADEQ PROJECT NAME/FREQUENCY: Public School Lead Screening Program PROJECT #: P01210 SAMPLING DATE: 03-25-2017 SAMPLED BY: 03/29/17 print full name CELIO ECHENIQUE signature				PRESERVATIVE (HNO3 added in lab)		NUMBER OF CONTAINERS Pb (200.8) COMPLIANCE (Y / N)		PROPERTY NAME ADDRESS PROPERTY TYPE COMMENTS	
SAMPLE #	TIME	LOCATION	SITE		CPMS				
31- 31	08:30	main library	08	1	X	N	TUCSON MAGNETHS	400 N. 2ND AVE	TUSD
32- 32	08:45	main library	09	1	X	N			
33- 33	09:15	east stadium	10	1	X	N			
34- 34	09:45	east stadium	11	1	X	N			
35- 35	10:00	W. Stadium	12	1	X	N			
36- 36	10:15	W. Stadium	13	1	X	N			
37- 37	10:30	West Gym	14	1	X	N			
38- 38	10:45	West Gym	15	1	X	N			
39- 39	10:45	Vocational Bldg	16	1	X	N			
40- 40	09:06	Vocational Bldg	17	1	X	N			
41- 41	11:30	Tech Bldg Lobby	18	1	X	N			
42- 42	11:50	Cherry Locker 1	19	1	X	N			
43- 43	11:55	Cherry Locker	20	1	X	N			
-14					X		okay. 03-28-17		
-15					X				
COMMENTS:		CONTACT: TINA COOK 225-4673							
SIGNATURE		DATE/TIME		SIGNATURE		DATE/TIME			
RELINQUISHED BY:		03-28-17 15:22		RECEIVED BY:		03-28-17 12:09			
RELINQUISHED BY:				RECEIVED BY:		03/28/17 1538			
RELINQUISHED BY:				RECEIVED BY:					

24.3°C

03-28-17
11:45

DF191A

GRR ESD6

A160A df

Rm 123