

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: Sabino High school

Reported:
06/23/17 14:59

Analyte

1 Confirmation- First Draw (7061981-01) Drinking Water (Grab) Sampled: 06/20/17 06:28 Received: 06/21/17 10:10

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	30	5.0	ug/L	1	B7F1675	06/21/17 13:33	06/22/17 15:40	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

2 Confirmation- Flush (7061981-02) Drinking Water (Grab) Sampled: 06/20/17 06:30 Received: 06/21/17 10:10

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	8.8	5.0	ug/L	1	B7F1675	06/21/17 13:33	06/22/17 15:44	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

2 Confirmation- First Draw (7061981-03) Drinking Water (Grab) Sampled: 06/20/17 12:44 Received: 06/21/17 10:10

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	14	5.0	ug/L	1	B7F1675	06/21/17 13:33	06/22/17 15:57	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

4 Screening (7061981-04) Drinking Water (Grab) Sampled: 06/20/17 06:33 Received: 06/21/17 10:10

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1675	06/21/17 13:33	06/22/17 16:01	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

5 Screening (7061981-05) Drinking Water (Grab) Sampled: 06/20/17 06:36 Received: 06/21/17 10:10

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	17	5.0	ug/L	1	B7F1675	06/21/17 13:33	06/22/17 16:13	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 26.60 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.

All samples were analyzed on a "wet" basis unless designated as "dry weight".

Notes and Definitions

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	
RELINQUISHING AGENT SIGNATURE:	
SIGNATORY NAME PRINTED:	

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	6/21/17
TIME LAB RECEIVED:	1010
LAB SIGNATURE:	<i>[Signature]</i>
LAB SIGNATORY NAME PRINTED:	ROMANO FLORES
NOTES:	Preserved @ Lab Temp 26.6°C

<i>[Signature]</i>	6/21/17
ROMANO FLORES	1600
COOPER	6/21/17
	1600