



April 19, 2017

Victor Scherer
Arizona Department of Environmental Quality-Phx
1110 W. Washington Street
Phoenix, AZ 85007

TEL (520) 398-2266
FAX (602) 207-2383

RE: Lead Analysis

Work Order No.: 17D0320
Order Name: Flowing Wells
Unified District

Dear Victor Scherer,

Turner Laboratories, Inc. received 13 sample(s) on 04/03/2017 for the analyses presented in the following report.

All results are intended to be considered in their entirety, and Turner Laboratories, Inc. is not responsible for use of less than the complete report. Results apply only to the samples analyzed. Samples will be disposed of 30 days after issue of our report unless special arrangements are made.

The pages that follow may contain sensitive, privileged or confidential information intended solely for the addressee named above. If you receive this message and are not the agent or employee of the addressee, this communication has been sent in error. Please do not disseminate or copy any of the attached and notify the sender immediately by telephone. Please also return the attached sheet(s) to the sender by mail.

Please call if you have any questions.

Respectfully submitted,

Turner Laboratories, Inc.
ADHS License AZ0066

Max DiSante
Laboratory Director

Client: Arizona Department of Environmental Quality-P**Project:** Lead Analysis**Work Order:** 17D0320**Date Received:** 04/03/2017**Order:** Flowing Wells Unified District**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Matrix	Collection Date/Time
17D0320-01	Laguna-1	Drinking Water	04/02/2017 1352
17D0320-02	Laguna-2	Drinking Water	04/02/2017 1350
17D0320-03	Laguna-3	Drinking Water	04/02/2017 1348
17D0320-04	Laguna-4	Drinking Water	04/02/2017 1347
17D0320-05	Laguna-5	Drinking Water	04/02/2017 1342
17D0320-06	Laguna-6	Drinking Water	04/02/2017 1339
17D0320-07	Laguna-7	Drinking Water	04/02/2017 1336
17D0320-08	Laguna-8	Drinking Water	04/02/2017 1333
17D0320-09	Laguna-9	Drinking Water	04/02/2017 1331
17D0320-10	Laguna-10	Drinking Water	04/02/2017 1328
17D0320-11	Laguna-11	Drinking Water	04/02/2017 1326
17D0320-12	Laguna-12	Drinking Water	04/02/2017 1321
17D0320-13	Laguna-13	Drinking Water	04/02/2017 1320

Client: Arizona Department of Environmental Quality-Phx
Project: Lead Analysis
Work Order: 17D0320
Date Received: 04/03/2017

Case Narrative

All soil, sludge, and solid matrix determinations are reported on a wet weight basis unless otherwise noted.

ND Not Detected at or above the PQL

PQL Practical Quantitation Limit

DF Dilution Factor

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-01

Client Sample ID: Laguna-1
Collection Date/Time: 04/02/2017 1352
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	1.9	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1603	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-02

Client Sample ID: Laguna-2
Collection Date/Time: 04/02/2017 1350
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	0.68	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1608	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-03

Client Sample ID: Laguna-3
Collection Date/Time: 04/02/2017 1348
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	ND	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1614	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-04

Client Sample ID: Laguna-4
Collection Date/Time: 04/02/2017 1347
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	ND	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1630	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-05

Client Sample ID: Laguna-5
Collection Date/Time: 04/02/2017 1342
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	0.53	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1635	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-06

Client Sample ID: Laguna-6
Collection Date/Time: 04/02/2017 1339
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	0.56	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1640	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-07

Client Sample ID: Laguna-7
Collection Date/Time: 04/02/2017 1336
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	ND	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1645	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-08

Client Sample ID: Laguna-8
Collection Date/Time: 04/02/2017 1333
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	1.8	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1651	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-09

Client Sample ID: Laguna-9
Collection Date/Time: 04/02/2017 1331
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	2.0	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1656	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-10

Client Sample ID: Laguna-10
Collection Date/Time: 04/02/2017 1328
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	0.87	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1701	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-11

Client Sample ID: Laguna-11
Collection Date/Time: 04/02/2017 1326
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	0.56	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1707	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-12

Client Sample ID: Laguna-12
Collection Date/Time: 04/02/2017 1321
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	2.4	0.50		ug/L	1	04/10/2017 1350	04/10/2017 1712	MH

Client: Arizona Department of Environmental Qual
Project: Lead Analysis
Work Order: 17D0320
Lab Sample ID: 17D0320-13

Client Sample ID: Laguna-13
Collection Date/Time: 04/02/2017 1320
Matrix: Drinking Water
Order Name: Flowing Wells Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	1.7	0.50		ug/L	1	04/17/2017 1305	04/17/2017 1513	MH

Client: Arizona Department of Environmental Quality-Phx
Project: Lead Analysis
Work Order: 17D0320
Date Received: 04/03/2017

QC Summary


Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qual
Batch 1704106 - E200.8 (5.4)										
Blank (1704106-BLK1)				Prepared & Analyzed: 04/10/2017						
Lead	ND	0.50	ug/L							
LCS (1704106-BS1)				Prepared & Analyzed: 04/10/2017						
Lead	49	0.50	ug/L	50.00		98	85-115			
LCS Dup (1704106-BSD1)				Prepared & Analyzed: 04/10/2017						
Lead	49	0.50	ug/L	50.00		97	85-115	0.3	20	
Matrix Spike (1704106-MS1)				Source: 17D0297-01		Prepared & Analyzed: 04/10/2017				
Lead	54	0.50	ug/L	50.00	1.6	104	70-130			
Matrix Spike (1704106-MS2)				Source: 17D0316-01		Prepared & Analyzed: 04/10/2017				
Lead	53	0.50	ug/L	50.00	0.12	106	70-130			
Batch 1704182 - E200.8 (5.4)										
Blank (1704182-BLK1)				Prepared & Analyzed: 04/17/2017						
Lead	ND	0.50	ug/L							
LCS (1704182-BS1)				Prepared & Analyzed: 04/17/2017						
Lead	46	0.50	ug/L	50.00		92	85-115			
LCS Dup (1704182-BSD1)				Prepared & Analyzed: 04/17/2017						
Lead	46	0.50	ug/L	50.00		92	85-115	0.6	20	
Matrix Spike (1704182-MS1)				Source: 17D0320-13		Prepared & Analyzed: 04/17/2017				
Lead	49	0.50	ug/L	50.00	1.7	94	70-130			
Matrix Spike (1704182-MS2)				Source: 17D0462-01		Prepared & Analyzed: 04/17/2017				
Lead	48	0.50	ug/L	50.00	0.17	97	70-130			

Collection Log
for experienced sample collectors


17D0320-01

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Rooms 27-28 - Portable bldg. Built 2000
Type of Fixture (tap, drinking fountain etc.)	Sink TAP - Room 27
Location of Fixture (example, room number)	Room 27 - Sink
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Laguna - 1
Date of Collection	4/2/17
Time of Collection	1:52 pm
Printed Name of Sample Collector	Kyle Maucher
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes:	Temp. 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors


17D0320-02

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Office - 1-6 Classroom
Type of Fixture (tap, drinking fountain etc.)	Outside Fountain Between Restroom
Location of Fixture (example, room number)	Bubbler-Fountain
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Laguna-2
Date of Collection	4/2/17
Time of Collection	1:50 PM
Printed Name of Sample Collector	Kyle Maicher
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes:	Temp 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log 17D0320-03
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Bldg. 7
Type of Fixture (tap, drinking fountain etc.)	Kitchen Sink
Location of Fixture (example, room number)	Room 7
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	109una-3
Date of Collection	4/2/17
Time of Collection	1:48 pm
Printed Name of Sample Collector	Kyle Maucher
Signature Sample Collector	

Built
1977

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:30
Signature	
Notes:	Temp 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log 17D0320-04
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Room 7 - Kitchen TAP
Type of Fixture (tap, drinking fountain etc.)	Kitchen TAP
Location of Fixture (example, room number)	Room 7 - Kitchen Sink
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Laguna-4
Date of Collection	4/2/17
Time of Collection	1:47 pm
Printed Name of Sample Collector	Kyle Maucher
Signature Sample Collector	

Built
1977

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:37
Signature	
Notes:	Temp. 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

17 D 0320-05


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Bldg. 23-26
Type of Fixture (tap, drinking fountain etc.)	Kitchen Sink bubbler Rm 25
Location of Fixture (example, room number)	Rm 25
Sample Identification Number (Write this number on the sample container and on this sheet)	1977-5
Date of Collection	4/2/17
Time of Collection	1:42 pm
Printed Name of Sample Collector	Kyle Muecho
Signature Sample Collector	

Built
1977

Notes Sample collector: *Reaping Log*

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:37
Signature	
Notes: <i>Temp. 22.3</i>	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log 17D0320-06
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Bldg. 25-26
Type of Fixture (tap, drinking fountain etc.)	Kitchen Sink bubbler-Rm 25
Location of Fixture (example, room number)	Rm 25
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	109Vna-6
Date of Collection	4/2/17
Time of Collection	1:39pm
Printed Name of Sample Collector	Kyle Maucher
Signature Sample Collector	

Built
1977

Notes Sample collector: Reading Lab

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes: Temp. 22.3	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


Collection Log 17D0320-07
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	NEW slab on grade bldg. — Built 2013
Type of Fixture (tap, drinking fountain etc.)	outside fountain
Location of Fixture (example, room number)	drinking fountain by computer lab
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Laguna-7
Date of Collection	4/2/17
Time of Collection	1:36 pm
Printed Name of Sample Collector	Lyle Mauchor
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes: Temp - 22.3	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log 17D0320-08
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Bldg. 9, 10, 11, 12
Type of Fixture (tap, drinking fountain etc.)	bubbler fountain - Rm 11
Location of Fixture (example, room number)	Rm 11
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Laguna -8
Date of Collection	4/2/17
Time of Collection	1:33 pm
Printed Name of Sample Collector	Kyle Maicher
Signature Sample Collector	

Built
1955

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes:	Temp 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log 17D0320-09
for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Bldg 9, 10, 11, 12
Type of Fixture (tap, drinking fountain etc.)	Bubbler Fountain
Location of Fixture (example, room number)	Rm 10
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1aguna-9
Date of Collection	4/2/17
Time of Collection	1:31 pm
Printed Name of Sample Collector	Kyle Macher
Signature Sample Collector	

Built
1955

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 1:32
Signature	
Notes:	Temp. 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

17D0320-10


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Classroom 13-20
Type of Fixture (tap, drinking fountain etc.)	Bubbler Fountain Rm 13
Location of Fixture (example, room number)	Rm 13
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Laguna-10
Date of Collection	4/2/17
Time of Collection	1:28 pm
Printed Name of Sample Collector	Kyle Marchee
Signature Sample Collector	

Built
1975

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes: Temp- 22.3	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

17D0320-11


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	Classroom 13-20
Type of Fixture (tap, drinking fountain etc.)	Bubbler Fountain Rm-17
Location of Fixture (example, room number)	Rm-17
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Laguna-11
Date of Collection	4/2/17
Time of Collection	1:26 pm
Printed Name of Sample Collector	Kyle Maucher
Signature Sample Collector	

Built
1976

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes:	Temp 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

17D0320-12


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	MRR-Kitchen
Type of Fixture (tap, drinking fountain etc.)	2 compartment Sink
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	laguna-12
Date of Collection	4/2/17
Time of Collection	1:21 pm
Printed Name of Sample Collector	Kyle Maucher
Signature Sample Collector	

Built
1955

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes:	Temp 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log
for experienced sample collectors

17D0320-13


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Flowing Wells Unified District
School Name	Laguna Elementary
Building (name/number)	MPR - Kitchen
Type of Fixture (tap, drinking fountain etc.)	3 compartment Sink
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	Laguna - 13
Date of Collection	4/2/17
Time of Collection	1:20 pm
Printed Name of Sample Collector	Kyle Maucher
Signature Sample Collector	

Built
1955

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/3/17 13:32
Signature	
Notes:	Temp 22.3

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.