

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Flowing wells high school

Reported:  
06/30/17 12:26

## Analyte

**1 Confirmation- First Draw (7062497-01) Drinking Water (Grab) Sampled: 06/26/17 06:30 Received: 06/27/17 10:10**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 19:05	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**2 Confirmation- Flush (7062497-02) Drinking Water (Grab) Sampled: 06/26/17 06:32 Received: 06/27/17 10:10**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 19:08	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**3 Confirmation- Frist Draw (7062497-03) Drinking Water (Grab) Sampled: 06/27/17 06:58 Received: 06/27/17 10:10**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	26	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 19:11	EPA 200.8	
------	----	-----	------	---	---------	----------------	----------------	-----------	--

**5 Screening (7062497-04) Drinking Water (Grab) Sampled: 06/26/17 06:44 Received: 06/27/17 10:10**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	36	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 19:15	EPA 200.8	
------	----	-----	------	---	---------	----------------	----------------	-----------	--

**6 Screening (7062497-05) Drinking Water (Grab) Sampled: 06/26/17 06:50 Received: 06/27/17 10:10**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	55	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 19:18	EPA 200.8	
------	----	-----	------	---	---------	----------------	----------------	-----------	--

**7 Screening (7062497-06) Drinking Water (Grab) Sampled: 06/26/17 06:42 Received: 06/27/17 10:10**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	5.1	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 19:21	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**8 Screening (7062497-07) Drinking Water (Grab) Sampled: 06/26/17 06:53 Received: 06/27/17 10:10**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 4

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Flowing wells high school

Reported:  
06/30/17 12:26

8 Screening (7062497-07) Drinking Water (Grab) Sampled: 06/26/17 06:53 Received: 06/27/17 10:10

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

#### Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1833	06/28/17 15:15	06/28/17 19:25	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

#### Sample Condition Upon Receipt:

Temperature: 30.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

#### Case Narrative:

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

#### Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

7062497

Lead In Schools Confirmation Sampling Log					
School District: Flowing Wells Unified District					
School Name: Flowing Wells High School					
Building Name/Number/Year Built: ROTC Classrooms 47,48,49					
Sample Collector Name and Phone Number:					
Sample ID # (must appear on bottle)	Bottle Size	Fixture Type/ Make and model, #	East Fixture location	Collection Time	Collection Date
1 Confirmation - First Draw	250 ml	3 gang Drinking fountain	Sink Fountain	6:30 AM	6.26.17
2 Confirmation - Flush	250 ml	3 gang Drinking fountain	Sink Fountain	6:32 AM	6.26.17
3 Confirmation - First Draw Day Two	1 Liter	3 gang Drinking fountain	Sink Fountain	6:58 AM	6.27.17
4 Screening	250 ml	NOT NEEDED	Drinking fountain	NOT NEEDED	RF
5 Screening	250 ml	SPACE SINK Between 2/3	Bubbler	6:44	6.26.17
6 Screening	250 ml	SUPPLY Rm Bubbler	Bubbler	6:50	6.26.17
7 Screening	250 ml	Rm 3 bubbler	Bubbler	6:42	6.26.17
8 Screening	250 ml	Supply Rm	Ice machine	6:53	6.26.17

These samples were collected for screening purposes only and are not to be used for compliance determinations

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	
RELINQUISHING AGENT SIGNATURE:	
SIGNATORY NAME PRINTED:	

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	6/27/17
TIME LAB RECEIVED:	@ Lab 10:00
LAB SIGNATURE:	RJ
LAB SIGNATORY NAME PRINTED:	RONALD FLORES
NOTES:	preserved @ Lab Temp 30.0°C

RJ  
RONALD FLORES

6/27/17  
1600

COVITER

6/27/17  
1600