

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Marion Donaldson Elementary School

Reported:  
05/18/17 12:49

## Analyte

**1001-1 (7050791-01) Drinking Water (Grab) Sampled: 05/05/17 06:09 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:12	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1001-2 (7050791-02) Drinking Water (Grab) Sampled: 05/05/17 06:12 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:16	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1007-1 (7050791-03) Drinking Water (Grab) Sampled: 05/05/17 06:14 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	8.1	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:20	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**1007-2 (7050791-04) Drinking Water (Grab) Sampled: 05/05/17 06:16 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	20	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:23	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1008-1 (7050791-05) Drinking Water (Grab) Sampled: 05/05/17 06:18 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:27	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1008-2 (7050791-06) Drinking Water (Grab) Sampled: 05/05/17 06:18 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:31	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1009-1 (7050791-07) Drinking Water (Grab) Sampled: 05/05/17 06:20 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 22

**1009-1 (7050791-07) Drinking Water (Grab) Sampled: 05/05/17 06:20 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:42	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1009-2 (7050791-08) Drinking Water (Grab) Sampled: 05/05/17 06:24 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:46	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1010-1 (7050791-09) Drinking Water (Grab) Sampled: 05/05/17 06:26 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:50	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1010-2 (7050791-10) Drinking Water (Grab) Sampled: 05/05/17 06:27 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	7.7	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/16/17 23:54	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**1011-1 (7050791-11) Drinking Water (Grab) Sampled: 05/05/17 06:36 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:05	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1011-2 (7050791-12) Drinking Water (Grab) Sampled: 05/05/17 06:37 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:09	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1012-1 (7050791-13) Drinking Water (Grab) Sampled: 05/05/17 06:35 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:13	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1012-2 (7050791-14) Drinking Water (Grab) Sampled: 05/05/17 06:36 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Marion Donaldson Elementary School

Reported:  
05/18/17 12:49

**1012-2 (7050791-14) Drinking Water (Grab) Sampled: 05/05/17 06:36 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	6.9	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:17	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**1013-1 (7050791-15) Drinking Water (Grab) Sampled: 05/05/17 06:38 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:28	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1013-2 (7050791-16) Drinking Water (Grab) Sampled: 05/05/17 06:39 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:32	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1014 (7050791-17) Drinking Water (Grab) Sampled: 05/05/17 06:45 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:36	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**Sample Condition Upon Receipt:**

Temperature: 24.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

**Notes and Definitions**

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791 - 0

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Admin, Library
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NURSE OFFICE
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-1
Date of Collection	5-5-17
Time of Collection	6:09 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	AP 5/8/17
Date and Time Lab received	5/8/17 0825 0850
Signature	
Notes: @Lab 0925 5/8/17	
24.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

✓  
TW

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791 -02

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Admin, Library
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	N of Library outside
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-2
Date of Collection	5-5-17
Time of Collection	6:12 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791-03

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building A
Type of Fixture (tap, drinking fountain etc.)	SINK + DRINKING
Location of Fixture (example, room number)	Rm. A1
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1007-1
Date of Collection	5-5-17
Time of Collection	6:14 A.M
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791 -04

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building A
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm. A4
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1007-2
Date of Collection	5-5-17
Time of Collection	6:16 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791 -08

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building B
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm. B1
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1008-1
Date of Collection	5-5-17
Time of Collection	6:18 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791-010

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building B
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm. B-4
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1008-2
Date of Collection	5-5-17
Time of Collection	6:18 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791-07

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building C
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm C7
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1009-1
Date of Collection	5-5-17
Time of Collection	6:20 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791-08

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building C
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm. C 4
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1009-2
Date of Collection	5-5-17
Time of Collection	6:24 AM.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

705091-09

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building D
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm. D 1
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1010-1
Date of Collection	5-5-17
Time of Collection	6:26 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791-10

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building D
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm. D4
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1010-2
Date of Collection	5-5-17
Time of Collection	6:27 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791-11

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building E
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm E1
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1011-1
Date of Collection	5-5-17
Time of Collection	6:36 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

705091-12

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building E
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	RM E 4
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1011-2
Date of Collection	5-5-17
Time of Collection	6:37 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791 -13

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building F
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm. F-1
Sample Identification Number (Write this number on the sample container and on this sheet)	1012-1
Date of Collection	5-5-17
Time of Collection	6:35 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

705091 -1

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	Building F
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm. F-4
Sample Identification Number (Write this number on the sample container and on this sheet)	1012-2
Date of Collection	5-5-17
Time of Collection	6:36 AM
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

705091 -15

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	M.P.R. ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	S.W. ENTRANCE
Sample Identification Number (Write this number on the sample container and on this sheet)	1013-1
Date of Collection	5-5-17
Time of Collection	6:38 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050791 -14

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	M.P.R. ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	S.E. ENTRANCE
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1013-2
Date of Collection	5-5-17
Time of Collection	6:39 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050911-17

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Marion Donaldson Elementary School
Building (name/number)	M.P.R. Addition #1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	MUSIC RM.
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1014
Date of Collection	5-5-17
Time of Collection	6:45 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

7050791

	District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
1	Amphitheater Unified District	Marion Donaldson Elementary School	1001	Administration & Library	Administration/Library	1971	
2	Amphitheater Unified District	Marion Donaldson Elementary School	1002	P1 (PAL)	PAL	1978	2
3	Amphitheater Unified District	Marion Donaldson Elementary School	1003	P2 (Kgn)	Classrooms	1978	2
4	Amphitheater Unified District	Marion Donaldson Elementary School	1007	Building A	Classrooms	1971	2
5	Amphitheater Unified District	Marion Donaldson Elementary School	1008	Building B	Classrooms	1971	2
6	Amphitheater Unified District	Marion Donaldson Elementary School	1009	Building C	Classrooms	1971	2
7	Amphitheater Unified District	Marion Donaldson Elementary School	1010	Building D	Classrooms	1971	2
8	Amphitheater Unified District	Marion Donaldson Elementary School	1011	Building E	Classrooms	1972	2
9	Amphitheater Unified District	Marion Donaldson Elementary School	1012	Building F	Classrooms	1973	2
10	Amphitheater Unified District	Marion Donaldson Elementary School	1013	MPR - Original	MPR	1974	2
11	Amphitheater Unified District	Marion Donaldson Elementary School	1014	MPR - Addition #1	Teachers Lounge	1989	1
12	Amphitheater Unified District	Marion Donaldson Elementary School	1015	CEP Portable	CEP	1978	2
13	Address:					Number of Bottles Per Kit:	17
14							23

7050701

