

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: E C Nash School

Reported:  
05/18/17 12:53

## Analyte

**1001 (7050794-01) Drinking Water (Grab) Sampled: 05/03/17 06:15 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:39	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1001-2 (7050794-02) Drinking Water (Grab) Sampled: 05/03/17 06:17 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:43	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1002-1 (7050794-03) Drinking Water (Grab) Sampled: 05/03/17 06:30 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1496	05/16/17 14:29	05/17/17 00:47	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1002-2 (7050794-04) Drinking Water (Grab) Sampled: 05/03/17 06:35 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:18	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1003 (7050794-05) Drinking Water (Grab) Sampled: 05/03/17 06:20 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:21	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1011-1 (7050794-06) Drinking Water (Grab) Sampled: 05/03/17 07:02 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:25	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1011-2 (7050794-07) Drinking Water (Grab) Sampled: 05/03/17 06:54 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 17

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: E C Nash School

Reported:  
05/18/17 12:53

**1011-2 (7050794-07) Drinking Water (Grab) Sampled: 05/03/17 06:54 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:29	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1012 (7050794-08) Drinking Water (Grab) Sampled: 05/03/17 07:07 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:33	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1016-2 (7050794-09) Drinking Water (Grab) Sampled: 05/03/17 06:48 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:37	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1016-1 (7050794-10) Drinking Water (Grab) Sampled: 05/03/17 06:45 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:40	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1018 (7050794-11) Drinking Water (Grab) Sampled: 05/03/17 06:53 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:44	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1020 (7050794-12) Drinking Water (Grab) Sampled: 05/03/17 06:50 Received: 05/08/17 09:25**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:48	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

**Sample Condition Upon Receipt:**

Temperature: 24.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

---

**Notes and Definitions**

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Admin. 1-6 ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Admin Lobby
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001
Date of Collection	5-3-17
Time of Collection	6:15 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/8/17 0850
Signature	
Notes: @Lab 5/8/17 0925 24.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

705074-02

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Admin, 1-6 ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	LOUNGE
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-2
Date of Collection	5-3-17
Time of Collection	6:17 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

**For relinquishing samples upon delivery to labs only**

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050794 -03

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	ADMIN, 1-6 Add# 1
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 1
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002-1
Date of Collection	5-3-17
Time of Collection	6:30 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050794-04

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Admin, 1-6 Add # 1
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 6
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002-2
Date of Collection	5-3-17
Time of Collection	6:35 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050794-05

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Admin, MPR. 1-6 Add #2
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	MPR
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1003
Date of Collection	5-3-17
Time of Collection	6:20 A.M
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050794-06

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Library, 8-18 Rooms ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 9
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1011-1
Date of Collection	5-3-17
Time of Collection	7:02 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

705079407

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Library, 8-18
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 18
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1011-2
Date of Collection	5-3-17
Time of Collection	6:54 AM.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050794-08

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Library, 8-18 Rooms Add #1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Library Lounge
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1012
Date of Collection	5-3-17
Time of Collection	7:07 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Rooms A100 - A202 1 <sup>st</sup> Floor
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 100
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1016-2
Date of Collection	5-3-17
Time of Collection	6:48 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

705074-10

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	Rooms A100-A202 1 <sup>st</sup> Floor
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 102
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	106-1
Date of Collection	5-3-17
Time of Collection	6:45AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050794-11

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	2 Additional Classrooms
Type of Fixture (tap, drinking fountain etc.)	Drinking + Sink
Location of Fixture (example, room number)	Rm 7
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1018 -
Date of Collection	5-3-17
Time of Collection	6:53 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7050794 12

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	E C Nash School
Building (name/number)	1020
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	FRONT OF BUILDING E
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1020
Date of Collection	5-3-17
Time of Collection	6:50 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

7050794

	District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
12	Amphitheater Unified District	E C Nash School	1001	Administration, 1-6 - Original	Classrooms, Administration	1960	2
3	Amphitheater Unified District	E C Nash School	1002	Administration, 1-6 - Addition #1	Classroom, Administration	1962	2
4	Amphitheater Unified District	E C Nash School	1003	Administration, MPR, 1-6 - Addition #2	Classroom, MPR, Administration	1989	1
5	Amphitheater Unified District	E C Nash School	1011	Library, 8-18 Rooms - Original	Library, Classrooms, Cafeteria	1960	2
6	Amphitheater Unified District	E C Nash School	1012	Library, 8-18 Rooms - Addition #1	Library, Computer Lab	1983	2
7	Amphitheater Unified District	E C Nash School	1016	Rooms A100 - A202 1st Floor	Classrooms	1978	2
8	Amphitheater Unified District	E C Nash School	1017	Rms A100 - A202 2nd floor	Classrooms	1999	1
9	Amphitheater Unified District	E C Nash School	1018	2 Additional Classrooms	Classrooms	2004	1
10	Amphitheater Unified District	E C Nash School	1019	Classrooms 31A-31B	Classrooms	2008	1
11	Amphitheater Unified District	E C Nash School	1020	1020	Classrooms	2012	1
12	Address:					Number of Bottles Per Kit:	11. 154 15



