

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Lulu Walker School

Reported:
05/04/17 17:10

Analyte

1001-1 (7042619-01) Drinking Water (Grab) Sampled: 04/25/17 06:50 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 02:22	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7042619-02) Drinking Water (Grab) Sampled: 04/26/17 06:10 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 02:26	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009-1 (7042619-03) Drinking Water (Grab) Sampled: 04/25/17 06:55 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 02:30	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009-2 (7042619-04) Drinking Water (Grab) Sampled: 04/25/17 06:57 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 02:34	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010-1 (7042619-05) Drinking Water (Grab) Sampled: 04/25/17 07:00 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 02:38	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010-2 (7042619-06) Drinking Water (Grab) Sampled: 04/25/17 07:05 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	13	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 02:42	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1011-1 (7042619-07) Drinking Water (Grab) Sampled: 04/26/17 06:18 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 17

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Lulu Walker School

Reported:
05/04/17 17:10

1011-1 (7042619-07) Drinking Water (Grab) Sampled: 04/26/17 06:18 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 02:53	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1011-2 (7042619-08) Drinking Water (Grab) Sampled: 04/26/17 06:20 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 02:57	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1014 (7042619-09) Drinking Water (Grab) Sampled: 04/25/17 07:10 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 03:08	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1016 (7042619-10) Drinking Water (Grab) Sampled: 04/26/17 06:15 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 03:12	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1017 (7042619-11) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 03:16	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1018 (7042619-12) Drinking Water (Grab) Sampled: 04/26/17 06:25 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1830	04/28/17 13:31	04/29/17 03:20	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Sample Condition Upon Receipt:

Temperature: 23.30 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042619-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	Admin ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	OFFICE hall
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-1
Date of Collection	4-25-17
Time of Collection	6:50 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received 4/27/17	1240
Signature [Signature]	
Notes: @lab 1315	23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042619-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	Admin - ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NURSE OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-2
Date of Collection	4-26-17
Time of Collection	6:10-AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	[Signature]
Notes:	@bb 1315 23.30C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

704 2019-03

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	MPR
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	MPR.
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-1
Date of Collection	4-25-17
Time of Collection	6:55 AM
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received 4/27/17	1240
Signature	
Notes: @lab 1315	23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042619-04

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	MPR.
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	MPR
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-2
Date of Collection	4-25-17
Time of Collection	6:57 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	Lab 135 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042019-05

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	1-11 AND LIBRARY
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Room 2
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-1
Date of Collection	4-25-17
Time of Collection	7:00 AM
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 12:40
Signature	
Notes:	@lab BIS 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

709 2019-06

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	1-11 AND LIBRARY
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	LIBRARY OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-2
Date of Collection	4-25-17
Time of Collection	7:05
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	@lab 135 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

704269-07

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	20-25 1 st FLOOR
Type of Fixture (tap, drinking fountain etc.)	DRINKING - SINK
Location of Fixture (example, room number)	Rm 20
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-1
Date of Collection	4-26-17
Time of Collection	6:18 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	@lab 1315 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042619-08

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	20-25 1 st Floor
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 22
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-2
Date of Collection	4-26-17
Time of Collection	6:20 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	@lab1315 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042619-09

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	Admin - Addition #1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Teachers Lounge
Sample Identification Number (Write this number on the sample container and on this sheet)	1014
Date of Collection	4-25-17
Time of Collection	7:10
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	@lab 1315 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042019-10

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	EARLY childhood Facility
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	PAI
Sample Identification Number (Write this number on the sample container and on this sheet)	1016
Date of Collection	4-26-17
Time of Collection	6:15 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	@bb1315 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042619-11

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	4 ADDITIONAL CLASSROOMS
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 7
Sample Identification Number (Write this number on the sample container and on this sheet)	1017
Date of Collection	4-26-17
Time of Collection	6:30 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	<i>[Signature]</i>
Notes: @lab BIS 23.3°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042619-12

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Lulu Walker School
Building (name/number)	1016
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	BACKWAY
Sample Identification Number (Write this number on the sample container and on this sheet)	1018
Date of Collection	4-26-17
Time of Collection	6:25 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	<i>[Signature]</i>
Notes:	@lab 1315 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Amphitheater Unified District	Lulu Walker School	1001	Administration - Original	Administration	1963	2
Amphitheater Unified District	Lulu Walker School	1009	MPR	Gymnasium	1981	2
Amphitheater Unified District	Lulu Walker School	1010	1-11 & Library	Classrooms, Library	1963	2
Amphitheater Unified District	Lulu Walker School	1011	20-25 1st Floor	Classrooms/Labs	1987	2
Amphitheater Unified District	Lulu Walker School	1012	Cafeteria & 26-27 - Original	Cafeteria, Classrooms	1963	2
Amphitheater Unified District	Lulu Walker School	1013	Cafeteria & 26-27 - Addition #1	Computer Classroom	1985	2
Amphitheater Unified District	Lulu Walker School	1014	Administration - Addition #1	Teachers Lounge	1985	1/2
Amphitheater Unified District	Lulu Walker School	1015	20-25 2nd Floor	Classrooms	1987	2
Amphitheater Unified District	Lulu Walker School	1016	Early Childhood Facility	Classrooms	1999	1
Amphitheater Unified District	Lulu Walker School	1017	4 Additional Classrooms	Classrooms	2004	1
Amphitheater Unified District	Lulu Walker School	1018	1016	Classrooms	2011	1

1750 W. Boller Coaster Rd.
 696-6510

