

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Coronado K-8 School

Reported:
05/25/17 16:43

Analyte

1001 (7051668-01) Drinking Water (Grab) Sampled: 05/15/17 06:10 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:10	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1004-1 (7051668-02) Drinking Water (Grab) Sampled: 05/15/17 06:18 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:14	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1004-2 (7051668-03) Drinking Water (Grab) Sampled: 05/15/17 06:19 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:18	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1005-1 (7051668-04) Drinking Water (Grab) Sampled: 05/15/17 06:21 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:22	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1005-2 (7051668-05) Drinking Water (Grab) Sampled: 05/15/17 06:23 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:26	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1006-1 (7051668-06) Drinking Water (Grab) Sampled: 05/15/17 06:24 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:29	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1006-2 (7051668-07) Drinking Water (Grab) Sampled: 05/15/17 06:26 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 27

1006-2 (7051668-07) Drinking Water (Grab) Sampled: 05/15/17 06:26 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:33	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1007-1 (7051668-08) Drinking Water (Grab) Sampled: 05/15/17 06:40 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:37	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1007-2 (7051668-09) Drinking Water (Grab) Sampled: 05/15/17 06:43 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:41	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1008-1 (7051668-10) Drinking Water (Grab) Sampled: 05/15/17 06:34 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/22/17 23:45	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1008-2 (7051668-11) Drinking Water (Grab) Sampled: 05/15/17 06:39 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:04	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009-1 (7051668-12) Drinking Water (Grab) Sampled: 05/15/17 06:32 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:08	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009-2 (7051668-13) Drinking Water (Grab) Sampled: 05/15/17 06:33 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:11	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010 (7051668-14) Drinking Water (Grab) Sampled: 05/15/17 06:50 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Coronado K-8 School

Reported:
05/25/17 16:43

1010 (7051668-14) Drinking Water (Grab) Sampled: 05/15/17 06:50 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:15	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1011 (7051668-15) Drinking Water (Grab) Sampled: 05/15/17 06:47 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:19	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1012 (7051668-16) Drinking Water (Grab) Sampled: 05/16/17 06:08 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:23	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1013 (7051668-17) Drinking Water (Grab) Sampled: 05/15/17 06:30 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:27	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1014 (7051668-18) Drinking Water (Grab) Sampled: 05/16/17 06:19 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:30	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1015 (7051668-19) Drinking Water (Grab) Sampled: 05/16/17 06:16 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:42	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1016 (7051668-20) Drinking Water (Grab) Sampled: 05/15/17 06:13 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1687	05/22/17 10:06	05/23/17 00:46	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1020 (7051668-21) Drinking Water (Grab) Sampled: 05/16/17 06:10 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Coronado K-8 School

Reported:
05/25/17 16:43

1020 (7051668-21) Drinking Water (Grab) Sampled: 05/16/17 06:10 Received: 05/16/17 13:33

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1688	05/22/17 10:10	05/23/17 01:09	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

Sample Condition Upon Receipt:

Temperature: 23.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668 -01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	Admin.
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	HALL - EAST
Sample Identification Number (Write this number on the sample container and on this sheet)	1001
Date of Collection	5-15-17
Time of Collection	6:10 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/16/17 1300
Signature	
Notes: @Lab 5/16/17 1333	
23.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	1-4
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 1
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-1
Date of Collection	5-15-17
Time of Collection	6:18 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051008 -03

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	1-4
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 4
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-2
Date of Collection	5-15-17
Time of Collection	6:19 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	5-8
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 5
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1
Date of Collection	5-15-17
Time of Collection	6:21 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668 -05

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	5-8
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 7
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-2
Date of Collection	5-15-17
Time of Collection	6:23 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramir

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

705/6668 -06

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	9-12
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm. 9
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-1
Date of Collection	5-15-17
Time of Collection	6:24 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051608 -07

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	9-12
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 11
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1006-2
Date of Collection	5-15-17
Time of Collection	6:26 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668-08

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	13-16
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 16
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-1
Date of Collection	6:40 A.M 5-15-17
Time of Collection	6:40 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668 -8

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	13-16
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	RM 13
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-2
Date of Collection	5-15-17
Time of Collection	6:43 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	17-20
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 20
Sample Identification Number (Write this number on the sample container and on this sheet)	1008-1
Date of Collection	5-15-17
Time of Collection	6:34 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

2051668

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	17-20
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 17
Sample Identification Number (Write this number on the sample container and on this sheet)	1008-2
Date of Collection	5-15-17
Time of Collection	6:39 A.M
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668 -12

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	21-24
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 21
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-1
Date of Collection	5-15-17
Time of Collection	6:32 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

70516008 -1

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	21-24
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 24
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-2
Date of Collection	5-15-17
Time of Collection	6:33 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7/5/16/08 -19

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	101-116 First Floor
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Foyer S
Sample Identification Number (Write this number on the sample container and on this sheet)	1010
Date of Collection	5-15-17
Time of Collection	6:50 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

70516608

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	Library
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	LIBRARY ENTRANCE
Sample Identification Number (Write this number on the sample container and on this sheet)	1011
Date of Collection	5-15-17
Time of Collection	6:47 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051448 -16

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	301-304
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Rm. 303
Sample Identification Number (Write this number on the sample container and on this sheet)	1012
Date of Collection	5-16-17
Time of Collection	6:08 A.M
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

4051668 -17

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	SMALL MPR.
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	MPR - NE
Sample Identification Number (Write this number on the sample container and on this sheet)	1013
Date of Collection	5-15-17
Time of Collection	6:30 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668 -18

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	LARGE MPR-Locker Rm - Add #1
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	HALLWAY
Sample Identification Number (Write this number on the sample container and on this sheet)	1014
Date of Collection	5-16-17
Time of Collection	6:19 A.M
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668 -19

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	LARGE MPR-Lake Rm. Act Rm. Add 2
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Gym - SW
Sample Identification Number (Write this number on the sample container and on this sheet)	1015
Date of Collection	5-16-17
Time of Collection	6:16 AM
Printed Name of Sample Collector	KCN Ramirez
Signature Sample Collector	KCN Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668 - 20

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	Admin. Bldg # 1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NURSE OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	1016
Date of Collection	5-15-17
Time of Collection	6:13 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7051668 - 21

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Coronado K-8 School
Building (name/number)	201-214 2ND FLOOR
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	FOYER - SW
Sample Identification Number (Write this number on the sample container and on this sheet)	1020
Date of Collection	5-16-17
Time of Collection	6:10 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7051668

	District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
1	Amphitheater Unified District	Coronado K-8 School	1001	Administration - Original	Administration	1976	1/2
2	Amphitheater Unified District	Coronado K-8 School	1004	1-4	Classrooms/Labs	1976	2
3	Amphitheater Unified District	Coronado K-8 School	1005	5-8	Classrooms/Labs	1978	2
4	Amphitheater Unified District	Coronado K-8 School	1006	9-12	Classrooms/Labs	1978	2
5	Amphitheater Unified District	Coronado K-8 School	1007	13-16	Classrooms/Labs	1972	2
6	Amphitheater Unified District	Coronado K-8 School	1008	17-20	Classrooms/Labs	1976	2
7	Amphitheater Unified District	Coronado K-8 School	1009	21-24	Classrooms/Labs	1976	2
8	Amphitheater Unified District	Coronado K-8 School	1010	101-116 - First Floor	Classrooms/Labs	1988	1
9	Amphitheater Unified District	Coronado K-8 School	1011	Library	Library	1994	1
10	Amphitheater Unified District	Coronado K-8 School	1012	301-304	Classrooms/Labs	1988	1
11	Amphitheater Unified District	Coronado K-8 School	1013	Small MPR	Gymnasium, Cafeteria, MPR	1976	1/2
12	Amphitheater Unified District	Coronado K-8 School	1014	Large MPR, Locker Room Addition #1	Gymnasium, Cafeteria, Locker Room	1988	1
13	Amphitheater Unified District	Coronado K-8 School	1015	Large MPR, Locker Room, Activity Rm - Addition #2	Activity Room	1994	1
14	Amphitheater Unified District	Coronado K-8 School	1016	Administration - Addition #1	Administration	1994	1
15	Amphitheater Unified District	Coronado K-8 School	1017	Grounds Shed	District Grounds Equipment	1988	1

**CORONADO K-8
3401 W WILDS ROAD
TUCSON, AZ 85739**

