

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: La Cima Middle School

Reported:
05/04/17 17:04

Analyte

1001 (7042611-01) Drinking Water (Grab) Sampled: 04/25/17 06:15 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1829	04/28/17 13:28	04/28/17 23:54	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1006 (7042611-02) Drinking Water (Grab) Sampled: 04/25/17 06:20 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1829	04/28/17 13:28	04/29/17 00:05	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1007 (7042611-03) Drinking Water (Grab) Sampled: 04/25/17 06:25 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1829	04/28/17 13:28	04/29/17 00:09	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009 (7042611-04) Drinking Water (Grab) Sampled: 04/25/17 06:30 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1829	04/28/17 13:28	04/29/17 00:13	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010 (7042611-05) Drinking Water (Grab) Sampled: 04/25/17 06:35 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1829	04/28/17 13:28	04/29/17 00:17	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1011 (7042611-06) Drinking Water (Grab) Sampled: 04/25/17 06:37 Received: 04/27/17 13:15

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1829	04/28/17 13:28	04/29/17 00:21	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 10

Sample Condition Upon Receipt:

Temperature: 23.30 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042611-01

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	La Cima Middle School
Building (name/number)	CLASSROOM Floor #1
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	1 st FLOOR HALLWAY
Sample Identification Number (Write this number on the sample container and on this sheet)	1001
Date of Collection	4-25-17
Time of Collection	6:15 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	@lab 1315 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042611-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	La Cima Middle School
Building (name/number)	MPR, Locker Rm, Kitchen - Ground Floor
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (Write this number on the sample container and on this sheet)	1006
Date of Collection	4-25-17
Time of Collection	6:20 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 12:40
Signature	
Notes:	@1315 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

704 2611-03

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	La Cima Middle School
Building (name/number)	Grounds shed
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	OUTSIDE
Sample Identification Number (Write this number on the sample container and on this sheet)	1007
Date of Collection	4-25-17
Time of Collection	6:25 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	@lab 13/5 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042611-04

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	La Cima Middle School
Building (name/number)	MPR Basement
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Basement
Sample Identification Number (Write this number on the sample container and on this sheet)	1009
Date of Collection	4-25-17
Time of Collection	6:30 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes:	@lab 1315 23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042611-05

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	La Cima Middle School
Building (name/number)	Admin, CLASSROOMS, LIBRARY
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	LIBRARY HALL
Sample Identification Number (Write this number on the sample container and on this sheet)	1010
Date of Collection	4-25-17
Time of Collection	6:35 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received 4/27/17	1240
Signature	
Notes: @lab 1315	23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	La Cima Middle School
Building (name/number)	NEW Building
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	OFFICE HALL
Sample Identification Number (Write this number on the sample container and on this sheet)	1011
Date of Collection	4-25-17
Time of Collection	6:37 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/27/17 1240
Signature	
Notes: @Lab 1315	23.3°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7042611

	District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
1	Amphitheater Unified District	La Cima Middle School	1001	Classrooms - Floor #1	Classrooms, Labs	1991	1
2	Amphitheater Unified District	La Cima Middle School	1006	MPR, Locker Rooms & Kitchen - Ground Floor	MPR, Locker Rooms, Kitchen	1991	1
3	Amphitheater Unified District	La Cima Middle School	1007	Grounds Shed	District Grounds Equipment	1991	1
	Amphitheater Unified District	La Cima Middle School	1008	Classrooms - Floor #2	Classrooms, Labs	1991	1
4	Amphitheater Unified District	La Cima Middle School	1009	MPR - Basement	MPR	1991	1
5	Amphitheater Unified District	La Cima Middle School	1010	Admin, Classrooms, Library	Admin, Classrooms, Library	2010	1
6	Amphitheater Unified District	La Cima Middle School	1011	NEW BUILDING	GENERAL PURPOSE	2011	1
Address:						Number of Bottles Per	6

