

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Amphitheater Middle School

Reported:
05/16/17 15:17

Analyte

1001-1 (7050401-01) Drinking Water (Grab) Sampled: 05/01/17 06:55 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 22:31	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7050401-02) Drinking Water (Grab) Sampled: 05/02/17 05:47 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 22:50	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009-1 (7050401-03) Drinking Water (Grab) Sampled: 05/02/17 06:21 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 22:54	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009-2 (7050401-04) Drinking Water (Grab) Sampled: 05/02/17 06:20 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 22:58	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010-1 (7050401-05) Drinking Water (Grab) Sampled: 05/02/17 06:17 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 23:02	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010-2 (7050401-06) Drinking Water (Grab) Sampled: 05/02/17 06:14 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 23:05	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1011 (7050401-07) Drinking Water (Grab) Sampled: 05/02/17 06:05 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 30

1011 (7050401-07) Drinking Water (Grab) Sampled: 05/02/17 06:05 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	8.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 23:09	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1012 (7050401-08) Drinking Water (Grab) Sampled: 05/02/17 06:27 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 23:13	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1013-1 (7050401-09) Drinking Water (Grab) Sampled: 05/02/17 06:35 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 23:17	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1013-2 (7050401-10) Drinking Water (Grab) Sampled: 05/02/17 07:10 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 23:21	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1014-1 (7050401-11) Drinking Water (Grab) Sampled: 05/01/17 07:05 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1412	05/12/17 16:15	05/12/17 23:32	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1014-2 (7050401-12) Drinking Water (Grab) Sampled: 05/01/17 07:10 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/12/17 23:55	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1016-1 (7050401-13) Drinking Water (Grab) Sampled: 05/01/17 07:20 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/12/17 23:59	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1016-2 (7050401-14) Drinking Water (Grab) Sampled: 05/01/17 07:25 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

1016-2 (7050401-14) Drinking Water (Grab) Sampled: 05/01/17 07:25 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	6.3	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:03	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

1018 (7050401-15) Drinking Water (Grab) Sampled: 05/01/17 07:35 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:06	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1019-1 (7050401-16) Drinking Water (Grab) Sampled: 05/02/17 05:55 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:18	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1019-2 (7050401-17) Drinking Water (Grab) Sampled: 05/02/17 05:56 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:22	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1020-1 (7050401-18) Drinking Water (Grab) Sampled: 05/02/17 05:58 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:25	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1020-2 (7050401-19) Drinking Water (Grab) Sampled: 05/02/17 06:02 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:29	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1023 (7050401-20) Drinking Water (Grab) Sampled: 05/02/17 05:57 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:33	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1021-1 (7050401-21) Drinking Water (Grab) Sampled: 05/02/17 06:55 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Amphitheater Middle School

Reported:
05/16/17 15:17

1021-1 (7050401-21) Drinking Water (Grab) Sampled: 05/02/17 06:55 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:37	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1021-2 (7050401-22) Drinking Water (Grab) Sampled: 05/02/17 07:00 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:48	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1025 (7050401-23) Drinking Water (Grab) Sampled: 05/02/17 05:50 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 00:52	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1026 (7050401-24) Drinking Water (Grab) Sampled: 05/02/17 07:05 Received: 05/03/17 09:40

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1413	05/12/17 16:30	05/13/17 01:03	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 24.10 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	Admin. ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	NURSE OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-1
Date of Collection	5-1-17
Time of Collection	6:55 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes: @lab 0940 24.1°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

✓ TUC

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	Admin - ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Lounge
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-2
Date of Collection	5-2-17
Time of Collection	5:47 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	[Signature]
Notes: @lab 0940 24.1°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-03

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	301 - 304
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 302
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-1
Date of Collection	5-2-17
Time of Collection	6:21 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	[Signature]
Notes: @lab 0940 24.1°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-04

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	301-304
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 304
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-2
Date of Collection	5-2-17
Time of Collection	6:20 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	<i>[Signature]</i>
Notes: @lab 0940 24.1°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-05

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	305 - 308
Type of Fixture (tap, drinking fountain etc.)	DRINKING & SINK
Location of Fixture (example, room number)	Rm 305
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-1
Date of Collection	5-2-17
Time of Collection	6:17 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	[Signature]
Notes: Lab 0940 24.1°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-06

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	305-308
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	Rm 308
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-2
Date of Collection	5-2-17
Time of Collection	6:14 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	[Signature]
Notes:	@lab 0940 24-1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-07

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	309-310
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Rm. 309
Sample Identification Number (Write this number on the sample container and on this sheet)	1011
Date of Collection	5-2-17
Time of Collection	6:05 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0800
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7650401-08

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	400
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Lounge
Sample Identification Number (Write this number on the sample container and on this sheet)	1012
Date of Collection	5-2-17
Time of Collection	6:27 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-09

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	500 - ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Counge
Sample Identification Number (Write this number on the sample container and on this sheet)	1013-1
Date of Collection	5-2-17
Time of Collection	6:35 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-10

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	500 - ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	HALLWAY
Sample Identification Number (Write this number on the sample container and on this sheet)	1013-2
Date of Collection	5-2-17
Time of Collection	7:00 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	<i>[Signature]</i>
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-11

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	600 - 700
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Teacher Lounge
Sample Identification Number (Write this number on the sample container and on this sheet)	1014-1
Date of Collection	5-1-17
Time of Collection	7:05 AM.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	elab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-12

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	600 + 700
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Teacher Lounge
Sample Identification Number (Write this number on the sample container and on this sheet)	1014-2
Date of Collection	5-1-17
Time of Collection	7:10 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	[Signature]
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-13

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	SMALL Gym & Locker Rms-Add #1
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Boys Locker
Sample Identification Number (Write this number on the sample container and on this sheet)	1016-1
Date of Collection	5-1-17
Time of Collection	7:20 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-14

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	Small Gym & Locker Rms - Add #1
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Small Gym (Act)
Sample Identification Number (Write this number on the sample container and on this sheet)	1016-2
Date of Collection	5-1-17
Time of Collection	7:25 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-15

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	Grounds Shed
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Grounds Shed
Sample Identification Number (Write this number on the sample container and on this sheet)	1018
Date of Collection	5-1-17
Time of Collection	7:35 AM
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-16

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	LIBRARY - ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	LIBRARY OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	1019-1
Date of Collection	5-2-17
Time of Collection	5:55 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	<i>[Signature]</i>
Notes: @lab 0940 24.1°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7650401-17

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	LIBRARY - ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	LIBRARY OFFICE
Sample Identification Number (Write this number on the sample container and on this sheet)	1019-2
Date of Collection	5-2-17
Time of Collection	5:56 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-18

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	M PR
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	CAFETERIA
Sample Identification Number (Write this number on the sample container and on this sheet)	1020-1
Date of Collection	5-2-17
Time of Collection	5:58 AM.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	[Signature]
Notes: @lab 0940 24.1°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-19

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	M.P.R.
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Kitchen Break Rm.
Sample Identification Number (Write this number on the sample container and on this sheet)	1020-2
Date of Collection	5-2-17
Time of Collection	6:02 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-20


Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	LIBRARY Add - #1
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	LIBRARY
Sample Identification Number (Write this number on the sample container and on this sheet)	1023
Date of Collection	5-2-17
Time of Collection	5:57 AM
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.10C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-21

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	800
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Rm. 804
Sample Identification Number (Write this number on the sample container and on this sheet)	1021-1
Date of Collection	5-2-17
Time of Collection	6:55 am
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes: @lab 0940 24.1°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-22

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	800
Type of Fixture (tap, drinking fountain etc.)	DRINKING + SINK
Location of Fixture (example, room number)	RM - 810
Sample Identification Number (Write this number on the sample container and on this sheet)	1021-2
Date of Collection	5-2-17
Time of Collection	7:00 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050401-23

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	Admin - Add - #1
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	FRONT Lobby
Sample Identification Number (Write this number on the sample container and on this sheet)	1025
Date of Collection	5-2-17
Time of Collection	5:50 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7050401-24

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater Middle School
Building (name/number)	1026
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Rm. 904
Sample Identification Number (Write this number on the sample container and on this sheet)	1026
Date of Collection	5-2-17
Time of Collection	7:05 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/3/17 0900
Signature	<i>[Signature]</i>
Notes:	@lab 0940 24.1°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7050461

	District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
1	Amphitheater Unified District	Amphitheater Middle School	1001 •	Administration - Original	Administration	1972	2
2	Amphitheater Unified District	Amphitheater Middle School	1009 •	301-304	Classrooms/Labs	1978	2
3	Amphitheater Unified District	Amphitheater Middle School	1010 •	305-308	Classrooms/Labs	1978	2
4	Amphitheater Unified District	Amphitheater Middle School	1011 •	309-310	Classrooms/Labs	1978	2
5	Amphitheater Unified District	Amphitheater Middle School	1012 •	400	Classrooms/Labs	1972	1/2
6	Amphitheater Unified District	Amphitheater Middle School	1013 •	500 - Original	Classrooms/Labs	1972	2
7	Amphitheater Unified District	Amphitheater Middle School	1014 •	600 & 700	Classrooms/Labs	1972	2
8	Amphitheater Unified District	Amphitheater Middle School	1015 •	Auditorium - Original	Auditorium, Gymnasium	1939	0/2
9	Amphitheater Unified District	Amphitheater Middle School	1016 •	Small Gym & Locker Rooms - Addition #1	Gymnasium, Lockers Rooms	1976	2
10	Amphitheater Unified District	Amphitheater Middle School	1018 •	Grounds Shed	Grounds Shed	1948	1/2
11	Amphitheater Unified District	Amphitheater Middle School	1019 •	Library - Original	Library	1979	2
12	Amphitheater Unified District	Amphitheater Middle School	1020 •	MPR	MPR	1973	2
13	Amphitheater Unified District	Amphitheater Middle School	1021 •	800	Classrooms/Labs	1972	2
14	Amphitheater Unified District	Amphitheater Middle School	1023 •	Library - Addition #1	Library	1993	1
15	Amphitheater Unified District	Amphitheater Middle School	1024 •	500 - Addition #1	Storage	1992	0/1
16	Amphitheater Unified District	Amphitheater Middle School	1025 •	Administration - Addition #1	Administration	1991	1

(OVER)

