

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Richard B Wilson Jr School

Reported:  
05/24/17 16:09

## Analyte

**1001 (7051281-01) Drinking Water (Grab) Sampled: 05/10/17 06:30 Received: 05/11/17 13:15**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1630	05/19/17 10:15	05/19/17 17:42	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1002 (7051281-02) Drinking Water (Grab) Sampled: 05/10/17 06:37 Received: 05/11/17 13:15**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1630	05/19/17 10:15	05/19/17 17:54	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1005 (7051281-03) Drinking Water (Grab) Sampled: 05/10/17 06:34 Received: 05/11/17 13:15**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1630	05/19/17 10:15	05/19/17 17:57	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

## Sample Condition Upon Receipt:

Temperature: 24.00 °C  
All samples were received in acceptable condition unless noted otherwise in the case narrative.

## Case Narrative:

**Holding Times:** All holding times were met unless otherwise qualified.  
**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.  
**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.  
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.  
**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

## Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7051281-01

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Richard B Wilson Jr School
Building (name/number)	MAIN Building 1st Floor
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	N. side of Foyer
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001
Date of Collection	5-10-17
Time of Collection	6:30 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/11/17 1255
Signature	
Notes:	@lab 135 24°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7051281-02

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Richard B Wilson Jr School
Building (name/number)	MPR South
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	E. side of MPR.
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002
Date of Collection	5-10-17
Time of Collection	6:37 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7051281-03

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Richard B Wilson Jr School
Building (name/number)	MPR NORTH
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	MPR N. of STAGE
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1005
Date of Collection	5-10-17
Time of Collection	6:34 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

7051281

	District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
1	Amphitheater Unified District	Richard B Wilson Jr School	1001	Main Building - First Floor	Administration, Library, Classrooms	1996	1
2	Amphitheater Unified District	Richard B Wilson Jr School	1002	MPR (South)	MPR	1996	1
	Amphitheater Unified District	Richard B Wilson Jr School	1003	Main Building - Second Floor	Administration, Library, Classrooms	1996	1
	Amphitheater Unified District	Richard B Wilson Jr School	1004	Grounds Building	District Grounds Equipment	1997	1
3	Amphitheater Unified District	Richard B Wilson Jr School	1005	MPR (North)	Multipurpose room	2000	1
Address:						Bottles Per Kit:	43 5

