

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Amphitheater High School

Reported:
05/23/17 15:22

Analyte

1001 (7050797-01) Drinking Water (Grab) Sampled: 05/04/17 06:34 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 01:59	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1002 (7050797-02) Drinking Water (Grab) Sampled: 05/04/17 06:00 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1588	05/18/17 12:35	05/18/17 14:33	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1014 (7050797-03) Drinking Water (Grab) Sampled: 05/04/17 05:45 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:15	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1015 (7050797-04) Drinking Water (Grab) Sampled: 05/04/17 06:15 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:18	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1017-1 (7050797-05) Drinking Water (Grab) Sampled: 05/04/17 06:52 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:22	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1017-2 (7050797-06) Drinking Water (Grab) Sampled: 05/04/17 06:50 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:26	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1018 (7050797-07) Drinking Water (Grab) Sampled: 05/04/17 06:55 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 27

1018 (7050797-07) Drinking Water (Grab) Sampled: 05/04/17 06:55 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:30	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1019-1 (7050797-08) Drinking Water (Grab) Sampled: 05/04/17 05:46 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:34	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1019-2 (7050797-09) Drinking Water (Grab) Sampled: 05/04/17 05:49 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:45	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1020-1 (7050797-10) Drinking Water (Grab) Sampled: 05/04/17 06:09 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:49	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1020-2 (7050797-11) Drinking Water (Grab) Sampled: 05/04/17 06:10 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1497	05/16/17 14:33	05/17/17 02:53	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1024-1 (7050797-12) Drinking Water (Grab) Sampled: 05/04/17 06:40 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:16	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1024-2 (7050797-13) Drinking Water (Grab) Sampled: 05/04/17 06:42 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	9.4	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:19	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

1025 (7050797-14) Drinking Water (Grab) Sampled: 05/04/17 06:45 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Amphitheater High School

Reported:
05/23/17 15:22

1025 (7050797-14) Drinking Water (Grab) Sampled: 05/04/17 06:45 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:31	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1026 (7050797-15) Drinking Water (Grab) Sampled: 05/04/17 06:02 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:35	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1032-1 (7050797-16) Drinking Water (Grab) Sampled: 05/04/17 05:55 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	15	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:38	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1032-2 (7050797-17) Drinking Water (Grab) Sampled: 05/04/17 05:53 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	15	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:42	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1033 (7050797-18) Drinking Water (Grab) Sampled: 05/04/17 06:26 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:46	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1035 (7050797-19) Drinking Water (Grab) Sampled: 05/04/17 06:20 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:50	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1052 (7050797-20) Drinking Water (Grab) Sampled: 05/04/17 07:02 Received: 05/08/17 09:25

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1498	05/16/17 14:39	05/17/17 03:54	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Sample Condition Upon Receipt:

Temperature: 24.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Self contained 900 wing
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	HALLWAY
Sample Identification Number (Write this number on the sample container and on this sheet)	1001
Date of Collection	5-4-17
Time of Collection	6:34 AM.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/8/17 0925
Signature	<i>[Signature]</i>
Notes: Picked up from district office @ 0850. Preserved at lab. 24.7 °C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

*V
TOL*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-02

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Admin.
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Lobby
Sample Identification Number (Write this number on the sample container and on this sheet)	1002
Date of Collection	5-4-17
Time of Collection	6:00 AM
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-03

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	CENTRAL PLANT # 1
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	CENTRAL PLANT
Sample Identification Number (Write this number on the sample container and on this sheet)	1014
Date of Collection	5-4-17
Time of Collection	5:45 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-04

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Old Gym Original
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	South Entrance
Sample Identification Number (Write this number on the sample container and on this sheet)	1015
Date of Collection	5-4-17
Time of Collection	6:15 AM
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Auditorium + Fine Arts Org.
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Lobby
Sample Identification Number (Write this number on the sample container and on this sheet)	1017-1
Date of Collection	5-4-17
Time of Collection	6:52 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-06

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Auditorium Fine Arts ORIGINAL
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	BAND ROOM
Sample Identification Number (Write this number on the sample container and on this sheet)	1017-2
Date of Collection	5-4-17
Time of Collection	6:50 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-07

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Auditorium Fine Arts Add #1
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Lobby
Sample Identification Number (Write this number on the sample container and on this sheet)	1018
Date of Collection	5-4-17
Time of Collection	6:55 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-08

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Home Economics
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	S. HALLWAY
Sample Identification Number (Write this number on the sample container and on this sheet)	1019-1
Date of Collection	5-4-17
Time of Collection	5:46 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-08

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Home Economics
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	HE3
Sample Identification Number (Write this number on the sample container and on this sheet)	1019-2
Date of Collection	5-4-17
Time of Collection	5:49 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-10

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	New Cafe Gym
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	CAFETERIA
Sample Identification Number (Write this number on the sample container and on this sheet)	1020-1
Date of Collection	5-4-17
Time of Collection	6:09 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	NEW CAFE. Gym
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	South Entrance Gym
Sample Identification Number (Write this number on the sample container and on this sheet)	1020-2
Date of Collection	5-4-17
Time of Collection	6:10 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-12

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	700
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Rm 702
Sample Identification Number (Write this number on the sample container and on this sheet)	1024-1
Date of Collection	6:40 A.M 5-4-17
Time of Collection	6:40 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	<i>Ken Ramirez</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-13

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	700
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Rm. 706
Sample Identification Number (Write this number on the sample container and on this sheet)	1024-2
Date of Collection	5-4-17
Time of Collection	6:42 A.M
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

705 0797-14

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	800
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	800 Front Office
Sample Identification Number (Write this number on the sample container and on this sheet)	1025
Date of Collection	5-4-17
Time of Collection	6:45 A.M
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-15

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	BOOKSTORE
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Rm 3
Sample Identification Number (Write this number on the sample container and on this sheet)	1026
Date of Collection	5-4-17
Time of Collection	6:02 A.M.
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-16

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Science Wing 413-4A
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Middle Office
Sample Identification Number (Write this number on the sample container and on this sheet)	1032-1
Date of Collection	5-4-1
Time of Collection	5:55 A.M
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-17

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	Science Wing 415-417
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Rm. 415
Sample Identification Number (Write this number on the sample container and on this sheet)	1032-2
Date of Collection	5-4-17
Time of Collection	5:53 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-18

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	COMMONS AREA
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	COMMONS AREA
Sample Identification Number (Write this number on the sample container and on this sheet)	1033
Date of Collection	5-4-17
Time of Collection	6:26 A.M
Printed Name of Sample Collector	KEN RAMIREZ
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-19

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	New Library
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	South Entrance
Sample Identification Number (Write this number on the sample container and on this sheet)	1035
Date of Collection	5-4-17
Time of Collection	6:20 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050797-20

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Amphitheater Unified District
School Name	Amphitheater High School
Building (name/number)	New Weight Rm.
Type of Fixture (tap, drinking fountain etc.)	DRINKING
Location of Fixture (example, room number)	Weight Rm.
Sample Identification Number (Write this number on the sample container and on this sheet)	1052
Date of Collection	5-4-17
Time of Collection	7:02 A.M.
Printed Name of Sample Collector	Ken Ramirez
Signature Sample Collector	Ken Ramirez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7050797

	District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
1	Amphitheater Unified District	Amphitheater High School	1001 •	Self-Contained Spec Ed (900 Wing N)	Classroom	1971	1/2
2	Amphitheater Unified District	Amphitheater High School	1002 •	Administration	Administration	1976	1/2
3	Amphitheater Unified District	Amphitheater High School	1013 •	Stadium, Weight Room	Gymnasium	1978	2
4	Amphitheater Unified District	Amphitheater High School	1014 •	Central Plant #1	Central Plant	1980	1/2
5	Amphitheater Unified District	Amphitheater High School	1015 •	Old Gym - Original	Gymnasium	1956	1/2
6	Amphitheater Unified District	Amphitheater High School	1016 •	Old Gym - Addition	Gymnasium	1976	2
7	Amphitheater Unified District	Amphitheater High School	1017 •	Auditorium & Fine Arts - Original	Auditorium	1960	2
8	Amphitheater Unified District	Amphitheater High School	1018 •	Auditorium & Fine Arts - Addition #1	Fine Arts	1983	1/2
9	Amphitheater Unified District	Amphitheater High School #	1019 •	Home Economics	Classrooms	1972	2
10	Amphitheater Unified District	Amphitheater High School	1020 •	New Cafeteria, Gym	Cafeteria, Gymnasium	1986	2
11	Amphitheater Unified District	Amphitheater High School	1021 •	501-503 - Original	Vocational	1960	2
12	Amphitheater Unified District	Amphitheater High School	1022 •	504-508	Classrooms, Labs	1960	2
13	Amphitheater Unified District	Amphitheater High School	1024 •	700	Classrooms, Labs	1976	2
14	Amphitheater Unified District	Amphitheater High School	1025 •	800	Student Council	1981	1/2
15	Amphitheater Unified District	Amphitheater High School	1026 •	Bookstore	Bookstore	1976	1/2
	Amphitheater Unified District	Amphitheater High School	1028 •	100-411 & Library - Original	Classrooms, Labs	1953	2

(OVER)

7050797

Amphitheater Unified District	Amphitheater High School	1051	Football Field Light Control	Football Field Light Control	1976	2
20 Amphitheater Unified District	Amphitheater High School	1052 •	New Weight Room	Weight room and restrooms	2014	1
Address:					Number of Bottles Per Kit:	20

