

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: Canyon Del Oro High School

Reported:
06/23/17 15:00

Analyte

1 Confirmation- First Draw (7062047-01) Drinking Water (Grab) Sampled: 06/20/17 05:58 Received: 06/21/17 13:50

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	12	5.0	ug/L	1	B7F1675	06/21/17 13:33	06/22/17 16:17	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1 Confirmation- Flush (7062047-02) Drinking Water (Grab) Sampled: 06/20/17 06:01 Received: 06/21/17 13:50

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1675	06/21/17 13:33	06/22/17 16:21	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1 Confirmation- First Draw Day Two (7062047-03) Drinking Water (Grab) Sampled: 06/21/17 06:05 Received: 06/21/17 13:50

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.5	5.0	ug/L	1	B7F1675	06/21/17 13:33	06/22/17 16:26	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 26.40 °C
All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.
QA/QC Criteria: All analyses met method requirements unless otherwise qualified.
Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.
Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Notes and Definitions

[illegible]

These samples were collected for screening purposes only and are not to be used for compliance determinations

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	
RELINQUISHING AGENT SIGNATURE:	
SIGNATORY NAME PRINTED:	

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	6/21/17
TIME LAB RECEIVED:	1300
LAB SIGNATURE:	<i>R. Flores</i>
LAB SIGNATORY NAME PRINTED:	RONALDO FLORES
NOTES:	Preserved @ Lab Temp 26.4 °C

R. Flores
RONALDO FLORES
COPIER

6/21/17
1600
6/21/17
1600