

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Los Ninos Elementary School

Reported:  
05/22/17 12:06

## Analyte

**1 Confirmation- First Draw (7051684-01) Drinking Water (Grab) Sampled: 05/15/17 05:17 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	220	5.0	ug/L	1	B7E1552	05/17/17 14:30	05/17/17 16:08	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**2 Confirmation - Flush (7051684-02) Drinking Water (Grab) Sampled: 05/15/17 05:19 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	7.8	5.0	ug/L	1	B7E1552	05/17/17 14:30	05/17/17 16:11	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**3 Confirmation - First Draw Day Two (7051684-03) Drinking Water (Grab) Sampled: 05/16/17 05:06 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	180	5.0	ug/L	1	B7E1552	05/17/17 14:30	05/17/17 16:13	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**4 Screening (7051684-04) Drinking Water (Grab) Sampled: 05/15/17 05:47 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	330	5.0	ug/L	1	B7E1552	05/17/17 14:30	05/17/17 16:16	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**5 Screening (7051684-05) Drinking Water (Grab) Sampled: 05/15/17 05:36 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	170	5.0	ug/L	1	B7E1552	05/17/17 14:30	05/17/17 16:18	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**6 Screening (7051684-06) Drinking Water (Grab) Sampled: 05/15/17 05:22 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	110	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 16:38	EPA 200.8	
------	-----	-----	------	---	---------	----------------	----------------	-----------	--

**7 Screening (7051684-07) Drinking Water (Grab) Sampled: 05/15/17 05:53 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Legend Technical Services of Arizona, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

*Anna Teter*

Client Services Representative

Phone Number: (602) 324-6100

Page 1 of 6

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Los Ninos Elementary School

Reported:  
05/22/17 12:06

**7 Screening (7051684-07) Drinking Water (Grab) Sampled: 05/15/17 05:53 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	690	10	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 19:16	EPA 200.8
------	-----	----	------	---	---------	----------------	----------------	-----------

**8 Screening (7051684-08) Drinking Water (Grab) Sampled: 05/15/17 05:52 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	360	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 16:43	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**9 Screening (7051684-09) Drinking Water (Grab) Sampled: 05/15/17 05:44 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	120	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 16:45	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**10 Screening (7051684-10) Drinking Water (Grab) Sampled: 05/15/17 05:41 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	190	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 16:48	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**11 Screening (7051684-11) Drinking Water (Grab) Sampled: 05/15/17 05:38 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	200	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 16:50	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**12 Screening (7051684-12) Drinking Water (Grab) Sampled: 05/15/17 04:49 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	400	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 16:53	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**13 Screening (7051684-13) Drinking Water (Grab) Sampled: 05/15/17 04:48 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	120	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 16:55	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**14 Screening (7051684-14) Drinking Water (Grab) Sampled: 05/15/17 05:51 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Confirmation (RUSH)  
Project Number: Los Ninos Elementary School

Reported:  
05/22/17 12:06

**14 Screening (7051684-14) Drinking Water (Grab) Sampled: 05/15/17 05:51 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	16	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 17:03	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**15 Screening (7051684-15) Drinking Water (Grab) Sampled: 05/15/17 05:43 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	12	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 17:05	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**16 Screening (7051684-16) Drinking Water (Grab) Sampled: 05/15/17 05:52 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	250	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 17:13	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**17 Screening (7051684-17) Drinking Water (Grab) Sampled: 05/15/17 05:55 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	6.1	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 17:15	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**18 Screening (7051684-18) Drinking Water (Grab) Sampled: 05/15/17 05:54 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	260	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 17:18	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**19 Screening (7051684-19) Drinking Water (Grab) Sampled: 05/15/17 05:28 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	670	10	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 19:18	EPA 200.8
------	-----	----	------	---	---------	----------------	----------------	-----------

**20 Screening (7051684-20) Drinking Water (Grab) Sampled: 05/15/17 05:31 Received: 05/16/17 13:45**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1553	05/17/17 14:45	05/17/17 17:23	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

**Sample Condition Upon Receipt:**

Temperature: 24.40 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

---

**Notes and Definitions**

[illegible]


These samples were collected for screening purposes only and are not to be used for compliance determinations

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	
RELINQUISHING AGENT SIGNATURE:	
SIGNATORY NAME PRINTED:	

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	5/16/17 @ Lab 1345
TIME LAB RECEIVED:	1335
LAB SIGNATURE:	
LAB SIGNATORY NAME PRINTED:	Amanda Picazzo
NOTES:	24.4°C Preserved @ Lab