



April 17, 2017

Victor Scherer  
Arizona Department of Environmental Quality-Phx  
1110 W. Washington Street  
Phoenix, AZ 85007

TEL (520) 398-2266  
FAX (602) 207-2383

RE: Lead Analysis

Work Order No.: 17D0341  
Order Name: Sunnyside Unified  
District

Dear Victor Scherer,

Turner Laboratories, Inc. received 5 sample(s) on 04/06/2017 for the analyses presented in the following report.

All results are intended to be considered in their entirety, and Turner Laboratories, Inc. is not responsible for use of less than the complete report. Results apply only to the samples analyzed. Samples will be disposed of 30 days after issue of our report unless special arrangements are made.

The pages that follow may contain sensitive, privileged or confidential information intended solely for the addressee named above. If you receive this message and are not the agent or employee of the addressee, this communication has been sent in error. Please do not disseminate or copy any of the attached and notify the sender immediately by telephone. Please also return the attached sheet(s) to the sender by mail.

Please call if you have any questions.

Respectfully submitted,

Turner Laboratories, Inc.  
ADHS License AZ0066

Max DiSante  
Laboratory Director

**Client:** Arizona Department of Environmental Quality-P**Project:** Lead Analysis**Order:** Sunnyside Unified District**Work Order:** 17D0341**Date Received:** 04/06/2017**Work Order Sample Summary**

---

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Matrix</b>	<b>Collection Date/Time</b>
17D0341-01	1	Drinking Water	04/06/2017 0610
17D0341-02	2	Drinking Water	04/06/2017 0615
17D0341-03	3	Drinking Water	04/06/2017 0619
17D0341-04	4	Drinking Water	04/06/2017 0626
17D0341-05	5	Drinking Water	04/06/2017 0630

**Client:** Arizona Department of Environmental Quality-Phx  
**Project:** Lead Analysis  
**Work Order:** 17D0341  
**Date Received:** 04/06/2017

**Case Narrative**

---

All soil, sludge, and solid matrix determinations are reported on a wet weight basis unless otherwise noted.

ND Not Detected at or above the PQL

PQL Practical Quantitation Limit

DF Dilution Factor

**Client:** Arizona Department of Environmental Qual  
**Project:** Lead Analysis  
**Work Order:** 17D0341  
**Lab Sample ID:** 17D0341-01

**Client Sample ID:** 1  
**Collection Date/Time:** 04/06/2017 0610  
**Matrix:** Drinking Water  
**Order Name:** Sunnyside Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	ND	0.50		ug/L	1	04/10/2017 1600	04/13/2017 1659	MH

**Client:** Arizona Department of Environmental Qual  
**Project:** Lead Analysis  
**Work Order:** 17D0341  
**Lab Sample ID:** 17D0341-02

**Client Sample ID:** 2  
**Collection Date/Time:** 04/06/2017 0615  
**Matrix:** Drinking Water  
**Order Name:** Sunnyside Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	1.6	0.50		ug/L	1	04/10/2017 1600	04/13/2017 1705	MH

**Client:** Arizona Department of Environmental Qual  
**Project:** Lead Analysis  
**Work Order:** 17D0341  
**Lab Sample ID:** 17D0341-03

**Client Sample ID:** 3  
**Collection Date/Time:** 04/06/2017 0619  
**Matrix:** Drinking Water  
**Order Name:** Sunnyside Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	1.4	0.50		ug/L	1	04/10/2017 1600	04/13/2017 1710	MH

**Client:** Arizona Department of Environmental Qual  
**Project:** Lead Analysis  
**Work Order:** 17D0341  
**Lab Sample ID:** 17D0341-04

**Client Sample ID:** 4  
**Collection Date/Time:** 04/06/2017 0626  
**Matrix:** Drinking Water  
**Order Name:** Sunnyside Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	1.5	0.50		ug/L	1	04/10/2017 1600	04/13/2017 1715	MH

**Client:** Arizona Department of Environmental Qual  
**Project:** Lead Analysis  
**Work Order:** 17D0341  
**Lab Sample ID:** 17D0341-05

**Client Sample ID:** 5  
**Collection Date/Time:** 04/06/2017 0630  
**Matrix:** Drinking Water  
**Order Name:** Sunnyside Unified District

Analyses	Result	PQL	Qual	Units	DF	Prep Date	Analysis Date	Analyst
ICP/MS Total Metals-E200.8 (5.4)								
Lead	0.91	0.50		ug/L	1	04/10/2017 1600	04/13/2017 1721	MH



**Client:** Arizona Department of Environmental Quality-Phx  
**Project:** Lead Analysis  
**Work Order:** 17D0341  
**Date Received:** 04/06/2017

**QC Summary**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qual
<b>Batch 1704111 - E200.8 (5.4)</b>										
<b>Blank (1704111-BLK1)</b>				Prepared: 04/11/2017 Analyzed: 04/13/2017						
Lead	ND	0.50	ug/L							
<b>LCS (1704111-BS1)</b>				Prepared: 04/11/2017 Analyzed: 04/13/2017						
Lead	49	0.50	ug/L	50.00		98	85-115			
<b>LCS Dup (1704111-BSD1)</b>				Prepared: 04/11/2017 Analyzed: 04/13/2017						
Lead	48	0.50	ug/L	50.00		97	85-115	0.6	20	
<b>Matrix Spike (1704111-MS1)</b>				<b>Source: 17D0111-01</b>		Prepared: 04/11/2017 Analyzed: 04/13/2017				
Lead	55	0.50	ug/L	50.00	1.2	108	70-130			
<b>Matrix Spike (1704111-MS2)</b>				<b>Source: 17D0297-02</b>		Prepared: 04/11/2017 Analyzed: 04/13/2017				
Lead	53	0.50	ug/L	50.00	2.6	101	70-130			


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors


17D0341-01

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Sunnyside Unified District
School Name	<del>Los</del> Los Amigos Elem
Building (name/number)	Front office #100
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	Front office #100 Room
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	# 1
Date of Collection	4-6-2017
Time of Collection	6:10 AM
Printed Name of Sample Collector	Anthony Ravi
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/6/17 14:16
Signature	
Notes: Temp 21.9	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors


17D0341-02

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Sunnyside Unified District
School Name	# Los Amigos Elem
Building (name/number)	# 600 wing
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	# 610 classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	# 2
Date of Collection	4-6-2017
Time of Collection	6:15 AM
Printed Name of Sample Collector	Anthony Val
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/6/17 14:11
Signature	
Notes: Temp. 21.9	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


These samples were collected for lead screening purposes only and cannot be used for compliance.

**Collection Log**  
*for experienced sample collectors*


17D0341-03

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Sunnyside Unified District
School Name	Los Amigos Elem
Building (name/number)	# 500 wing
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	# 506 Classroom
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	#3
Date of Collection	4-6-2017
Time of Collection	6:19 AM
Printed Name of Sample Collector	Anthony F. Cui
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/6/17 14:11
Signature	
Notes:	Temp. 21.9

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors


17D0341-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Sunnyside Unified District
School Name	Los Arroyos Elem
Building (name/number)	#400 wing
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	#406 class
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	#4
Date of Collection	4-6-2017
Time of Collection	6:26 AM
Printed Name of Sample Collector	Anthony Peral
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/6/17 14:11
Signature	
Notes: Temp. 21.9	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


These samples were collected for lead screening purposes only and cannot be used for compliance.

**Collection Log**  
*for experienced sample collectors*


17D0341-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Sunnyside Unified District
School Name	Los Amigos Elem
Building (name/number)	# 300 wing
Type of Fixture (tap, drinking fountain etc.)	drinking Fountain
Location of Fixture (example, room number)	# 308 Classroom
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	# 5
Date of Collection	4-6-2017
Time of Collection	6:30 AM
Printed Name of Sample Collector	Anthony Davis
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/6/17 14:11
Signature	
Notes:	Temp. 21.9

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*