

750 Royal Oaks Drive, Suite 100  
Monrovia, California 91016-3629  
Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)



AT-1807

## Laboratory Report

for

Arizona Department of Environmental Quality  
1110 West Washington Street  
Phoenix, AZ 85007  
Attention: David Burchard

Date of Issue  
06/04/2017

  
Eurofins Eaton  
Analytical

TDF: Thomas.D.French  
Project Manager

Report:663746  
Project:INDIANOASIS-BUD  
ADHS License #:AZ0778  
Group:Baboquivari Middle School  
PO#:PO#: ADEQ16-116686:3



\* Accredited in accordance with TNi 2009 and ISO/IEC 17025:2005.

\* Laboratory certifies that the test results meet all **TNi 2009 and ISO/IEC 17025:2005** requirements unless noted under the individual analysis.

\* Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

\* Test results relate only to the sample(s) tested.

\* This report shall not be reproduced except in full, without the written approval of the laboratory.

## STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Mississippi	Certified
Arizona	AZ0778	Montana	Cert 0035
Arkansas	Certified	Nebraska	Certified
California-Monrovia-ELAP	2813	Nevada	CA00006-2016
California-Colton- ELAP	2812	New Hampshire *	2959
California-Folsom- ELAP	2820	New Jersey *	CA 008
California-Fresno- ELAP	2966	New Mexico	Certified
Colorado	Certified	New York *	11320
Connecticut	PH-0107	North Carolina	06701
Delaware	CA 006	North Dakota	R-009
Florida *	E871024	Oregon (Primary AB) *	ORELAP 4034
Georgia	947	Pennsylvania *	68-565
Guam	16-003r	Puerto Rico	Certified
Hawaii	Certified	Rhode Island	LAO00326
Idaho	Certified	South Carolina	87016
Illinois *	200033	South Dakota	Certified
Indiana	C-CA-01	Tennessee	TN02839
Kansas *	E-10268	Texas *	T104704230-15-9
Kentucky	90107	Utah *	CA000062016-10
Louisiana *	LA16003	Vermont	VT0114
Maine	CA0006	Virginia *	460260
Maryland	224	Washington	C838
Commonwealth of Northern Marianas Is.	MP0004	Wyoming	Certified
Massachusetts	M-CA006	EPA Region 5	Certified
Michigan	9906	Los Angeles County Sanitation Districts	10264

\* NELAP/TNI Recognized Accreditation Bodies

ISO 17025 Accredited Method List

The tests listed below are accredited and meet the requirements of ISO 17025 as verified by the ANSI-ASQ National Accreditation Board/ANAB.

Refer to Certificate and scope of accreditation (AT 1807) found at: <http://www.eatonanalytical.com>

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
1,4-Dioxane	EPA 522	x		x
2,3,7,8-TCDD	Modified EPA 1613B	x		x
Acrylamide	In House Method (2440)	x		x
Alkalinity	SM 2320B	x	x	x
Ammonia	EPA 350.1		x	x
Ammonia	SM 4500-NH3 H		x	x
Anions and DBPs by IC	EPA 300.0	x	x	x
Anions and DBPs by IC	EPA 300.1	x		x
Asbestos	EPA 100.2	x	x	
Bicarbonate Alkalinity as HCO <sub>3</sub>	SM 2320B	x	x	x
BOD / CBOD	SM 5210B		x	x
Bromate	In House Method (2447)	x		x
Carbamates	EPA 531.2	x		x
Carbonate as CO <sub>3</sub>	SM 2330B	x	x	x
Carbonyls	EPA 556	x		x
COD	EPA 410.4 / SM 5220D		x	
Chloramines	SM 4500-CL G	x	x	x
Chlorinated Acids	EPA 515.4	x		x
Chlorinated Acids	EPA 555	x		x
Chlorine Dioxide	SM 4500-CLO <sub>2</sub> D	x		x
Chlorine -Total/Free/ Combined Residual	SM 4500-Cl G	x	x	x
Conductivity	EPA 120.1		x	
Conductivity	SM 2510B	x	x	x
Corrosivity (Langelier Index)	SM 2330B	x		x
Cryptosporidium	EPA 1623	x		x
Cyanide, Amenable	SM 4500-CN G	x	x	
Cyanide, Free	SM 4500CN F	x	x	x
Cyanide, Total	EPA 335.4	x	x	x
Cyanogen Chloride (screen)	In House Method (2470)	x		x
Diquat and Paraquat	EPA 549.2	x		x
DBP/HAA	SM 6251B	x		x
Dissolved Oxygen	SM 4500-O G		x	x
DOC	SM 5310C	x		x
E. Coli (MTF/EC+MUG)		x		x
E. Coli	CFR 141.21(f)(6)(i)	x		x
E. Coli	SM 9223		x	
E. Coli (Enumeration)	SM 9221B.1/ SM 9221F	x		x
E. Coli (Enumeration)	SM 9223B	x		x
EDB/DCBP	EPA 504.1	x		
EDB/DCBP and DBP	EPA 551.1	x		x
EDTA and NTA	In House Method (2454)	x		x
Endothall	EPA 548.1	x		x
Endothall	In-house Method (2445)	x		x
Enterococci	SM 9230B	x	x	
Fecal Coliform	SM 9221 E (MTF/EC)	x		
Fecal Coliform	SM 9221C, E (MTF/EC)		x	
Fecal Coliform (Enumeration)	SM 9221E (MTF/EC)	x		x
Fecal Coliform with Chlorine Present	SM 9221E		x	
Fecal Streptococci	SM 9230B	x	x	
Fluoride	SM 4500-F C	x	x	x
Giardia	EPA 1623	x		x
Glyphosate	EPA 547	x		x
Gross Alpha/Beta	EPA 900.0	x	x	x
Gross Alpha Coprecipitation	SM 7110 C	x	x	x
Hardness	SM 2340B	x	x	x
Heterotrophic Bacteria	In House Method (2439)	x		x
Heterotrophic Bacteria	SM 9215 B	x		x
Hexavalent Chromium	EPA 218.6	x	x	x

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
Hexavalent Chromium	EPA 218.7	x		x
Hexavalent Chromium	SM 3500-Cr B		x	
Hormones	EPA 539	x		x
Hydroxide as OH Calc.	SM 2330B	x		x
Kjeldahl Nitrogen	EPA 351.2		x	
Legionella	CDC Legionella	x		x
Mercury	EPA 245.1	x	x	x
Metals	EPA 200.7 / 200.8	x	x	x
Microcystin LR	ELISA (2360)	x		x
NDMA	EPA 521	x		x
NDMA	TQ In house method based on EPA 521 (2425)	x		x
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x	x
OCL, Pesticides/PCB	EPA 505	x		x
Ortho Phosphate	EPA 365.1	x	x	x
Ortho Phosphate	SM 4500P E			x
Ortho Phosphorous	SM 4500P E	x		
Oxyhalides Disinfection Byproducts	EPA 317.0	x		x
Perchlorate	EPA 331.0	x		x
Perchlorate (low and high)	EPA 314.0	x		x
Perfluorinated Alkyl Acids	EPA 537	x		x
pH	EPA 150.1	x		
pH	SM 4500-H+B	x	x	x
Phenylurea Pesticides/ Herbicides	In House Method, based on EPA 532 (2448)	x		x
Pseudomonas	IDEXX Pseudalert (2461)	x		x
Radium-226	GA Institute of Tech	x		x
Radium-228	GA Institute of Tech	x		x
Radon-222	SM 7500RN	x		x
Residue, Filterable	SM 2540C	x	x	x
Residue, Non-filterable	SM 2540D		x	
Residue, Total	SM 2540B		x	x
Residue, Volatile	EPA 160.4		x	
Semi-VOC	EPA 525.2	x		x
Semi-VOC	EPA 625		x	x
Silica	SM 4500-Si D	x	x	
Silica	SM 4500-SiO <sub>2</sub> C	x	x	
Sulfide	SM 4500-S <sup>-</sup> D		x	
Sulfite	SM 4500-SO <sub>3</sub> B	x	x	x
Surfactants	SM 5540C	x	x	x
Taste and Odor Analytes	SM 6040E	x		x
Total Coliform (P/A)	SM 9221 A, B	x		x
Total Coliform (Enumeration)	SM 9221 A, B, C	x		x
Total Coliform / E. coli	Colisure SM 9223	x		x
Total Coliform	SM 9221B		x	
Total Coliform with Chlorine Present	SM 9221B		x	
Total Coliform / E.coli (P/A and Enumeration)	SM 9223	x		x
TOC	SM 5310C	x	x	x
TOX	SM 5320B		x	
Total Phenols	EPA 420.1		x	
Total Phenols	EPA 420.4	x	x	x
Total Phosphorous	SM 4500 P E		x	
Turbidity	EPA 180.1	x	x	x
Turbidity	SM 2130B	x	x	
Uranium by ICP/MS	EPA 200.8	x		x
UV 254	SM 5910B	x		
VOC	EPA 524.2/EPA 524.3	x		x
VOC	EPA 624		x	x
VOC	EPA SW 846 8260	x		x
VOC	In House Method (2411)	x		x
Yeast and Mold	SM 9610	x		x

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 663746  
Project: INDIANOASIS-BUD  
Sample Group: Baboquivari Middle School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Barbara Cardinal

The following samples were received from you on **June 01, 2017 at 1256**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
<u>201706011060</u>	Cafeteria - Second	05/18/2017 0850
	Sample Type: Tap Facility ID: Cafeteria Sample Point ID: Kitchen	
	@ICPMS	Freight - Outbound
		Freight - Return
<u>201706011061</u>	I5	05/18/2017 0815
	Sample Type: Drinking Fountain Facility ID: I Sample Point ID: I5	
	@ICPMS	
<u>201706011062</u>	M.S Restroom	05/18/2017 0838
	Sample Type: Drinking Fountain Facility ID: Middle School Outside - RR Sample Point ID: M.S. Outside Restroom	
	@ICPMS	
<u>201706011063</u>	Boys Restroom	05/18/2017 0800
	Sample Type: Tap Facility ID: M.S. Restrooms Sample Point ID: Boys M.S. Restroom	
	@ICPMS	
<u>201706011064</u>	Bld A	05/18/2017 0812
	Sample Type: Drinking Fountain Facility ID: A Building Sample Point ID: A Building Hallway	
	@ICPMS	
<u>201706011065</u>	B Building	05/18/2017 0808
	Sample Type: Drinking Fountain Facility ID: B Building Sample Point ID: B Building Hallway	
	@ICPMS	
<u>201706011076</u>	E2 Building	05/18/2017 0751
	Sample Type: Tap Facility ID: E Building Sample Point ID: E2	
	@ICPMS	
<u>201706011077</u>	F3 Building	05/18/2017 0755

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 663746  
Project: INDIANOASIS-BUD  
Sample Group: Baboquivari Middle School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Barbara Cardinal

The following samples were received from you on **June 01, 2017 at 1256**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	Sample Type: Tap Facility ID: F Building Sample Point ID: F3 @ICPMS	
<b>201706011078</b>	<b>F4 Building</b>	<b>05/18/2017 0758</b>
	Sample Type: Tap Facility ID: F Building Sample Point ID: F4 @ICPMS	

### Test Description

@ICPMS -- ICPMS Metals

Invoice: Date: 10 May 17 SHIPPING: 0.00  
 Customer: K#169884 Wgt: 8.00 LBS SPECIAL: 0.00  
 Dept: COD: HANDLING: 0.00  
 PO Number: DV: 0.00 TOTAL: 0.00  
 ADEQ Public School District  
 Sampling Plan & Collection  
 Sys: GND PPD RMGR  
 TRCK: 732498204727

## Collection Log

for experienced sample collectors

663746

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD #40
School Name	BARBQUIVARI SECONDARY
Building (name/number)	CAFETERIA
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	KITCHEN
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	CAFETERIA - SECOND
Date of Collection	5/18/17
Time of Collection	8:50 AM
Printed Name of Sample Collector	BARBARA CARDINAL
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/1/17 12:56
Signature	<i>[Signature]</i>
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD#40
School Name	BABOQUIVARI SECONDARY
Building (name/number)	I
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	I5
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	I5
Date of Collection	5/18/17
Time of Collection	8:15 AM
Printed Name of Sample Collector	BARBARA CARDINAL
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/1/17 12:56
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD #40
School Name	BABOQUIARI MIDDLE SCHOOL
Building (name/number)	MIDDLE SCHOOL OUTSIDE RESTROOM
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	M.S. OUTSIDE RESTROOM
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	M.S. RESTROOM
Date of Collection	5/18/17
Time of Collection	8:38 AM
Printed Name of Sample Collector	BARBARA CARDINAL
Signature Sample Collector	<i>Barbara Cardinal</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/1/17 12:56
Signature	<i>[Signature]</i>
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD #40
School Name	BABOQUIVARI M. S.
Building (name/number)	M.S. RESTROOMS
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	BOYS M.S. RESTROOM
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	BOYS RESTROOM
Date of Collection	5/18/17
Time of Collection	8:00 AM
Printed Name of Sample Collector	BARBARA CARDINAL
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/1/17 12:56
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD #40
School Name	B. M. S.
Building (name/number)	A BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	A BUILDING HALLWAY
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	BUD. A.
Date of Collection	5/18/17
Time of Collection	8:12 AM
Printed Name of Sample Collector	BARBARA CARDINAL
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/1/17 12:56
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD #40
School Name	BMS
Building (name/number)	B BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	B BUILDING HALLWAY
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	B BUILDING
Date of Collection	8/18/17
Time of Collection	8:08AM
Printed Name of Sample Collector	BARBARA CARDINAC
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	8/1/17 12:56
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD #40
School Name	BABO MIDDLE SCHOOL
Building (name/number)	E BUILDING
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	E2
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	E2 BUILDING
Date of Collection	5/18/17
Time of Collection	7:51 AM
Printed Name of Sample Collector	BARBARA CARDINAL
Signature Sample Collector	<i>Barbara Cardinal</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/1/17 12:56
Signature	<i>[Signature]</i>
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD #40
School Name	BABO M. S.
Building (name/number)	F BUILDING
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	F3
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	F3 BUILDING
Date of Collection	5/18/17
Time of Collection	7:55 AM
Printed Name of Sample Collector	BARBARA CARDINAL
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/1/17 12:56
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	BUSD#40
School Name	BABO M. S.
Building (name/number)	F BUILDING
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	F4
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	F4 BUILDING
Date of Collection	5/18/17
Time of Collection	7:58 AM
Printed Name of Sample Collector	BARBARA CARDINAL
Signature Sample Collector	<i>Barbara Cardinal</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/1/17 12:56
Signature	<i>[Signature]</i>
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



750 Royal Oaks Drive, Suite 100  
Monrovia, California 91016-3629  
(626) 386-1100 FAX (626) 386-1101

Kit #: 169889



**Created By:** Thomas.D.French - [TDF]  
**Deliver By:** 05/12/2017

**STG:** Bottle Orders

**Ice Type:** W

**Note: Sampler Please return this paper with your samples**
**Client ID:** ADEQ-LEAD

**Project Code:** INDIANOASIS-BUD Bottle Orders

**Group Name:** Baboquivari Middle School

**PO#/JOB#:** ADEQ16-116686:3

**Ship Sample Kits to**  
Indian Oasis-Baboquivari Unified District  
Attention Highway 86, Mile Post 115.5  
Sells, AZ 85634  
  
Attn: Edna Morris-Superintendent

**Send Report to**  
Arizona Department of Environmental  
Quality  
1110 West Washington Street  
Phoenix, AZ 85007  
  
Attn: David Burchard  
Phone: (602) 771-4298

**Billing Address**  
Arizona Department of Environmental  
Quality  
1110 West Washington Street  
Phoenix, AZ 85007  
  
Attn: ADEQ  
Phone: (602) 771-1936

# of

Sample Tests

6

@ICPMS

Bottle Qty - Type [ preservative information ]

1 - 250ml poly [ no preservative ]

UN DOT #

**Comments**

Baboquivari Middle School - Include Indian Oasis-Baboquivari Unified District School-Specific Sample list, 6 Lead Sampling Plan Records, packing instructions for return shipment to Eurofins Eaton Analytical, Inc.  
750 Royal Oaks Drive, Suite C, Monrovia, CA 91016. 6 sample containers. Return Shipment Fed EX

Sampler - please refer to Sampling Plan Records for instructions on completing paperwork and what to include with return shipment of the samples.

Code

Status


Date Shipped

Via

Tracking #

# of Coolers

Prepared By



Eaton Analytical

# INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number:

663746

SAMPLE TEMP RECEIVED:

SAMPLES REC'D DAY OF COLLECTION?

IR Gun ID = 569A (Observation = 25.1 °C) (Corr.Factor = -2 °C) (Final = 24.9 °C)

TYPE OF ICE: Real ☐ Synthetic ☒ No Ice ☒ CONDITION OF ICE: Frozen ☐ Partially Frozen ☐ Thawed ☒ N/A ☒

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: 7324-9826-4727

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤ 6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥ 10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)

4) UCMR3 : 524.3: (Observation = \_\_\_\_\_ °C) (Corr.Factor = \_\_\_\_\_ °C) (Final = \_\_\_\_\_ °C)  
(non-GLEC)

522: (Observation = \_\_\_\_\_ °C) (Corr.Factor = \_\_\_\_\_ °C) (Final = \_\_\_\_\_ °C)

≤ 10°C if received within 48 hours of sample collection (not the same business day); ≤ 6°C if received after 48 hours of sample collection. Measure temperature for each method above.

5) LT2: Giardia /Cryptosporidium: <20 °C, not frozen (received after 8 hours of sample collection)

E. Coli: < 10°C, not frozen (if received after 2 hours of sample collection)

Giardia/Crypto: (Observation = \_\_\_\_\_ °C) (Corr.Factor = \_\_\_\_\_ °C) (Final = \_\_\_\_\_ °C)

E.Coli: (Observation = \_\_\_\_\_ °C) (Corr.Factor = \_\_\_\_\_ °C) (Final = \_\_\_\_\_ °C)

6) Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SIGNATURE

PRINT NAME

COMPANY/TITLE

DATE

TIME

RECEIVED BY:

Chris Gelfo

Eurofins Eaton Analytical

6/1/17

12:56

Indian Oasis- Baboquivari Unified District	Baboquivari Middle School	1001	10301-administration, computer lab	administration, computer classroom, jostons trainin	1993	Pima	1
Indian Oasis- Baboquivari Unified District	Baboquivari Middle School	1002	10302-student services	<u>Bldg-B</u> offices, student service, teachers lounge 5/18/17 8:00 AM	1997	Pima	1
Indian Oasis- Baboquivari Unified District	Baboquivari Middle School	1003	10303-seventh grade	classrooms 5/18/17 - 7:51 AM	1997	Pima	1
Indian Oasis- Baboquivari Unified District	Baboquivari Middle School	1004	10304 o odham language, health, fine arts	F-3 classrooms 7:55 AM (5/18/17)	1997	Pima	1
Indian Oasis- Baboquivari Unified District	Baboquivari Middle School	1005	10305-alternative, boys, girls restrooms	alternative classroom, detention, restrooms 8:00 AM	1997	Pima	1
Indian Oasis- Baboquivari Unified District	Baboquivari Middle School	1006	10306-eighth grade classrooms	F-4 classrooms - math, social studies 5/18/17 7:58 AM	1997	Pima	1

Total Containers

6

9

Bld. A 5/18/17 8:12 AM

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

**Laboratory Comments**

**Report:** 663746  
**Project:** INDIANOASIS-BUD  
**Group:** Baboquivari Middle School

Arizona Department of Environmental Quality  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

---

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

**Report:** 663746  
**Project:** INDIANOASIS-BUD  
**Group:** Baboquivari Middle School

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
06/01/2017 1256

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
06/02/2017 13:42	Lead Total ICAP/MS	<b><u>Boys Restroom</u></b>	5.8	15	ug/L	0.5
06/02/2017 13:51	Lead Total ICAP/MS	<b><u>E2 Building</u></b>	4.2	15	ug/L	0.5
06/02/2017 13:52	Lead Total ICAP/MS	<b><u>F3 Building</u></b>	2.2	15	ug/L	0.5

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data

**Report:** 663746  
**Project:** INDIANOASIS-BUD  
**Group:** Baboquivari Middle School

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
06/01/2017 1256

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
<b><u>Cafeteria - Second (201706011060)</u></b>						<b>Sampled on 05/18/2017 0850</b>			
Sample Type: Tap Facility ID: Cafeteria Sample Point ID: Kitchen									
<b>EPA 200.8 - ICPMS Metals</b>									
06/02/17	06/02/17 13:38	999650	999877	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>I5 (201706011061)</u></b>						<b>Sampled on 05/18/2017 0815</b>			
Sample Type: Drinking Fountain Facility ID: I Sample Point ID: I5									
<b>EPA 200.8 - ICPMS Metals</b>									
06/02/17	06/02/17 13:41	999650	999877	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>M.S Restroom (201706011062)</u></b>						<b>Sampled on 05/18/2017 0838</b>			
Sample Type: Drinking Fountain Facility ID: Middle School Outside - RR Sample Point ID: M.S. Outside Restroom									
<b>EPA 200.8 - ICPMS Metals</b>									
06/02/17	06/02/17 13:41	999650	999877	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>Boys Restroom (201706011063)</u></b>						<b>Sampled on 05/18/2017 0800</b>			
Sample Type: Tap Facility ID: M.S. Restrooms Sample Point ID: Boys M.S. Restroom									
<b>EPA 200.8 - ICPMS Metals</b>									
06/02/17	06/02/17 13:42	999650	999877	(EPA 200.8)	Lead Total ICAP/MS	5.8	ug/L	0.5	1
<b><u>Bld A (201706011064)</u></b>						<b>Sampled on 05/18/2017 0812</b>			
Sample Type: Drinking Fountain Facility ID: A Building Sample Point ID: A Building Hallway									
<b>EPA 200.8 - ICPMS Metals</b>									
06/02/17	06/02/17 13:43	999650	999877	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>B Building (201706011065)</u></b>						<b>Sampled on 05/18/2017 0808</b>			
Sample Type: Drinking Fountain Facility ID: B Building Sample Point ID: B Building Hallway									
<b>EPA 200.8 - ICPMS Metals</b>									
06/02/17	06/02/17 13:49	999650	999879	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>E2 Building (201706011076)</u></b>						<b>Sampled on 05/18/2017 0751</b>			
Sample Type: Tap Facility ID: E Building Sample Point ID: E2									
<b>EPA 200.8 - ICPMS Metals</b>									
06/02/17	06/02/17 13:51	999650	999879	(EPA 200.8)	Lead Total ICAP/MS	4.2	ug/L	0.5	1
<b><u>F3 Building (201706011077)</u></b>						<b>Sampled on 05/18/2017 0755</b>			

Rounding on totals after summation.  
(c) - indicates calculated results



Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data

**Report:** 663746  
**Project:** INDIANOASIS-BUD  
**Group:** Baboquivari Middle School

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
06/01/2017 1256

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
<p>Sample Type: Tap Facility ID: F Building Sample Point ID: F3</p> <p><b>EPA 200.8 - ICPMS Metals</b></p>									
06/02/17	06/02/17 13:52	999650	999879	(EPA 200.8)	Lead Total ICAP/MS	2.2	ug/L	0.5	1
<p><b><u>F4 Building (201706011078)</u></b></p> <p>Sample Type: Tap Facility ID: F Building Sample Point ID: F4</p> <p><b>EPA 200.8 - ICPMS Metals</b></p>									
06/02/17	06/02/17 13:53	999650	999879	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1

**Sampled on 05/18/2017 0758**

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

## Laboratory QC Summary

**Report:** 663746  
**Project:** INDIANOASIS-BUD  
**Group:** Baboquivari Middle School

Arizona Department of Environmental Quality

---

## ICPMS Metals

**Prep Batch: 999650 Analytical Batch: 999877**

201706011060	Cafeteria - Second
201706011061	I5
201706011062	M.S Restroom
201706011063	Boys Restroom
201706011064	Bld A

**Analysis Date: 06/02/2017**

Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD

## ICPMS Metals

**Prep Batch: 999650 Analytical Batch: 999879**

201706011065	B Building
201706011076	E2 Building
201706011077	F3 Building
201706011078	F4 Building

**Analysis Date: 06/02/2017**

Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

**Report:** 663746  
**Project:** INDIANOASIS-BUD  
**Group:** Baboquivari Middle School

## Arizona Department of Environmental Quality

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield (%)	Limits (%)	RPDLimit (%)	RPD%
<b>ICPMS Metals by EPA 200.8</b>									
<b>Analytical Batch: 999877</b>					<b>Analysis Date: 06/02/2017</b>				
LCS1	Lead Total ICAP/MS		20	19.8	ug/L	99	(85-115)		
LCS2	Lead Total ICAP/MS		20	19.7	ug/L	99	(85-115)	20	0.51
MBLK	Lead Total ICAP/MS			<0.25	ug/L				
MRL_CHK	Lead Total ICAP/MS		0.5	0.527	ug/L	105	(50-150)		
MS_201706011001	Lead Total ICAP/MS	3.9	20	25.3	ug/L	107	(70-130)		
MS2_201706011024	Lead Total ICAP/MS	ND	20	21.8	ug/L	109	(70-130)		
MSD_201706011001	Lead Total ICAP/MS	3.9	20	25.4	ug/L	108	(70-130)	20	0.39
MSD2_201706011024	Lead Total ICAP/MS	ND	20	21.6	ug/L	108	(70-130)	20	0.92
<b>ICPMS Metals by EPA 200.8</b>									
<b>Analytical Batch: 999879</b>					<b>Analysis Date: 06/02/2017</b>				
LCS1	Lead Total ICAP/MS		20	19.8	ug/L	99	(85-115)		
LCS2	Lead Total ICAP/MS		20	20.0	ug/L	100	(85-115)	20	1.0
MBLK	Lead Total ICAP/MS			<0.25	ug/L				
MRL_CHK	Lead Total ICAP/MS		0.5	0.527	ug/L	105	(50-150)		
MS_201706011065	Lead Total ICAP/MS	ND	20	21.4	ug/L	107	(70-130)		
MS2_201706011093	Lead Total ICAP/MS	ND	20	21.7	ug/L	108	(70-130)		
MSD_201706011065	Lead Total ICAP/MS	ND	20	21.3	ug/L	107	(70-130)	20	0.47
MSD2_201706011093	Lead Total ICAP/MS	ND	20	21.6	ug/L	108	(70-130)	20	0.46

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.