

750 Royal Oaks Drive, Suite 100  
Monrovia, California 91016-3629  
Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)



## Laboratory Report

for

Arizona Department of Environmental Quality  
1110 West Washington Street  
Phoenix, AZ 85007  
Attention: David Burchard

Date of Issue  
05/30/2017



Eurofins Eaton  
Analytical

TDF: Thomas.D.French  
Project Manager

Report:661841  
Project:GANADO-USD  
ADHS License #:AZ0778  
Group:Ganado Intermediate School  
PO#:PO#: ADEQ16-116686:3



\* Accredited in accordance with TNI 2009 and ISO/IEC 17025:2005.

\* Laboratory certifies that the test results meet all **TNI 2009 and ISO/IEC 17025:2005** requirements unless noted under the individual analysis.

\* Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

\* Test results relate only to the sample(s) tested.

\* This report shall not be reproduced except in full, without the written approval of the laboratory.

## STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Mississippi	Certified
Arizona	AZ0778	Montana	Cert 0035
Arkansas	Certified	Nebraska	Certified
California-Monrovia-ELAP	2813	Nevada	CA00006-2016
California-Colton- ELAP	2812	New Hampshire *	2959
California-Folsom- ELAP	2820	New Jersey *	CA 008
California-Fresno- ELAP	2966	New Mexico	Certified
Colorado	Certified	New York *	11320
Connecticut	PH-0107	North Carolina	06701
Delaware	CA 006	North Dakota	R-009
Florida *	E871024	Oregon (Primary AB) *	ORELAP 4034
Georgia	947	Pennsylvania *	68-565
Guam	16-003r	Puerto Rico	Certified
Hawaii	Certified	Rhode Island	LAO00326
Idaho	Certified	South Carolina	87016
Illinois *	200033	South Dakota	Certified
Indiana	C-CA-01	Tennessee	TN02839
Kansas *	E-10268	Texas *	T104704230-15-9
Kentucky	90107	Utah *	CA000062016-10
Louisiana *	LA16003	Vermont	VT0114
Maine	CA0006	Virginia *	460260
Maryland	224	Washington	C838
Commonwealth of Northern Marianas Is.	MP0004	Wyoming	Certified
Massachusetts	M-CA006	EPA Region 5	Certified
Michigan	9906	Los Angeles County Sanitation Districts	10264

\* NELAP/TNI Recognized Accreditation Bodies

ISO 17025 Accredited Method List

The tests listed below are accredited and meet the requirements of ISO 17025 as verified by the ANSI-ASQ National Accreditation Board/ANAB.

Refer to Certificate and scope of accreditation (AT 1807) found at: <http://www.eatonanalytical.com>

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
1,4-Dioxane	EPA 522	x		x
2,3,7,8-TCDD	Modified EPA 1613B	x		x
Acrylamide	In House Method (2440)	x		x
Alkalinity	SM 2320B	x	x	x
Ammonia	EPA 350.1		x	x
Ammonia	SM 4500-NH3 H		x	x
Anions and DBPs by IC	EPA 300.0	x	x	x
Anions and DBPs by IC	EPA 300.1	x		x
Asbestos	EPA 100.2	x	x	
Bicarbonate Alkalinity as HCO3	SM 2320B	x	x	x
BOD / CBOD	SM 5210B		x	x
Bromate	In House Method (2447)	x		x
Carbamates	EPA 531.2	x		x
Carbonate as CO3	SM 2330B	x	x	x
Carbonyls	EPA 556	x		x
COD	EPA 410.4 / SM 5220D		x	
Chloramines	SM 4500-CL G	x	x	x
Chlorinated Acids	EPA 515.4	x		x
Chlorinated Acids	EPA 555	x		x
Chlorine Dioxide	SM 4500-CLO2 D	x		x
Chlorine -Total/Free/ Combined Residual	SM 4500-Cl G	x	x	x
Conductivity	EPA 120.1		x	
Conductivity	SM 2510B	x	x	x
Corrosivity (Langelier Index)	SM 2330B	x		x
Cryptosporidium	EPA 1623	x		x
Cyanide, Amenable	SM 4500-CN G	x	x	
Cyanide, Free	SM 4500CN F	x	x	x
Cyanide, Total	EPA 335.4	x	x	x
Cyanogen Chloride (screen)	In House Method (2470)	x		x
Diquat and Paraquat	EPA 549.2	x		x
DBP/HAA	SM 6251B	x		x
Dissolved Oxygen	SM 4500-O G		x	x
DOC	SM 5310C	x		x
E. Coli (MTF/EC+MUG)		x		x
E. Coli	CFR 141.21(f)(6)(i)	x		x
E. Coli	SM 9223		x	
E. Coli (Enumeration)	SM 9221B.1/ SM 9221F	x		x
E. Coli (Enumeration)	SM 9223B	x		x
EDB/DCBP	EPA 504.1	x		
EDB/DBCP and DBP	EPA 551.1	x		x
EDTA and NTA	In House Method (2454)	x		x
Endothall	EPA 548.1	x		x
Endothall	In-house Method (2445)	x		x
Enterococci	SM 9230B	x	x	
Fecal Coliform	SM 9221 E (MTF/EC)	x		
Fecal Coliform	SM 9221C, E (MTF/EC)		x	
Fecal Coliform (Enumeration)	SM 9221E (MTF/EC)	x		x
Fecal Coliform with Chlorine Present	SM 9221E		x	
Fecal Streptococci	SM 9230B	x	x	
Fluoride	SM 4500-F C	x	x	x
Giardia	EPA 1623	x		x
Glyphosate	EPA 547	x		x
Gross Alpha/Beta	EPA 900.0	x	x	x
Gross Alpha Coprecipitation	SM 7110 C	x	x	x
Hardness	SM 2340B	x	x	x
Heterotrophic Bacteria	In House Method (2439)	x		x
Heterotrophic Bacteria	SM 9215 B	x		x
Hexavalent Chromium	EPA 218.6	x	x	x

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
Hexavalent Chromium	EPA 218.7	x		x
Hexavalent Chromium	SM 3500-Cr B		x	
Hormones	EPA 539	x		x
Hydroxide as OH Calc.	SM 2330B	x		x
Kjeldahl Nitrogen	EPA 351.2		x	
Legionella	CDC Legionella	x		x
Mercury	EPA 245.1	x	x	x
Metals	EPA 200.7 / 200.8	x	x	x
Microcystin LR	ELISA (2360)	x		x
NDMA	EPA 521	x		x
NDMA	TQ In house method based on EPA 521 (2425)	x		x
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x	x
OCL, Pesticides/PCB	EPA 505	x		x
Ortho Phosphate	EPA 365.1	x	x	x
Ortho Phosphate	SM 4500P E			x
Ortho Phosphorous	SM 4500P E	x		
Oxyhalides Disinfection Byproducts	EPA 317.0	x		x
Perchlorate	EPA 331.0	x		x
Perchlorate (low and high)	EPA 314.0	x		x
Perfluorinated Alkyl Acids	EPA 537	x		x
pH	EPA 150.1	x		
pH	SM 4500-H+B	x	x	x
Phenylurea Pesticides/ Herbicides	In House Method, based on EPA 532 (2448)	x		x
Pseudomonas	IDEXX Pseudalert (2461)	x		x
Radium-226	GA Institute of Tech	x		x
Radium-228	GA Institute of Tech	x		x
Radon-222	SM 7500RN	x		x
Residue, Filterable	SM 2540C	x	x	x
Residue, Non-filterable	SM 2540D		x	
Residue, Total	SM 2540B		x	x
Residue, Volatile	EPA 160.4		x	
Semi-VOC	EPA 525.2	x		x
Semi-VOC	EPA 625		x	x
Silica	SM 4500-Si D	x	x	
Silica	SM 4500-SiO2 C	x	x	
Sulfide	SM 4500-S <sup>-</sup> D		x	
Sulfite	SM 4500-SO <sup>3</sup> B	x	x	x
Surfactants	SM 5540C	x	x	x
Taste and Odor Analytes	SM 6040E	x		x
Total Coliform (P/A)	SM 9221 A, B	x		x
Total Coliform (Enumeration)	SM 9221 A, B, C	x		x
Total Coliform / E. coli	Colisure SM 9223	x		x
Total Coliform	SM 9221B		x	
Total Coliform with Chlorine Present	SM 9221B		x	
Total Coliform / E.coli (P/A and Enumeration)	SM 9223	x		x
TOC	SM 5310C	x	x	x
TOX	SM 5320B		x	
Total Phenols	EPA 420.1		x	
Total Phenols	EPA 420.4	x	x	x
Total Phosphorous	SM 4500 P E		x	
Turbidity	EPA 180.1	x	x	x
Turbidity	SM 2130B	x	x	
Uranium by ICP/MS	EPA 200.8	x		x
UV 254	SM 5910B	x		
VOC	EPA 524.2/EPA 524.3	x		x
VOC	EPA 624		x	x
VOC	EPA SW 846 8260	x		x
VOC	In House Method (2411)	x		x
Yeast and Mold	SM 9610	x		x

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 661841  
Project: GANADO-USD  
Sample Group: Ganado Intermediate School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Keith Long

The following samples were received from you on **May 23, 2017** at **1025**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
<u>201705230595</u>	1001	05/18/2017 0535
Sample Type: Classroom Sink Facility ID: Building 100 Part 1 Sample Point ID: D-1 Classroom #13 @ICPMS                      Freight - Outbound                      Freight - Return		
<u>201705230596</u>	1001	05/18/2017 0613
Sample Type: Classroom Facility ID: Building 100 Part 1 Sample Point ID: D-1 Classroom #13 @ICPMS		
<u>201705230597</u>	1002	05/18/2017 0542
Sample Type: Classroom Sink Facility ID: Building 100 Part 2 Sample Point ID: E1 E40-0 @ICPMS		
<u>201705230598</u>	1003	05/18/2017 0552
Sample Type: Kitchen Sink Facility ID: Kitchen Addition Sample Point ID: Intermediate Discharge Sink F @ICPMS		

## Test Description

@ICPMS -- ICPMS Metals

Invoice: Date: 09May17  
Customer: K#169567 Wgt: 0.65 LBS  
Dept: COD:  
PO Number: DV:

SHIPPING: 0.00  
SPECIAL: 0.00  
HANDLING: 0.00  
TOTAL: 0.00

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Sys: GND PPD RMGR  
TRCK: 732498204337

## Collection Log

for experienced sample collectors

661841

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Ganado USD #20
School Name	Ganado Intermediate School
Building (name/number)	building 100 part 1
Type of Fixture (tap, drinking fountain etc.)	Classroom Sink
Location of Fixture (example, room number)	D-1 Classroom #13
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	1001
Date of Collection	5/18/17
Time of Collection	5:35 am
Printed Name of Sample Collector	Keith Long
Signature Sample Collector	Keith Long

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5/23/17 1025
Signature	[Signature]
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Granado USD #20
School Name	Granado Intermediate School
Building (name/number)	building 100 part 1
Type of Fixture (tap, drinking fountain etc.)	Class room
Location of Fixture (example, room number)	D-1 Classroom #13
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	1001
Date of Collection	5-18-17
Time of Collection	6:13 am
Printed Name of Sample Collector	Keith Long
Signature Sample Collector	Keith Long

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5-23-17 10:25
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Ganado USD #20
School Name	Ganado Intermediate
Building (name/number)	building 100 part 2
Type of Fixture (tap, drinking fountain etc.)	Classroom Sink
Location of Fixture (example, room number)	E1 E40-0
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	1002
Date of Collection	5/18/17
Time of Collection	5:42 am
Printed Name of Sample Collector	Keith Long
Signature Sample Collector	Keith Long

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5-23-17 1025
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Ganado USD #20
School Name	Ganado Intermediate School
Building (name/number)	Kitchen Addition
Type of Fixture (tap, drinking fountain etc.)	Kitchen Sink
Location of Fixture (example, room number)	Intermediate Dishwashing Sink Faucet
Sample Identification Number ( <b><u>Write this number on the sample container and on this sheet</u></b> )	1003
Date of Collection	5/18/17
Time of Collection	5:52 am
Printed Name of Sample Collector	Keith Long
Signature Sample Collector	Keith J Long

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	5-23-17 1025
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



750 Royal Oaks Drive, Suite 100  
Monrovia, California 91016-3629  
(626) 386-1100 FAX (626) 386-1101

Kit #: 169567



Created By: Thomas.D.French - [TDF]  
Deliver By: 05/12/2017  
STG: Bottle Orders  
Ice Type: W

**Note: Sampler Please return this paper with your samples**

Client ID: ADEQ-LEAD  
Project Code: GANADO-USD Bottle Orders  
Group Name: Ganado Intermediate School  
PO#/JOB#: ADEQ16-116686:3

**Ship Sample Kits to**  
Ganado Unified School  
District/Warehouse  
Highway 264  
Ganado, AZ 86505  
  
Attn: Wesley Begay-Housing Supervisor

**Send Report to**  
Arizona Department of Environmental  
Quality  
1110 West Washington Street  
Phoenix, AZ 85007  
  
Attn: David Burchard  
Phone: (602) 771-4298

**Billing Address**  
Arizona Department of Environmental  
Quality  
1110 West Washington Street  
Phoenix, AZ 85007  
  
Attn: ADEQ  
Phone: (602) 771-1936

# of

Sample Tests

4

@ICPMS

Bottle Qty - Type [preservative information]

1 - 250ml poly [ no preservative ]

UN DOT #

### Comments

Ganado Intermediate School - Include Ganado Unified District School-Specific Sample list, 4 Lead Sampling Plan Records, packing instructions for return shipment to Eurofins Eaton Analytical, Inc. 750 Royal Oaks Drive, Suite C, Monrovia, CA 91016. 4 sample containers. Return Shipment Fed EX

Sampler - please refer to Sampling Plan Records for instructions on completing paperwork and what to include with return shipment of the samples.

Code

Status


Date Shipped

Via

Tracking #

# of Coolers

Prepared By



Eaton Analytical

# INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number:

SAMPLES REC'D DAY OF COLLECTION? ☐

SAMPLE TEMP RECEIVED:

IR Gun ID = 569A (Observation = 23.1 °C) (Corr.Factor -0.2 °C) (Final = 22.9 °C)

TYPE OF ICE: Real ☒ Synthetic ☐ No Ice ☒

Thawed N/A

CONDITION OF ICE: Frozen ☐ Partially Frozen ☐

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: ON TRAC

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr.Factor = _____ °C) (Final = _____ °C)

- 4) UCMR3: 524.3: (Observation = \_\_\_\_\_ °C) (Corr.Factor = \_\_\_\_\_ °C) (Final = \_\_\_\_\_ °C)  
(non-GLEC)  
522: (Observation = \_\_\_\_\_ °C) (Corr.Factor = \_\_\_\_\_ °C) (Final = \_\_\_\_\_ °C)

≤10°C if received within 48 hours of sample collection (not the same business day); ≤6°C if received after 48 hours of sample collection, Measure temperature for each method above.

- 5) LT2: Giardia /Cryptosporidium: <20 °C, not frozen (received after 8 hours of sample collection)

E. Coli: < 10°C, not frozen (if received after 2 hours of sample collection)

Giardia/Crypto: (Observation = \_\_\_\_\_ °C) (Corr.Factor = \_\_\_\_\_ °C) (Final = \_\_\_\_\_ °C)

E.Coli: (Observation = \_\_\_\_\_ °C) (Corr.Factor = \_\_\_\_\_ °C) (Final = \_\_\_\_\_ °C)

- 6) Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

RECEIVED BY:	SIGNATURE	COMPANY/TITLE Eurofins Eaton Analytical	DATE 5.23.17	TIME 1025
--------------	-----------	--	-----------------	--------------

Ganado Unified District	Ganado Intermediate School	1001	building 100 part 1	classrooms	1977	Apache	2
Ganado Unified District	Ganado Intermediate School	1002	building 100 part 2	classrooms	1997	Apache	1
Ganado Unified District	Ganado Intermediate School	1003	Kitchen addition	Kitchen	2008	Apache	1
Total Containers							4
Address							

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

**Laboratory Comments**

**Report:** 661841  
**Project:** GANADO-USD  
**Group:** Ganado Intermediate School

Arizona Department of Environmental Quality  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

---

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Hits

**Report:** 661841  
**Project:** GANADO-USD  
**Group:** Ganado Intermediate School

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
05/23/2017 1025

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
05/28/2017 11:14	Lead Total ICAP/MS	<b>201705230597</b> <u><b>1002</b></u>	14	15	ug/L	0.5

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data

**Report:** 661841  
**Project:** GANADO-USD  
**Group:** Ganado Intermediate School

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
05/23/2017 1025

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
<b>1001 (201705230595)</b>						<b>Sampled on 05/18/2017 0535</b>			
Sample Type: Classroom Sink Facility ID: Building 100 Part 1 Sample Point ID: D-1 Classroom #13									
<b>EPA 200.8 - ICPMS Metals</b>									
05/24/17	05/28/17 11:10	997275	998555	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1001 (201705230596)</b>						<b>Sampled on 05/18/2017 0613</b>			
Sample Type: Classroom Facility ID: Building 100 Part 1 Sample Point ID: D-1 Classroom #13									
<b>EPA 200.8 - ICPMS Metals</b>									
05/24/17	05/28/17 11:14	997275	998555	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1002 (201705230597)</b>						<b>Sampled on 05/18/2017 0542</b>			
Sample Type: Classroom Sink Facility ID: Building 100 Part 2 Sample Point ID: E1 E40-0									
<b>EPA 200.8 - ICPMS Metals</b>									
05/24/17	05/28/17 11:14	997275	998555	(EPA 200.8)	Lead Total ICAP/MS	14	ug/L	0.5	1
<b>1003 (201705230598)</b>						<b>Sampled on 05/18/2017 0552</b>			
Sample Type: Kitchen Sink Facility ID: Kitchen Addition Sample Point ID: Intermediate Discharge Sink F									
<b>EPA 200.8 - ICPMS Metals</b>									
05/24/17	05/28/17 11:15	997275	998555	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

**Laboratory QC Summary**

**Report:** 661841  
**Project:** GANADO-USD  
**Group:** Ganado Intermediate School

Arizona Department of Environmental Quality

---

**ICPMS Metals**

**Prep Batch: 997275   Analytical Batch: 998555**

201705230595	1001
201705230596	1001
201705230597	1002
201705230598	1003

**Analysis Date: 05/28/2017**

Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

**Report:** 661841  
**Project:** GANADO-USD  
**Group:** Ganado Intermediate School

Arizona Department of Environmental Quality

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield (%)	Limits (%)	RPDLimit (%)	RPD%
<b>ICPMS Metals by EPA 200.8</b>									
<b>Analytical Batch: 998555</b>					<b>Analysis Date: 05/28/2017</b>				
LCS1	Lead Total ICAP/MS		20	19.5	ug/L	98	(85-115)		
LCS2	Lead Total ICAP/MS		20	19.5	ug/L	98	(85-115)	20	0.0
MBLK	Lead Total ICAP/MS			<0.25	ug/L				
MRL_CHK	Lead Total ICAP/MS		0.5	0.548	ug/L	110	(50-150)		
MS_201705230595	Lead Total ICAP/MS	ND	20	21.1	ug/L	106	(70-130)		
MS2_201705230613	Lead Total ICAP/MS	1.6	20	22.5	ug/L	105	(70-130)		
MSD_201705230595	Lead Total ICAP/MS	ND	20	21.0	ug/L	105	(70-130)	20	0.48
MSD2_201705230613	Lead Total ICAP/MS	1.6	20	22.2	ug/L	103	(70-130)	20	1.3

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.