

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Phoenix

4625 East Cotton Ctr Blvd

Suite 189

Phoenix, AZ 85040

Tel: (602)437-3340

TestAmerica Job ID: 550-80810-1

TestAmerica SDG: Taylor Hicks Elementary School

Client Project/Site: Pb in DW/Prescott Unified District

For:

Arizona Dept of Environmental Quality

1110 W. Washington St., MC5415B-1

Phoenix, Arizona 85007

Attn: David A Burchard



Authorized for release by:

4/24/2017 4:16:23 PM

Jannel Franklin, Project Manager I

(732)593-2551

jannel.franklin@testamericainc.com

Designee for

Susan Armijo, Project Manager II

(602)659-7664

susan.armijo@testamericainc.com

LINKS

Review your project
results through

TotalAccess

Have a Question?



Visit us at:

www.testamericainc.com

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Table of Contents

Cover Page	1
Table of Contents	2
Definitions/Glossary	3
Case Narrative	4
Sample Summary	5
Detection Summary	6
Client Sample Results	8
QC Sample Results	11
QC Association Summary	13
Lab Chronicle	15
Certification Summary	18
Method Summary	19
Chain of Custody	20
Receipt Checklists	37



Definitions/Glossary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Case Narrative

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Job ID: 550-80810-1

Laboratory: TestAmerica Phoenix

Narrative

Job Narrative 550-80810-1

Comments

No additional comments.

Receipt

The samples were received on 4/11/2017 10:10 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 21.0° C.

Receipt Exceptions

The following samples for metals were received unpreserved and were preserved upon receipt to the laboratory: 1001-Main (550-80810-1), 1001-Main (550-80810-2), 1002-104 (550-80810-3), 1002-104 (550-80810-4), 1003-108 (550-80810-5), 1003-109 (550-80810-6), 1004-107 (550-80810-7), 1004-107 (550-80810-8), 1011-Port (550-80810-9), 1005-106 (550-80810-10), 1005-106 (550-80810-11), 1006-105 (550-80810-12), 1006-105 (550-80810-13), 1007-MPR (550-80810-14), 1009-1009 (550-80810-15) and 10110-8 (550-80810-16). Regulatory documents require a 24-hour waiting period from the time of the addition of the acid preservative to the time of digestion.

Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Sample Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
550-80810-1	1001-Main	Drinking Water	04/10/17 08:20	04/11/17 10:10
550-80810-2	1001-Main	Drinking Water	04/10/17 08:20	04/11/17 10:10
550-80810-3	1002-104	Drinking Water	04/10/17 08:22	04/11/17 10:10
550-80810-4	1002-104	Drinking Water	04/10/17 08:24	04/11/17 10:10
550-80810-5	1003-108	Drinking Water	04/10/17 08:26	04/11/17 10:10
550-80810-6	1003-109	Drinking Water	04/10/17 08:27	04/11/17 10:10
550-80810-7	1004-107	Drinking Water	04/10/17 08:28	04/11/17 10:10
550-80810-8	1004-107	Drinking Water	04/10/17 08:29	04/11/17 10:10
550-80810-9	1011-Port	Drinking Water	04/10/17 08:45	04/11/17 10:10
550-80810-10	1005-106	Drinking Water	04/10/17 08:31	04/11/17 10:10
550-80810-11	1005-106	Drinking Water	04/10/17 08:30	04/11/17 10:10
550-80810-12	1006-105	Drinking Water	04/10/17 08:35	04/11/17 10:10
550-80810-13	1006-105	Drinking Water	04/10/17 08:33	04/11/17 10:10
550-80810-14	1007-MPR	Drinking Water	04/10/17 08:38	04/11/17 10:10
550-80810-15	1009-1009	Drinking Water	04/10/17 08:40	04/11/17 10:10
550-80810-16	10110-8	Drinking Water	04/10/17 08:42	04/11/17 10:10

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Client Sample ID: 1001-Main

Lab Sample ID: 550-80810-1

☐ No Detections.

Client Sample ID: 1001-Main

Lab Sample ID: 550-80810-2

☐ No Detections.

Client Sample ID: 1002-104

Lab Sample ID: 550-80810-3

☐ No Detections.

Client Sample ID: 1002-104

Lab Sample ID: 550-80810-4

☐ No Detections.

Client Sample ID: 1003-108

Lab Sample ID: 550-80810-5

☐ No Detections.

Client Sample ID: 1003-109

Lab Sample ID: 550-80810-6

☐ No Detections.

Client Sample ID: 1004-107

Lab Sample ID: 550-80810-7

☐ No Detections.

Client Sample ID: 1004-107

Lab Sample ID: 550-80810-8

☐ No Detections.

Client Sample ID: 1011-Port

Lab Sample ID: 550-80810-9

☐ No Detections.

Client Sample ID: 1005-106

Lab Sample ID: 550-80810-10

☐ No Detections.

Client Sample ID: 1005-106

Lab Sample ID: 550-80810-11

☐ No Detections.

Client Sample ID: 1006-105

Lab Sample ID: 550-80810-12

☐ No Detections.

Client Sample ID: 1006-105

Lab Sample ID: 550-80810-13

☐ No Detections.

Client Sample ID: 1007-MPR

Lab Sample ID: 550-80810-14

☐ No Detections.

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Client Sample ID: 1009-1009

Lab Sample ID: 550-80810-15

☐ No Detections.

Client Sample ID: 10110-8

Lab Sample ID: 550-80810-16

☐ No Detections.

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Client Sample ID: 1001-Main

Date Collected: 04/10/17 08:20

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-1

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:01	1

Client Sample ID: 1001-Main

Date Collected: 04/10/17 08:20

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-2

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:03	1

Client Sample ID: 1002-104

Date Collected: 04/10/17 08:22

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-3

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:05	1

Client Sample ID: 1002-104

Date Collected: 04/10/17 08:24

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-4

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:07	1

Client Sample ID: 1003-108

Date Collected: 04/10/17 08:26

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-5

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:09	1

Client Sample ID: 1003-109

Date Collected: 04/10/17 08:27

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-6

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:15	1

Client Sample ID: 1004-107

Date Collected: 04/10/17 08:28

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-7

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:17	1

TestAmerica Phoenix

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Client Sample ID: 1004-107

Date Collected: 04/10/17 08:29

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-8

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:19	1

Client Sample ID: 1011-Port

Date Collected: 04/10/17 08:45

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-9

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:21	1

Client Sample ID: 1005-106

Date Collected: 04/10/17 08:31

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-10

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:23	1

Client Sample ID: 1005-106

Date Collected: 04/10/17 08:30

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-11

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:24	1

Client Sample ID: 1006-105

Date Collected: 04/10/17 08:35

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-12

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:26	1

Client Sample ID: 1006-105

Date Collected: 04/10/17 08:33

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-13

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:28	1

Client Sample ID: 1007-MPR

Date Collected: 04/10/17 08:38

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-14

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:30	1

TestAmerica Phoenix

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Client Sample ID: 1009-1009

Date Collected: 04/10/17 08:40

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-15

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 12:32	1

Client Sample ID: 10110-8

Date Collected: 04/10/17 08:42

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-16

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:35	04/22/17 21:02	1

QC Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 550-114886/1-A
Matrix: Water
Analysis Batch: 115530

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 114886

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:30	04/23/17 11:41	1

Lab Sample ID: LCS 550-114886/3-A
Matrix: Water
Analysis Batch: 115530

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 114886

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	94.7		ppb		95	85 - 115

Lab Sample ID: LCSD 550-114886/4-A
Matrix: Water
Analysis Batch: 115530

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 114886

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	100	96.5		ppb		96	85 - 115	2	20

Lab Sample ID: 550-80805-A-10-B MS
Matrix: Water
Analysis Batch: 115530

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 114886

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	1.1		100	93.7		ppb		93	70 - 130

Lab Sample ID: 550-80805-A-10-C MSD
Matrix: Water
Analysis Batch: 115530

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 114886

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	1.1		100	93.0		ppb		92	70 - 130	1	20

Lab Sample ID: MB 550-114887/1-A
Matrix: Water
Analysis Batch: 115523

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 114887

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		04/14/17 06:35	04/22/17 20:55	1

Lab Sample ID: LCS 550-114887/3-A
Matrix: Water
Analysis Batch: 115523

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 114887

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	85.5		ppb		85	85 - 115

Lab Sample ID: LCSD 550-114887/4-A
Matrix: Water
Analysis Batch: 115523

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 114887

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	100	85.9		ppb		86	85 - 115	1	20

TestAmerica Phoenix

QC Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Lab Sample ID: 550-80810-16 MS

Matrix: Drinking Water

Analysis Batch: 115523

Client Sample ID: 10110-8

Prep Type: Total/NA

Prep Batch: 114887

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	ND		100	81.2		ppb		81	70 - 130

Lab Sample ID: 550-80810-16 MSD

Matrix: Drinking Water

Analysis Batch: 115523

Client Sample ID: 10110-8

Prep Type: Total/NA

Prep Batch: 114887

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	ND		100	81.3		ppb		81	70 - 130	0	20

QC Association Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Metals

Prep Batch: 114886

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80810-1	1001-Main	Total/NA	Drinking Water	200.8	
550-80810-2	1001-Main	Total/NA	Drinking Water	200.8	
550-80810-3	1002-104	Total/NA	Drinking Water	200.8	
550-80810-4	1002-104	Total/NA	Drinking Water	200.8	
550-80810-5	1003-108	Total/NA	Drinking Water	200.8	
550-80810-6	1003-109	Total/NA	Drinking Water	200.8	
550-80810-7	1004-107	Total/NA	Drinking Water	200.8	
550-80810-8	1004-107	Total/NA	Drinking Water	200.8	
550-80810-9	1011-Port	Total/NA	Drinking Water	200.8	
550-80810-10	1005-106	Total/NA	Drinking Water	200.8	
550-80810-11	1005-106	Total/NA	Drinking Water	200.8	
550-80810-12	1006-105	Total/NA	Drinking Water	200.8	
550-80810-13	1006-105	Total/NA	Drinking Water	200.8	
550-80810-14	1007-MPR	Total/NA	Drinking Water	200.8	
550-80810-15	1009-1009	Total/NA	Drinking Water	200.8	
MB 550-114886/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-114886/3-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-114886/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-80805-A-10-B MS	Matrix Spike	Total/NA	Water	200.8	
550-80805-A-10-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

Prep Batch: 114887

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80810-16	10110-8	Total/NA	Drinking Water	200.8	
MB 550-114887/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-114887/3-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-114887/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-80810-16 MS	10110-8	Total/NA	Drinking Water	200.8	
550-80810-16 MSD	10110-8	Total/NA	Drinking Water	200.8	

Analysis Batch: 115523

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80810-16	10110-8	Total/NA	Drinking Water	200.8	114887
MB 550-114887/1-A	Method Blank	Total/NA	Water	200.8	114887
LCS 550-114887/3-A	Lab Control Sample	Total/NA	Water	200.8	114887
LCSD 550-114887/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	114887
550-80810-16 MS	10110-8	Total/NA	Drinking Water	200.8	114887
550-80810-16 MSD	10110-8	Total/NA	Drinking Water	200.8	114887

Analysis Batch: 115530

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80810-1	1001-Main	Total/NA	Drinking Water	200.8	114886
550-80810-2	1001-Main	Total/NA	Drinking Water	200.8	114886
550-80810-3	1002-104	Total/NA	Drinking Water	200.8	114886
550-80810-4	1002-104	Total/NA	Drinking Water	200.8	114886
550-80810-5	1003-108	Total/NA	Drinking Water	200.8	114886
550-80810-6	1003-109	Total/NA	Drinking Water	200.8	114886
550-80810-7	1004-107	Total/NA	Drinking Water	200.8	114886
550-80810-8	1004-107	Total/NA	Drinking Water	200.8	114886
550-80810-9	1011-Port	Total/NA	Drinking Water	200.8	114886
550-80810-10	1005-106	Total/NA	Drinking Water	200.8	114886

TestAmerica Phoenix

QC Association Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Metals (Continued)

Analysis Batch: 115530 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-80810-11	1005-106	Total/NA	Drinking Water	200.8	114886
550-80810-12	1006-105	Total/NA	Drinking Water	200.8	114886
550-80810-13	1006-105	Total/NA	Drinking Water	200.8	114886
550-80810-14	1007-MPR	Total/NA	Drinking Water	200.8	114886
550-80810-15	1009-1009	Total/NA	Drinking Water	200.8	114886
MB 550-114886/1-A	Method Blank	Total/NA	Water	200.8	114886
LCS 550-114886/3-A	Lab Control Sample	Total/NA	Water	200.8	114886
LCSD 550-114886/4-A	Lab Control Sample Dup	Total/NA	Water	200.8	114886
550-80805-A-10-B MS	Matrix Spike	Total/NA	Water	200.8	114886
550-80805-A-10-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	114886

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Client Sample ID: 1001-Main

Date Collected: 04/10/17 08:20

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-1

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:01	TEK	TAL PHX

Client Sample ID: 1001-Main

Date Collected: 04/10/17 08:20

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-2

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:03	TEK	TAL PHX

Client Sample ID: 1002-104

Date Collected: 04/10/17 08:22

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-3

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:05	TEK	TAL PHX

Client Sample ID: 1002-104

Date Collected: 04/10/17 08:24

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-4

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:07	TEK	TAL PHX

Client Sample ID: 1003-108

Date Collected: 04/10/17 08:26

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-5

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:09	TEK	TAL PHX

Client Sample ID: 1003-109

Date Collected: 04/10/17 08:27

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-6

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:15	TEK	TAL PHX

TestAmerica Phoenix

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Client Sample ID: 1004-107

Date Collected: 04/10/17 08:28

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-7

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:17	TEK	TAL PHX

Client Sample ID: 1004-107

Date Collected: 04/10/17 08:29

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-8

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:19	TEK	TAL PHX

Client Sample ID: 1011-Port

Date Collected: 04/10/17 08:45

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-9

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:21	TEK	TAL PHX

Client Sample ID: 1005-106

Date Collected: 04/10/17 08:31

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-10

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:23	TEK	TAL PHX

Client Sample ID: 1005-106

Date Collected: 04/10/17 08:30

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-11

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:24	TEK	TAL PHX

Client Sample ID: 1006-105

Date Collected: 04/10/17 08:35

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-12

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:26	TEK	TAL PHX

TestAmerica Phoenix

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Client Sample ID: 1006-105

Date Collected: 04/10/17 08:33

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-13

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:28	TEK	TAL PHX

Client Sample ID: 1007-MPR

Date Collected: 04/10/17 08:38

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-14

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:30	TEK	TAL PHX

Client Sample ID: 1009-1009

Date Collected: 04/10/17 08:40

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-15

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114886	04/14/17 06:30	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115530	04/23/17 12:32	TEK	TAL PHX

Client Sample ID: 10110-8

Date Collected: 04/10/17 08:42

Date Received: 04/11/17 10:10

Lab Sample ID: 550-80810-16

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			114887	04/14/17 06:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	115523	04/22/17 21:02	TEK	TAL PHX

Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

Accreditation/Certification Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Laboratory: TestAmerica Phoenix

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	EPA Region	Identification Number	Expiration Date
Arizona	State Program	9	AZ0728	06-09-17

Analysis Method	Prep Method	Matrix	Analyte
-----------------	-------------	--------	---------

Method Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Prescott Unified District

TestAmerica Job ID: 550-80810-1
SDG: Taylor Hicks Elementary School

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	TAL PHX

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340


80810

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.


- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	D430
School Name	RYAN NICKS
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	
Sample Identification Number (Write this number on the sample container and on this sheet)	1001- MAIN
Date of Collection	4.10.17
Time of Collection	0820
Printed Name of Sample Collector	ALONG
Signature Sample Collector	

550-80810 Chain of Custody



Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4-11-17 1010
Signature	
Notes: 210°C NO ZCB FE OR	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PLUSD
School Name	TH
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1001-MAIN
Date of Collection	4.10.17
Time of Collection	0820
Printed Name of Sample Collector	R Long
Signature Sample Collector	R J

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	D430
School Name	T.H.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1002-104
Date of Collection	4.10.17
Time of Collection	0822
Printed Name of Sample Collector	R Long
Signature Sample Collector	RJ

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	P430
School Name	T.N.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1002-104
Date of Collection	4/10/17
Time of Collection	0824
Printed Name of Sample Collector	R LONG
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	P430
School Name	T.N.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1003-108
Date of Collection	4.10.17
Time of Collection	0826
Printed Name of Sample Collector	RLONG
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	P430
School Name	T.N.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1003-109
Date of Collection	4.10.17
Time of Collection	0827
Printed Name of Sample Collector	R Long
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	P43.D
School Name	T.N.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1004-107
Date of Collection	4.10.17
Time of Collection	0828
Printed Name of Sample Collector	R Long
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	D430
School Name	T.N.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1004-107
Date of Collection	4.10.17
Time of Collection	0829
Printed Name of Sample Collector	R Long
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	D430
School Name	T.N.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINK FOUNTAIN
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1005-106
Date of Collection	4/10/17
Time of Collection	0831
Printed Name of Sample Collector	R Long
Signature Sample Collector	R Long

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	P430
School Name	T.H.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1005-106
Date of Collection	4.10.17
Time of Collection	0830
Printed Name of Sample Collector	R Long
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PE130
School Name	T.H.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINK FOUNT
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1006-105
Date of Collection	4.10.17
Time of Collection	0835
Printed Name of Sample Collector	R Long
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	P430
School Name	T.H.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1006-105
Date of Collection	4.10.17
Time of Collection	0833
Printed Name of Sample Collector	R. Long
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	D430
School Name	T.N.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINK FOUNT
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1007- MPR
Date of Collection	4.10.17
Time of Collection	0838
Printed Name of Sample Collector	R Long
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	P430
School Name	T.H.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-1009
Date of Collection	4.10.17
Time of Collection	0840
Printed Name of Sample Collector	R Long
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	<u>P430</u>
School Name	<u>T.H.</u>
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	<u>DRINK FOUNT</u>
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	<u>10110-8</u>
Date of Collection	<u>4.10.17</u>
Time of Collection	<u>0842</u>
Printed Name of Sample Collector	<u>R Long</u>
Signature Sample Collector	<u>[Signature]</u>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	P430
School Name	T.H.
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	1011- Port
Date of Collection	4.10.17
Time of Collection	0845
Printed Name of Sample Collector	R Long
Signature Sample Collector	R Long

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Prescott Unified District	Taylor Hicks Elementary School	1001	820 AM Main Building	Classrooms	1963	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1002	822 AM Rooms 10-104 824 AM	Classrooms	1963	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1003	826 / 827 Rooms 108-109	Classrooms	1963	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1004	828 / 829 AM Room 107	Classroom	1963	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1005	830 / 831 AM Room 106	Classrooms	1963	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1006	833 / 835 AM Room 105	Classrooms	1963	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1007	838 AM Multipurpose Bldg	Gym, Art, Music	2007	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1009	840 AM 1009	Classrooms	2008	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1010	842 AM 8 Classroom addition	Classrooms	2008	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Prescott Unified District	Taylor Hicks Elementary School	1011	845 AM Leased Portable	Classrooms	2006	1845 Campbell Ave	Prescott	86301-1211	Yavapai
Total Containers									

Prescott Unified District ATTN: Joe Howard 146 S Granite St, Prescott, AZ 86303

2 ✓
2 ✓
2 ✓
2 ✓
2 ✓
2 ✓
1 ✓
1 ✓
1 ✓
1 ✓
16

Login Sample Receipt Checklist

Client: Arizona Dept of Environmental Quality

Job Number: 550-80810-1

SDG Number: Taylor Hicks Elementary School

Login Number: 80810

List Number: 1

Creator: Doerr, Bret C

List Source: TestAmerica Phoenix

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	Check done at department level as required.