TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.
TestAmerica Phoenix
4625 East Cotton Ctr Blvd
Suite 189
Phoenix, AZ 85040
Tel: (602)437-3340

TestAmerica Job ID: 550-79266-1
TestAmerica SDG: Bagdad Elementary & H.S.
Client Project/Site: Pb in DW / Bagdad Unified District

For:
Arizona Dept of Environmental Quality
1110 W. Washington St., MC5415B-1
Phoenix, Arizona 85007

Attn: David A Burchard

Authorized for release by:
3/28/2017 12:03:51 PM

Susan Armijo, Project Manager II
(602)659-7664
susan.armijo@testamericainc.com

LINKS

Review your project results through TotalAccess

Have a Question? Ask The Expert

Visit us at: www.testamericainc.com

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Table of Contents

Cover Page 1
Table of Contents 2
Definitions/Glossary 3
Case Narrative 4
Sample Summary 5
Detection Summary 6
Client Sample Results 8
QC Sample Results 11
QC Association Summary 13
Lab Chronicle 15
Certification Summary 18
Method Summary 19
Chain of Custody 20
Receipt Checklists 39

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
¤	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Job ID: 550-79266-1

Laboratory: TestAmerica Phoenix

Narrative

Job Narrative
550-79266-1

Comments
No additional comments.

Receipt
The samples were received on 3/15/2017 11:00 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 19.8º C.

Receipt Exceptions
The following samples for metals were received unpreserved and were preserved upon receipt to the laboratory: Bldg-200-1 (550-79266-1), Bldg-200-2 (550-79266-2), Bldg-200 Phase II (550-79266-3), Bldg-100-1 (550-79266-4), Bldg-100-2 (550-79266-5), Bldg-100-1 Phase II (550-79266-6), Bldg-100-2 Phase II (550-79266-7), Bldg-300-1 (550-79266-8), Bldg-300-2 (550-79266-9), Bldg-600-1 (550-79266-10), Bldg-600-2 (550-79266-11), Bldg-700 (550-79266-12), Bldg-400 (550-79266-13), Bldg-500 (550-79266-14), Bldg-800-1 (550-79266-15), Bldg-800-2 (550-79266-16), Modular Classroom (550-79266-17), Bldg-900 (550-79266-18) and Bldg-900 from other campus (550-79266-19). Regulatory documents require a 24-hour waiting period from the time of the addition of the acid preservative to the time of digestion.

The containers for samples 17-19 were received empty due to a lack of water at those sampling sites according to the information noted on the sampling forms.
Modular Classroom (550-79266-17), Bldg-900 (550-79266-18) and Bldg-900 from other campus (550-79266-19)

Metals
No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Sample Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
550-79266-1	Bldg-200-1	Drinking Water	03/13/17 07:30	03/15/17 11:00
550-79266-2	Bldg-200-2	Drinking Water	03/13/17 07:34	03/15/17 11:00
550-79266-3	Bldg-200 Phase II	Drinking Water	03/13/17 07:45	03/15/17 11:00
550-79266-4	Bldg-100-1	Drinking Water	03/13/17 07:43	03/15/17 11:00
550-79266-5	Bldg-100-2	Drinking Water	03/13/17 07:45	03/15/17 11:00
550-79266-6	Bldg-100-1 Phase II	Drinking Water	03/13/17 07:50	03/15/17 11:00
550-79266-7	Bldg-100-2 Phase II	Drinking Water	03/13/17 07:51	03/15/17 11:00
550-79266-8	Bldg-300-1	Drinking Water	03/13/17 07:55	03/15/17 11:00
550-79266-9	Bldg-300-2	Drinking Water	03/13/17 07:55	03/15/17 11:00
550-79266-10	Bldg-600-1	Drinking Water	03/13/17 08:00	03/15/17 11:00
550-79266-11	Bldg-600-2	Drinking Water	03/13/17 08:00	03/15/17 11:00
550-79266-12	Bldg-700	Drinking Water	03/13/17 08:04	03/15/17 11:00
550-79266-13	Bldg-400	Drinking Water	03/13/17 08:09	03/15/17 11:00
550-79266-14	Bldg-500	Drinking Water	03/13/17 08:12	03/15/17 11:00
550-79266-15	Bldg-800-1	Drinking Water	03/13/17 08:56	03/15/17 11:00
550-79266-16	Bldg-800-2	Drinking Water	03/13/17 08:55	03/15/17 11:00

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Client Sample ID: Bldg-200-1 — Lab Sample ID: 550-79266-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	69		0.50	ppb	1		200.8	Total/NA

Client Sample ID: Bldg-200-2 — Lab Sample ID: 550-79266-2

No Detections.

Client Sample ID: Bldg-200 Phase II — Lab Sample ID: 550-79266-3

No Detections.

Client Sample ID: Bldg-100-1 — Lab Sample ID: 550-79266-4

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.80		0.50	ppb	1		200.8	Total/NA

Client Sample ID: Bldg-100-2 — Lab Sample ID: 550-79266-5

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50	ppb	1		200.8	Total/NA

Client Sample ID: Bldg-100-1 Phase II — Lab Sample ID: 550-79266-6

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.0		0.50	ppb	1		200.8	Total/NA

Client Sample ID: Bldg-100-2 Phase II — Lab Sample ID: 550-79266-7

No Detections.

Client Sample ID: Bldg-300-1 — Lab Sample ID: 550-79266-8

No Detections.

Client Sample ID: Bldg-300-2 — Lab Sample ID: 550-79266-9

No Detections.

Client Sample ID: Bldg-600-1 — Lab Sample ID: 550-79266-10

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50	ppb	1		200.8	Total/NA

Client Sample ID: Bldg-600-2 — Lab Sample ID: 550-79266-11

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.53		0.50	ppb	1		200.8	Total/NA

Client Sample ID: Bldg-700 — Lab Sample ID: 550-79266-12

No Detections.

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Client Sample ID: Bldg-400 — Lab Sample ID: 550-79266-13

No Detections.

Client Sample ID: Bldg-500 — Lab Sample ID: 550-79266-14

No Detections.

Client Sample ID: Bldg-800-1 — Lab Sample ID: 550-79266-15

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ppb	1		200.8	Total/NA

Client Sample ID: Bldg-800-2 — Lab Sample ID: 550-79266-16

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Lead	15		0.50		ppb	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Client Sample ID: Bldg-200-1
Lab Sample ID: 550-79266-1
Date Collected: 03/13/17 07:30
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	69		0.50		ppb		03/22/17 07:09	03/22/17 11:45	1

Client Sample ID: Bldg-200-2
Lab Sample ID: 550-79266-2
Date Collected: 03/13/17 07:34
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 11:47	1

Client Sample ID: Bldg-200 Phase II
Lab Sample ID: 550-79266-3
Date Collected: 03/13/17 07:45
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 11:49	1

Client Sample ID: Bldg-100-1
Lab Sample ID: 550-79266-4
Date Collected: 03/13/17 07:43
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.80		0.50		ppb		03/22/17 07:09	03/22/17 11:51	1

Client Sample ID: Bldg-100-2
Lab Sample ID: 550-79266-5
Date Collected: 03/13/17 07:45
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ppb		03/22/17 07:09	03/22/17 11:53	1

Client Sample ID: Bldg-100-1 Phase II
Lab Sample ID: 550-79266-6
Date Collected: 03/13/17 07:50
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		0.50		ppb		03/22/17 07:09	03/22/17 11:58	1

Client Sample ID: Bldg-100-2 Phase II
Lab Sample ID: 550-79266-7
Date Collected: 03/13/17 07:51
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 12:00	1

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Client Sample ID: Bldg-300-1
Lab Sample ID: 550-79266-8
Date Collected: 03/13/17 07:55
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 12:02	1

Client Sample ID: Bldg-300-2
Lab Sample ID: 550-79266-9
Date Collected: 03/13/17 07:55
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 12:04	1

Client Sample ID: Bldg-600-1
Lab Sample ID: 550-79266-10
Date Collected: 03/13/17 08:00
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.7**		0.50		ppb		03/22/17 07:09	03/22/17 12:06	1

Client Sample ID: Bldg-600-2
Lab Sample ID: 550-79266-11
Date Collected: 03/13/17 08:00
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.53**		0.50		ppb		03/22/17 07:09	03/22/17 12:08	1

Client Sample ID: Bldg-700
Lab Sample ID: 550-79266-12
Date Collected: 03/13/17 08:04
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 12:10	1

Client Sample ID: Bldg-400
Lab Sample ID: 550-79266-13
Date Collected: 03/13/17 08:09
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 12:12	1

Client Sample ID: Bldg-500
Lab Sample ID: 550-79266-14
Date Collected: 03/13/17 08:12
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 12:14	1

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Client Sample ID: Bldg-800-1

Lab Sample ID: 550-79266-15

Date Collected: 03/13/17 08:56
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ppb		03/22/17 07:09	03/22/17 12:16	1

Client Sample ID: Bldg-800-2

Lab Sample ID: 550-79266-16

Date Collected: 03/13/17 08:55
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	15		0.50		ppb		03/22/17 07:28	03/25/17 09:11	1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 550-112932/1-A — **Client Sample ID: Method Blank**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 112977 — **Prep Batch: 112932**

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:09	03/22/17 11:22	1

Lab Sample ID: LCS 550-112932/4-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 112977 — **Prep Batch: 112932**

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits		
Lead			100	92.6		ppb		93	85 - 115		

Lab Sample ID: LCSD 550-112932/5-A — **Client Sample ID: Lab Control Sample Dup**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 112977 — **Prep Batch: 112932**

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Lead			100	93.3		ppb		93	85 - 115	1	20

Lab Sample ID: 550-79105-A-11-B MS — **Client Sample ID: Matrix Spike**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 112977 — **Prep Batch: 112932**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits		
Lead	0.82		100	87.8		ppb		87	70 - 130		

Lab Sample ID: 550-79105-A-11-C MSD — **Client Sample ID: Matrix Spike Duplicate**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 112977 — **Prep Batch: 112932**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Lead	0.82		100	87.7		ppb		87	70 - 130	0	20

Lab Sample ID: MB 550-112933/1-A — **Client Sample ID: Method Blank**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 113239 — **Prep Batch: 112933**

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50		ppb		03/22/17 07:28	03/25/17 09:02	1

Lab Sample ID: LCS 550-112933/4-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 113239 — **Prep Batch: 112933**

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits		
Lead			100	94.6		ppb		95	85 - 115		

Lab Sample ID: LCSD 550-112933/5-A — **Client Sample ID: Lab Control Sample Dup**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 113239 — **Prep Batch: 112933**

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Lead			100	96.3		ppb		96	85 - 115	2	20

QC Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Lab Sample ID: 550-79266-16 MS
Matrix: Drinking Water
Analysis Batch: 113239

Client Sample ID: Bldg-800-2
Prep Type: Total/NA
Prep Batch: 112933

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits		
Lead	15		100	103		ppb		88	70 - 130		

Lab Sample ID: 550-79266-16 MSD
Matrix: Drinking Water
Analysis Batch: 113239

Client Sample ID: Bldg-800-2
Prep Type: Total/NA
Prep Batch: 112933

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Lead	15		100	101		ppb		86	70 - 130	2	20

QC Association Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Metals

Prep Batch: 112932

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79266-1	Bldg-200-1	Total/NA	Drinking Water	200.8	
550-79266-2	Bldg-200-2	Total/NA	Drinking Water	200.8	
550-79266-3	Bldg-200 Phase II	Total/NA	Drinking Water	200.8	
550-79266-4	Bldg-100-1	Total/NA	Drinking Water	200.8	
550-79266-5	Bldg-100-2	Total/NA	Drinking Water	200.8	
550-79266-6	Bldg-100-1 Phase II	Total/NA	Drinking Water	200.8	
550-79266-7	Bldg-100-2 Phase II	Total/NA	Drinking Water	200.8	
550-79266-8	Bldg-300-1	Total/NA	Drinking Water	200.8	
550-79266-9	Bldg-300-2	Total/NA	Drinking Water	200.8	
550-79266-10	Bldg-600-1	Total/NA	Drinking Water	200.8	
550-79266-11	Bldg-600-2	Total/NA	Drinking Water	200.8	
550-79266-12	Bldg-700	Total/NA	Drinking Water	200.8	
550-79266-13	Bldg-400	Total/NA	Drinking Water	200.8	
550-79266-14	Bldg-500	Total/NA	Drinking Water	200.8	
550-79266-15	Bldg-800-1	Total/NA	Drinking Water	200.8	
MB 550-112932/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-112932/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-112932/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-79105-A-11-B MS	Matrix Spike	Total/NA	Water	200.8	
550-79105-A-11-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

Prep Batch: 112933

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79266-16	Bldg-800-2	Total/NA	Drinking Water	200.8	
MB 550-112933/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-112933/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-112933/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-79266-16 MS	Bldg-800-2	Total/NA	Drinking Water	200.8	
550-79266-16 MSD	Bldg-800-2	Total/NA	Drinking Water	200.8	

Analysis Batch: 112977

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79266-1	Bldg-200-1	Total/NA	Drinking Water	200.8	112932
550-79266-2	Bldg-200-2	Total/NA	Drinking Water	200.8	112932
550-79266-3	Bldg-200 Phase II	Total/NA	Drinking Water	200.8	112932
550-79266-4	Bldg-100-1	Total/NA	Drinking Water	200.8	112932
550-79266-5	Bldg-100-2	Total/NA	Drinking Water	200.8	112932
550-79266-6	Bldg-100-1 Phase II	Total/NA	Drinking Water	200.8	112932
550-79266-7	Bldg-100-2 Phase II	Total/NA	Drinking Water	200.8	112932
550-79266-8	Bldg-300-1	Total/NA	Drinking Water	200.8	112932
550-79266-9	Bldg-300-2	Total/NA	Drinking Water	200.8	112932
550-79266-10	Bldg-600-1	Total/NA	Drinking Water	200.8	112932
550-79266-11	Bldg-600-2	Total/NA	Drinking Water	200.8	112932
550-79266-12	Bldg-700	Total/NA	Drinking Water	200.8	112932
550-79266-13	Bldg-400	Total/NA	Drinking Water	200.8	112932
550-79266-14	Bldg-500	Total/NA	Drinking Water	200.8	112932
550-79266-15	Bldg-800-1	Total/NA	Drinking Water	200.8	112932
MB 550-112932/1-A	Method Blank	Total/NA	Water	200.8	112932
LCS 550-112932/4-A	Lab Control Sample	Total/NA	Water	200.8	112932
LCSD 550-112932/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	112932
550-79105-A-11-B MS	Matrix Spike	Total/NA	Water	200.8	112932

Metals (Continued)

Analysis Batch: 112977 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79105-A-11-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	112932

Analysis Batch: 113239

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79266-16	Bldg-800-2	Total/NA	Drinking Water	200.8	112933
MB 550-112933/1-A	Method Blank	Total/NA	Water	200.8	112933
LCS 550-112933/4-A	Lab Control Sample	Total/NA	Water	200.8	112933
LCSD 550-112933/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	112933
550-79266-16 MS	Bldg-800-2	Total/NA	Drinking Water	200.8	112933
550-79266-16 MSD	Bldg-800-2	Total/NA	Drinking Water	200.8	112933

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Client Sample ID: Bldg-200-1 — Lab Sample ID: 550-79266-1

Date Collected: 03/13/17 07:30 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 11:45	TEK	TAL PHX

Client Sample ID: Bldg-200-2 — Lab Sample ID: 550-79266-2

Date Collected: 03/13/17 07:34 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 11:47	TEK	TAL PHX

Client Sample ID: Bldg-200 Phase II — Lab Sample ID: 550-79266-3

Date Collected: 03/13/17 07:45 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 11:49	TEK	TAL PHX

Client Sample ID: Bldg-100-1 — Lab Sample ID: 550-79266-4

Date Collected: 03/13/17 07:43 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 11:51	TEK	TAL PHX

Client Sample ID: Bldg-100-2 — Lab Sample ID: 550-79266-5

Date Collected: 03/13/17 07:45 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 11:53	TEK	TAL PHX

Client Sample ID: Bldg-100-1 Phase II — Lab Sample ID: 550-79266-6

Date Collected: 03/13/17 07:50 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 11:58	TEK	TAL PHX

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Client Sample ID: Bldg-100-2 Phase II — Lab Sample ID: 550-79266-7

Date Collected: 03/13/17 07:51 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:00	TEK	TAL PHX

Client Sample ID: Bldg-300-1 — Lab Sample ID: 550-79266-8

Date Collected: 03/13/17 07:55 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:02	TEK	TAL PHX

Client Sample ID: Bldg-300-2 — Lab Sample ID: 550-79266-9

Date Collected: 03/13/17 07:55 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:04	TEK	TAL PHX

Client Sample ID: Bldg-600-1 — Lab Sample ID: 550-79266-10

Date Collected: 03/13/17 08:00 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:06	TEK	TAL PHX

Client Sample ID: Bldg-600-2 — Lab Sample ID: 550-79266-11

Date Collected: 03/13/17 08:00 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:08	TEK	TAL PHX

Client Sample ID: Bldg-700 — Lab Sample ID: 550-79266-12

Date Collected: 03/13/17 08:04 — **Matrix: Drinking Water**
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:10	TEK	TAL PHX

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Client Sample ID: Bldg-400

Lab Sample ID: 550-79266-13
Date Collected: 03/13/17 08:09
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:12	TEK	TAL PHX

Client Sample ID: Bldg-500

Lab Sample ID: 550-79266-14
Date Collected: 03/13/17 08:12
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:14	TEK	TAL PHX

Client Sample ID: Bldg-800-1

Lab Sample ID: 550-79266-15
Date Collected: 03/13/17 08:56
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112932	03/22/17 07:09	SGO	TAL PHX
Total/NA	Analysis	200.8		1	112977	03/22/17 12:16	TEK	TAL PHX

Client Sample ID: Bldg-800-2

Lab Sample ID: 550-79266-16
Date Collected: 03/13/17 08:55
Matrix: Drinking Water
Date Received: 03/15/17 11:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			112933	03/22/17 07:28	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113239	03/25/17 09:11	TEK	TAL PHX

Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

Certification Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Laboratory: TestAmerica Phoenix

Unless otherwise noted, all analytes for this laboratory were covered under each certification below.

Authority	Program	EPA Region	Certification ID	Expiration Date
Arizona	State Program	9	AZ0728	06-09-17

Analysis Method	Prep Method	Matrix	Analyte

Method Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / Bagdad Unified District

TestAmerica Job ID: 550-79266-1
SDG: Bagdad Elementary & H.S.

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	TAL PHX

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

79266

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DISTRICT
School Name	BAGDAD ELEMENTARY
Building (name/number)	200
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	OLD ELEMENTARY OFFICE 213
Sample Identification Number (ensure this number is also on the sample container)	BLDG-200-1
Date of Collection	3-13-17
Time of Collection	7:30 AM
Printed Name of Sample Collector	STEVE REID
Signature Sample Collector	[signature]

550-79266 Chain of Custody

Notes Sample collector:
SAMPLE TAKEN FROM WATER SUPPLY LINE. FOUNTAIN HAS BEEN REMOVED

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	[signature]
Notes: 19.8°C	FE Cu

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

1

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DISTRICT
School Name	BAGDAD ELEMENTARY
Building (name/number)	200
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	HALL OUTSIDE OF LIBRARY
Sample Identification Number (ensure this number is also on the sample container)	RLDG-200-2
Date of Collection	3-13-17
Time of Collection	7:54 AM
Printed Name of Sample Collector	STEVEN REED
Signature Sample Collector	Steven Reed

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

(2)

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST.
School Name	BAGDAD ELEMENTARY
Building (name/number)	300 PHASE II
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	BY OUTSIDE BATHROOMS
Sample Identification Number (ensure this number is also on the sample container)	BLDG-300 PHASE II
Date of Collection	3-13-17
Time of Collection	7:45
Printed Name of Sample Collector	STEVEN READ
Signature Sample Collector	Steven Read

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

3

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DISTRICT
School Name	BAGDAD HIGH SCHOOL
Building (name/number)	100
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	OUTSIDE OF BATHROOMS
Sample Identification Number (ensure this number is also on the sample container)	BLDG-100-1
Date of Collection	3-13-17
Time of Collection	7:43 AM
Printed Name of Sample Collector	STEVEN [illegible]
Signature Sample Collector	[illegible]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	[illegible]
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

4

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST.
School Name	BAGDAD HIGH SCHOOL
Building (name/number)	100
Type of Fixture (tap, drinking fountain etc.)	BATHROOM SINK (HANDICAPED)
Location of Fixture (example, room number)	GIRLS BATHROOM
Sample Identification Number (ensure this number is also on the sample container)	BLDG-100-2
Date of Collection	3-13-17
Time of Collection	7:45 AM
Printed Name of Sample Collector	STEVEN READ
Signature Sample Collector	Steven Read

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

5

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST.
School Name	BAGDAD HIGH SCHOOL
Building (name/number)	100
Type of Fixture (tap, drinking fountain etc.)	BATHROOM SINK
Location of Fixture (example, room number)	STAFF BATHROOM LEFT HAND SINK
Sample Identification Number (ensure this number is also on the sample container)	BLDG-100-1 PHASE II
Date of Collection	3-13-17
Time of Collection	7:50 AM
Printed Name of Sample Collector	STEVEN READ
Signature Sample Collector	Steven Read

Notes Sample collector:
NO DRINKING FOUNTAINS IN THIS BUILDINGS

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

6

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST
School Name	BAGDAD HIGH SCHOOL
Building (name/number)	100
Type of Fixture (tap, drinking fountain etc.)	BATHROOM SINK
Location of Fixture (example, room number)	STAFF BATHROOM SINK #3
Sample Identification Number (ensure this number is also on the sample container)	BLDG-100-2 PHASE II
Date of Collection	3-13-17
Time of Collection	7:51 AM
Printed Name of Sample Collector	STEVE KEAD
Signature Sample Collector	[signature]

Notes Sample collector:
NO DRINKING FOUNTAINS IN THIS BUILDING

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1140
Signature	[signature]
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST.
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	300
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	AUDITORIUM
Sample Identification Number (ensure this number is also on the sample container)	BLDG-300-1
Date of Collection	3-13-17
Time of Collection	7:55 AM
Printed Name of Sample Collector	STEVE READ
Signature Sample Collector	Steve Read

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	300
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	AUDITORIUM
Sample Identification Number (ensure this number is also on the sample container)	RLDG-300-2
Date of Collection	3-13-17
Time of Collection	7:55 AM
Printed Name of Sample Collector	STEVE HEAD
Signature Sample Collector	Steve Head

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	2-15-17 11:00
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

9

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST
School Name	BAGDAD ELEMENTARY & H.S.
Building (name/number)	600
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	AUTO SHOP
Sample Identification Number (ensure this number is also on the sample container)	BLD6-600-1
Date of Collection	3-13-17
Time of Collection	8:00 AM
Printed Name of Sample Collector	STEVE READ
Signature Sample Collector	[signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	[signature]
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST.
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	600
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	WELDING SHOP
Sample Identification Number (ensure this number is also on the sample container)	BLDG-600-2
Date of Collection	3-13-17
Time of Collection	8:00
Printed Name of Sample Collector	STEVE BLEAD
Signature Sample Collector	[illegible]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1140
Signature	[illegible]
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

11

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST.
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	700
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	LOBBY
Sample Identification Number (ensure this number is also on the sample container)	BCDG-700
Date of Collection	3-13-17
Time of Collection	8:04
Printed Name of Sample Collector	STEVE REED
Signature Sample Collector	Steve Reed

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

12

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	400
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	HALL
Sample Identification Number (ensure this number is also on the sample container)	BLDG-400
Date of Collection	3-13-17
Time of Collection	8:09 AM
Printed Name of Sample Collector	STEVE REED
Signature Sample Collector	Steve Reed

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17, 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

13

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	500
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CAFETERIA
Sample Identification Number (ensure this number is also on the sample container)	BLDG-500
Date of Collection	3-13-17
Time of Collection	8:12 AM
Printed Name of Sample Collector	STEVE READ
Signature Sample Collector	Steve Read

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

14

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST
School Name	BAGDAD ELEMENTARY & H.S.
Building (name/number)	800
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	STEAM SINK
Sample Identification Number (ensure this number is also on the sample container)	BLDG-800-1
Date of Collection	3-13-17
Time of Collection	8:56
Printed Name of Sample Collector	STEVE READ
Signature Sample Collector	Steve Read

Notes Sample collector:
NO DRINKING WATER IN THIS BUILDING

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

(6)

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DISTRICT
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	800
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	GARAGE
Sample Identification Number (ensure this number is also on the sample container)	BLDG-800-2
Date of Collection	3-13-17
Time of Collection	8:55
Printed Name of Sample Collector	STEVE CLARK
Signature Sample Collector	Steve Clark

Notes Sample collector:
NO DRINKING WATER IN THIS BUILDING

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-15-17 1100
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

10

Collection Log

for experienced sample collectors

Empty Copy

Complete copy of this form for each sample collected. Your drinking water sam
unless a copy of this form is shipped to the lab with each sample. In addition, the sa
tested unless the Sample Identification Number matches the number on the sample co

☐ Check this box to confirm that water had not been used at this tap or other taps i
area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST.
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	MODULAR CLASSROOM
Type of Fixture (tap, drinking fountain etc.)	N/A
Location of Fixture (example, room number)	N/A
Sample Identification Number (ensure this number is also on the sample container)	MODULAR CLASSROOM
Date of Collection	N/A
Time of Collection	N/A
Printed Name of Sample Collector	STEVE GLEAD
Signature Sample Collector	Steve Gleed

Notes Sample collector:
NO WATER IN THIS BUILDING

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

(17)

Collection Log

for experienced sample collectors

Empty Copy

Complete copy of this form for each sample collected. Your drinking water sar
unless a copy of this form is shipped to the lab with each sample. In addition, the
tested unless the Sample Identification Number matches the number on the sample

☑ Check this box to confirm that water had not been used at this tap or other tap
area for 6 hours and no flushing was done prior to sampling

Name of School District	RAGSDAD UNIFIED DIST
School Name	RAGSDAD ELEMENTARY + H.S.
Building (name/number)	900
Type of Fixture (tap, drinking fountain etc.)	N/A
Location of Fixture (example, room number)	N/A
Sample Identification Number (ensure this number is also on the sample container)	BLDG-900
Date of Collection	N/A
Time of Collection	N/A
Printed Name of Sample Collector	STEVE KERR
Signature Sample Collector	Steve Kerr

Notes Sample collector:
NO WATER IN THIS BUILDING

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

16

Collection Log

for experienced sample collectors

Empty Cont.

Complete copy of this form for each sample collected. Your drinking water sam
unless a copy of this form is shipped to the lab with each sample. In addition, the s
tested unless the Sample Identification Number matches the number on the sample co

☐ Check this box to confirm that water had not been used at this tap or other taps in
area for 6 hours and no flushing was done prior to sampling

Name of School District	BAGDAD UNIFIED DIST
School Name	BAGDAD ELEMENTARY + H.S.
Building (name/number)	900
Type of Fixture (tap, drinking fountain etc.)	N/A
Location of Fixture (example, room number)	N/A
Sample Identification Number (ensure this number is also on the sample container)	BLDG-900 FROM OTHER CAMPUS
Date of Collection	N/A
Time of Collection	N/A
Printed Name of Sample Collector	STEVE REED
Signature Sample Collector	[signature]

Notes Sample collector:
NO WATER IN THIS BUILDING

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

19

Login Sample Receipt Checklist

Client: Arizona Dept of Environmental Quality

Job Number: 550-79266-1
SDG Number: Bagdad Elementary & H.S.

Login Number: 79266
List Number: 1
Creator: Vilaboy, Monica

List Source: TestAmerica Phoenix

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	Check done at department level as required.