

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)



AT-1807

Laboratory Report

for

Arizona Department of Environmental Quality
1110 West Washington Street
Phoenix, AZ 85007
Attention: David Burchard

Date of Issue
04/03/2017


Eurofins Eaton
Analytical

TDF: Thomas.D.French
Project Manager



Report: 647901
Project: PARKER-USD
ADHS License #: AZ0778
Group: La Pera Elementary
PO#: School
PO#: ADEQ16-116686:3

* Accredited in accordance with TNI 2009 and ISO/IEC 17025:2005.

* Laboratory certifies that the test results meet all **TNI 2009 and ISO/IEC 17025:2005** requirements unless noted under the individual analysis.

* Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

* Test results relate only to the sample(s) tested.

* This report shall not be reproduced except in full, without the written approval of the laboratory.

STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Mississippi	Certified
Arizona	AZ0778	Montana	Cert 0035
Arkansas	Certified	Nebraska	Certified
California-Monrovia-ELAP	2813	Nevada	CA00006-2016
California-Colton- ELAP	2812	New Hampshire *	2959
California-Folsom- ELAP	2820	New Jersey *	CA 008
California-Fresno- ELAP	2966	New Mexico	Certified
Colorado	Certified	New York *	11320
Connecticut	PH-0107	North Carolina	06701
Delaware	CA 006	North Dakota	R-009
Florida *	E871024	Oregon (Primary AB) *	ORELAP 4034
Georgia	947	Pennsylvania *	68-565
Guam	16-003r	Puerto Rico	Certified
Hawaii	Certified	Rhode Island	LAO00326
Idaho	Certified	South Carolina	87016
Illinois *	200033	South Dakota	Certified
Indiana	C-CA-01	Tennessee	TN02839
Kansas *	E-10268	Texas *	T104704230-15-9
Kentucky	90107	Utah *	CA000062016-10
Louisiana *	LA16003	Vermont	VT0114
Maine	CA0006	Virginia *	460260
Maryland	224	Washington	C838
Commonwealth of Northern Marianas Is.	MP0004	Wyoming	Certified
Massachusetts	M-CA006	EPA Region 5	Certified
Michigan	9906	Los Angeles County Sanitation Districts	10264

* NELAP/TNI Recognized Accreditation Bodies

ISO 17025 Accredited Method List

The tests listed below are accredited and meet the requirements of ISO 17025 as verified by the ANSI-ASQ National Accreditation Board/ANAB.

Refer to Certificate and scope of accreditation (AT 1807) found at: <http://www.eatonanalytical.com>

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
1,4-Dioxane	EPA 522	x		x
2,3,7,8-TCDD	Modified EPA 1613B	x		x
Acrylamide	In House Method (2440)	x		x
Alkalinity	SM 2320B	x	x	x
Ammonia	EPA 350.1		x	x
Ammonia	SM 4500-NH3 H		x	x
Anions and DBPs by IC	EPA 300.0	x	x	x
Anions and DBPs by IC	EPA 300.1	x		x
Asbestos	EPA 100.2	x	x	
Bicarbonate Alkalinity as HCO3	SM 2320B	x	x	x
BOD / CBOD	SM 5210B		x	x
Bromate	In House Method (2447)	x		x
Carbamates	EPA 531.2	x		x
Carbonate as CO3	SM 2330B	x	x	x
Carbonyls	EPA 556	x		x
COD	EPA 410.4 / SM 5220D		x	
Chloramines	SM 4500-CL G	x	x	x
Chlorinated Acids	EPA 515.4	x		x
Chlorinated Acids	EPA 555	x		x
Chlorine Dioxide	SM 4500-CLO2 D	x		x
Chlorine -Total/Free/ Combined Residual	SM 4500-Cl G	x	x	x
Conductivity	EPA 120.1		x	
Conductivity	SM 2510B	x	x	x
Corrosivity (Langelier Index)	SM 2330B	x		x
Cryptosporidium	EPA 1623	x		x
Cyanide, Amenable	SM 4500-CN G	x	x	
Cyanide, Free	SM 4500CN F	x	x	x
Cyanide, Total	EPA 335.4	x	x	x
Cyanogen Chloride (screen)	In House Method (2470)	x		x
Diquat and Paraquat	EPA 549.2	x		x
DBP/HAA	SM 6251B	x		x
Dissolved Oxygen	SM 4500-O G		x	x
DOC	SM 5310C	x		x
E. Coli (MTF/EC+MUG)		x		x
E. Coli	CFR 141.21(f)(6)(i)	x		x
E. Coli	SM 9223		x	
E. Coli (Enumeration)	SM 9221B.1/ SM 9221F	x		x
E. Coli (Enumeration)	SM 9223B	x		x
EDB/DCBP	EPA 504.1	x		
EDB/DCBP and DBP	EPA 551.1	x		x
EDTA and NTA	In House Method (2454)	x		x
Endothall	EPA 548.1	x		x
Endothall	In-house Method (2445)	x		x
Enterococci	SM 9230B	x	x	
Fecal Coliform	SM 9221 E (MTF/EC)	x		
Fecal Coliform	SM 9221C, E (MTF/EC)		x	
Fecal Coliform (Enumeration)	SM 9221E (MTF/EC)	x		x
Fecal Coliform with Chlorine Present	SM 9221E		x	
Fecal Streptococci	SM 9230B	x	x	
Fluoride	SM 4500-F C	x	x	x
Giardia	EPA 1623	x		x
Glyphosate	EPA 547	x		x
Gross Alpha/Beta	EPA 900.0	x	x	x
Gross Alpha Coprecipitation	SM 7110 C	x	x	x
Hardness	SM 2340B	x	x	x
Heterotrophic Bacteria	In House Method (2439)	x		x
Heterotrophic Bacteria	SM 9215 B	x		x
Hexavalent Chromium	EPA 218.6	x	x	x

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
Hexavalent Chromium	EPA 218.7	x		x
Hexavalent Chromium	SM 3500-Cr B		x	
Hormones	EPA 539	x		x
Hydroxide as OH Calc.	SM 2330B	x		x
Kjeldahl Nitrogen	EPA 351.2		x	
Legionella	CDC Legionella	x		x
Mercury	EPA 245.1	x	x	x
Metals	EPA 200.7 / 200.8	x	x	x
Microcystin LR	ELISA (2360)	x		x
NDMA	EPA 521	x		x
NDMA	TQ In house method based on EPA 521 (2425)	x		x
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x	x
OCL, Pesticides/PCB	EPA 505	x		x
Ortho Phosphate	EPA 365.1	x	x	x
Ortho Phosphate	SM 4500P E			x
Ortho Phosphorous	SM 4500P E	x		
Oxyhalides Disinfection Byproducts	EPA 317.0	x		x
Perchlorate	EPA 331.0	x		x
Perchlorate (low and high)	EPA 314.0	x		x
Perfluorinated Alkyl Acids	EPA 537	x		x
pH	EPA 150.1	x		
pH	SM 4500-H+B	x	x	x
Phenylurea Pesticides/ Herbicides	In House Method, based on EPA 532 (2448)	x		x
Pseudomonas	IDEXX Pseudalert (2461)	x		x
Radium-226	GA Institute of Tech	x		x
Radium-228	GA Institute of Tech	x		x
Radon-222	SM 7500RN	x		x
Residue, Filterable	SM 2540C	x	x	x
Residue, Non-filterable	SM 2540D		x	
Residue, Total	SM 2540B		x	x
Residue, Volatile	EPA 160.4		x	
Semi-VOC	EPA 525.2	x		x
Semi-VOC	EPA 625		x	x
Silica	SM 4500-Si D	x	x	
Silica	SM 4500-SiO2 C	x	x	
Sulfide	SM 4500-S ⁻ D		x	
Sulfite	SM 4500-SO ³ B	x	x	x
Surfactants	SM 5540C	x	x	x
Taste and Odor Analytes	SM 6040E	x		x
Total Coliform (P/A)	SM 9221 A, B	x		x
Total Coliform (Enumeration)	SM 9221 A, B, C	x		x
Total Coliform / E. coli	Colisure SM 9223	x		x
Total Coliform	SM 9221B		x	
Total Coliform with Chlorine Present	SM 9221B		x	
Total Coliform / E.coli (P/A and Enumeration)	SM 9223	x		x
TOC	SM 5310C	x	x	x
TOX	SM 5320B		x	
Total Phenols	EPA 420.1		x	
Total Phenols	EPA 420.4	x	x	x
Total Phosphorous	SM 4500 P E		x	
Turbidity	EPA 180.1	x	x	x
Turbidity	SM 2130B	x	x	
Uranium by ICP/MS	EPA 200.8	x		x
UV 254	SM 5910B	x		
VOC	EPA 524.2/EPA 524.3	x		x
VOC	EPA 624		x	x
VOC	EPA SW 846 8260	x		x
VOC	In House Method (2411)	x		x
Yeast and Mold	SM 9610	x		x

Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**
1110 West Washington Street
Phoenix, AZ 85007

Attn: David Burchard
Phone: (602) 771-4298

Client ID: ADEQ-LEAD
Folder #: 647901
Project: PARKER-USD
Sample Group: La Pera Elementary School

Project Manager: Thomas.D.French
Phone: (480) 778-1558
PO #: ADEQ16-116686:3
Sampler: Joe Hermes

The following samples were received from you on **March 28, 2017** at **1915**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
<u>201703290267</u>	004035	03/24/2017 0600
	Sample Type: Faucet Facility ID: P Building Sample Point ID: Main Water Line	
	@ICPMS	Freight - Outbound
		Freight - Return
<u>201703290268</u>	004066	03/24/2017 0612
	Sample Type: Faucet Sink #2 Facility ID: D Sample Point ID: Kitchen	
	@ICPMS	
<u>201703290269</u>	004033	03/24/2017 0613
	Sample Type: Faucet Sink #1 Facility ID: D Sample Point ID: Kitchen	
	@ICPMS	
<u>201703290270</u>	004039	03/24/2017 0617
	Sample Type: Sink Faucet #1 Facility ID: B Sample Point ID: Shop Sink	
	@ICPMS	
<u>201703290271</u>	004051	03/24/2017 0619
	Sample Type: Sink Facility ID: B Sample Point ID: Bathroom Sink	
	@ICPMS	
<u>201703290272</u>	004073	03/24/2017 0624
	Sample Type: Sink Facility ID: E Sample Point ID: Lounge	
	@ICPMS	
<u>201703290273</u>	004034	03/24/2017 0628
	Sample Type: Sink Facility ID: E Sample Point ID: Health Aid	
	@ICPMS	
<u>201703290274</u>	004067	03/24/2017 0633

Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**
1110 West Washington Street
Phoenix, AZ 85007

Attn: David Burchard
Phone: (602) 771-4298

Client ID: ADEQ-LEAD
Folder #: 647901
Project: PARKER-USD
Sample Group: La Pera Elementary School

Project Manager: Thomas.D.French
Phone: (480) 778-1558
PO #: ADEQ16-116686:3
Sampler: Joe Hermes

The following samples were received from you on **March 28, 2017** at **1915**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	Sample Type: Faucet/Fountain Facility ID: F Sample Point ID: Room #7 @ICPMS	
<u>201703290275</u>	004053	03/24/2017 0636
	Sample Type: Fountain Drinking Facility ID: F Sample Point ID: 5 @ICPMS	
<u>201703290276</u>	004063	03/24/2017 0640
	Sample Type: Drinking Fountain Facility ID: J Sample Point ID: 9 @ICPMS	
<u>201703290277</u>	004061	03/24/2017 0642
	Sample Type: Drinking Fountain Facility ID: J Sample Point ID: 14 @ICPMS	
<u>201703290278</u>	004080	03/24/2017 0645
	Sample Type: Outside Drinking Fountain Facility ID: K Sample Point ID: GYM @ICPMS	
<u>201703290279</u>	004065	03/24/2017 0647
	Sample Type: Sink Facility ID: K Sample Point ID: Men's Restroom Sink @ICPMS	
<u>201703290280</u>	004079	03/24/2017 0650
	Sample Type: Drinking Fountain Facility ID: C Sample Point ID: Not Provided @ICPMS	
<u>201703290281</u>	004077	03/24/2017 0652
	Sample Type: Restroom Sink Facility ID: C Sample Point ID: Restroom Sink	

Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**
1110 West Washington Street
Phoenix, AZ 85007

Attn: David Burchard
Phone: (602) 771-4298

Client ID: ADEQ-LEAD
Folder #: 647901
Project: PARKER-USD
Sample Group: La Pera Elementary School

Project Manager: Thomas.D.French
Phone: (480) 778-1558
PO #: ADEQ16-116686:3
Sampler: Joe Hermes

The following samples were received from you on **March 28, 2017** at **1915**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	@ICPMS	
201703290282	004064	03/24/2017 0655
	Sample Type: Sink Facility ID: H Sample Point ID: 18	
	@ICPMS	
201703290283	004058	03/24/2017 0658
	Sample Type: Sink Facility ID: H Sample Point ID: 19	
	@ICPMS	
201703290284	004068	03/24/2017 0700
	Sample Type: Fountain Facility ID: L Sample Point ID: 23	
	@ICPMS	
201703290285	004047	03/24/2017 0703
	Sample Type: 25 Facility ID: L Sample Point ID: Not Provided	
	@ICPMS	
201703290286	004062	03/24/2017 0717
	Sample Type: Drinking Fountain Facility ID: A Sample Point ID: Maintenance Shop	
	@ICPMS	
201703290287	004070	03/24/2017 0719
	Sample Type: Maintenance Shop Sink Facility ID: A Sample Point ID: Maintenance Shop	
	@ICPMS	
201703290288	004046	03/24/2017 1122
	Sample Type: Sink Facility ID: Housing 18803 Sample Point ID: Kitchen	
	@ICPMS	
201703290289	004052	03/24/2017 1135

Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**
1110 West Washington Street
Phoenix, AZ 85007

Attn: David Burchard
Phone: (602) 771-4298

Client ID: ADEQ-LEAD
Folder #: 647901
Project: PARKER-USD
Sample Group: La Pera Elementary School

Project Manager: Thomas.D.French
Phone: (480) 778-1558
PO #: ADEQ16-116686:3
Sampler: Joe Hermes

The following samples were received from you on **March 28, 2017** at **1915**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	Sample Type: Sink Tap Facility ID: Housing 18791 Sample Point ID: Kitchen <div>@ICPMS</div>	

Test Description

@ICPMS -- ICPMS Metals


Collection Log

for experienced sample collectors


647901

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Lepera Elementary School
Building (name/number)	P. Building
Type of Fixture (tap, drinking fountain etc.)	Faucet
Location of Fixture (example, room number)	Main Line Main Water Line
Sample Identification Number (<u>Write the number here and on sample container</u>)	004035
Date of Collection	3-24-17
Time of Collection	6:00 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Lepera Elementary School
Building (name/number)	D
Type of Fixture (tap, drinking fountain etc.)	Faucet Sink #2
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (<u>Write the number here and on sample container</u>)	004066
Date of Collection	3-24-17
Time of Collection	6:12 A.M
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received 3-28-17 1915	
Signature 	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	D
Type of Fixture (tap, drinking fountain etc.)	Faucet sink #1
Location of Fixture (example, room number)	Faucet sink #1 Kitchen
Sample Identification Number (<u>Write the number here and on sample container</u>)	004033
Date of Collection	3-24-17
Time of Collection	06:13 A.M.
Printed Name of Sample Collector	Joe Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received 3-28-17 1915	
Signature 	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePera Elementary School
Building (name/number)	B
Type of Fixture (tap, drinking fountain etc.)	Sink Faucet #1
Location of Fixture (example, room number)	Shop Sink
Sample Identification Number (<u>Write the number here and on sample container</u>)	004039
Date of Collection	03-24-17
Time of Collection	06:17 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 19:15
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePera Elementary School
Building (name/number)	B
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Bathroom Sink
Sample Identification Number (<u>Write the number here and on sample container</u>)	006051
Date of Collection	3/24/17
Time of Collection	06:19 A.M.
Printed Name of Sample Collector	Joe Hormes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementar School
Building (name/number)	E
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Lounge
Sample Identification Number (<u>Write the number here and on sample container</u>)	004073
Date of Collection	3/24
Time of Collection	6:24
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 19:15
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePerq Elementary School
Building (name/number)	E 520K
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Health Aid
Sample Identification Number (<u>Write the number here and on sample container</u>)	004034
Date of Collection	3-24-17
Time of Collection	06:28
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received 3-28-17 1915	
Signature 	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	F
Type of Fixture (tap, drinking fountain etc.)	Room # 7
Location of Fixture (example, room number)	Room # 7
Sample Identification Number (<u>Write the number here and on sample container</u>)	004067
Date of Collection	03-24-17
Time of Collection	06:33 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 19:15
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	F
Type of Fixture (tap, drinking fountain etc.)	Fountain drinking
Location of Fixture (example, room number)	5
Sample Identification Number (<u>Write the number here and on sample container</u>)	004053
Date of Collection	03-24-17
Time of Collection	06:36 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received 3-28-17 1915	
Signature 	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	J
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	9
Sample Identification Number (<u>Write the number here and on sample container</u>)	004063
Date of Collection	03-24-17
Time of Collection	06:40 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	5
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	14
Sample Identification Number (<u>Write the number here and on sample container</u>)	004061
Date of Collection	03-24-17
Time of Collection	06:42 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePera Elementary School
Building (name/number)	K
Type of Fixture (tap, drinking fountain etc.)	outside drinking fountain
Location of Fixture (example, room number)	Gym
Sample Identification Number (<u>Write the number here and on sample container</u>)	004080
Date of Collection	3-24-17
Time of Collection	06:45 AM
Printed Name of Sample Collector	
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	K
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Men's Restroom sink
Sample Identification Number (<u>Write the number here and on sample container</u>)	004069
Date of Collection	03-24-17
Time of Collection	06:47
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	C
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	
Sample Identification Number (Write the number here and on sample container)	004079
Date of Collection	03-24
Time of Collection	06:50
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Lepera Elementary School
Building (name/number)	C
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	Restroom Sink
Sample Identification Number (<u>Write the number here and on sample container</u>)	004077
Date of Collection	03-24-17
Time of Collection	06:52 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-18-17 19:5
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	La Pera Elementary School
Building (name/number)	H
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	18
Sample Identification Number (<u>Write the number here and on sample container</u>)	004064
Date of Collection	03-24-17
Time of Collection	06:55 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePera Elementary School
Building (name/number)	H
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	19
Sample Identification Number (<u>Write the number here and on sample container</u>)	004058
Date of Collection	03-24-17
Time of Collection	06:58 AM
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePera Elementary School
Building (name/number)	L
Type of Fixture (tap, drinking fountain etc.)	2 Fountain
Location of Fixture (example, room number)	23
Sample Identification Number (<u>Write the number here and on sample container</u>)	004068
Date of Collection	03-24-17
Time of Collection	07:00 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Lepera Elementary School
Building (name/number)	L
Type of Fixture (tap, drinking fountain etc.)	25
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write the number here and on sample container</u>)	004047
Date of Collection	03-24-17
Time of Collection	07:03 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	A
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	Maintenance Shop
Sample Identification Number (<u>Write the number here and on sample container</u>)	004062
Date of Collection	03-24-17
Time of Collection	07:17 A.M.
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePera Elementary School
Building (name/number)	A
Type of Fixture (tap, drinking fountain etc.)	Maintenance Shop Sink
Location of Fixture (example, room number)	Maintenance Shop
Sample Identification Number (<u>Write the number here and on sample container</u>)	004070
Date of Collection	03-24-17
Time of Collection	07:19
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17/15
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePerq Elementary School
Building (name/number)	Housing 18803
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (<u>Write the number here and on sample container</u>)	004046
Date of Collection	03-24-17
Time of Collection	11:22 AM
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1515
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	Housing 18791
Type of Fixture (tap, drinking fountain etc.)	Sink Tap
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (<u>Write the number here and on sample container</u>)	004052
Date of Collection	3/24/17
Time of Collection	11:35 AM
Printed Name of Sample Collector	Joe Hermes
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17/915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePera Elementary School
Building (name/number)	G Greenhouse
Type of Fixture (tap, drinking fountain etc.)	No Greenhouse on property
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write the number here and on sample container</u>)	
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	
Signature Sample Collector	

Notes Sample collector: *There is no G Building*

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePerq Elementary School
Building (name/number)	M Building
Type of Fixture (tap, drinking fountain etc.)	No water to building
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write the number here and on sample container</u>)	
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	
Signature Sample Collector	

Notes Sample collector: *No water in music rooms and water is off for locker rooms for renovation.*

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	LePera Elementary School
Building (name/number)	Q Building
Type of Fixture (tap, drinking fountain etc.)	none
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write the number here and on sample container</u>)	
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	
Signature Sample Collector	

Notes Sample collector:

No water to building.

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Parker Unified School District
School Name	Le Pera Elementary School
Building (name/number)	P building
Type of Fixture (tap, drinking fountain etc.)	none
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write the number here and on sample container</u>)	
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	
Signature Sample Collector	

Notes Sample collector:

only one water source to sample from

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-28-17 1915
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Eaton Analytical

Kit Order for Arizona Department of Environmental Quality
Thomas.D.French is your Eurofins Eaton Analytical Service Manager

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
(626) 386-1100 FAX (626) 386-1101

Kit #: 159077



Created By: Thomas.D.French - [TDF]
Deliver By: 02/14/2017

STG: Bottle Orders

Ice Type: W

Note: Sampler Please return this paper with your samples

Client ID: ADEQ-LEAD
Project Code: PARKER-USD Bottle Orders
Group Name: La Pera Elementary School
PO#JOB#:

Ship Sample Kits to
Parker Unified School District
1608 Laguna Avenue
Parker, AZ 85344

Attn: Brad Sale
Phone: (928) 669-9244

Send Report to
Arizona Department of Environmental
Quality
1110 West Washington Street
Phoenix, AZ 85007

Attn: David Burchard
Phone: (602) 771-4298

Billing Address
Arizona Department of Environmental
Quality
1110 West Washington Street
Phoenix, AZ 85007

Attn: ADEQ
Phone: (602) 771-1936

of

Sample Tests

30 @ICPMS

Bottle Qty - Type [preservative information]

1 - 250ml poly [no preservative]

UN DOT #

Comments

La Pera Elementary School - Include Parker Unified School District Sample list, 30 Lead Sampling Plan Records, packing instructions for return shipment to Eurofins Eaton Analytical, Inc. 750 Royal Oaks Drive, Suite C, Monrovia, CA 91016. 30 sample containers. Return Shipment Fed EX

Sampler - please refer to Sampling Plan Records for instructions on completing paperwork and what to include with return shipment of the samples.

Code

Status

Date Shipped

Via

Tracking #

of Coolers

Prepared By



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number:

SAMPLE TEMP RECEIVED:

SAMPLES REC'D DAY OF COLLECTION? ☐

IR Gun ID = 570A (Observation = 22.5 °C) (Corr. Factor 0.1 °C) (Final = 22.4 °C)

TYPE OF ICE: Real ☐ Synthetic ☐ No Ice ☒ CONDITION OF ICE: Frozen ☐ Partially Frozen ☐ Thawed ☐ N/A ☒

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other:

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: <10°C, not frozen (can be ≥10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: <10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	2 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)
3 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)	4 = (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

- 4) UCMR3: 524.3: (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)
(non-GLEC)
522: (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

≤ 10°C if received within 48 hours of sample collection (not the same business day); ≤ 6°C if received after 48 hours of sample collection. Measure temperature for each method above.

- 5) LT2: Giardia /Cryptosporidium: <20 °C, not frozen (received after 8 hours of sample collection)

E. Coli: <10°C, not frozen (if received after 2 hours of sample collection)

Giardia/Crypto: (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

E.Coli: (Observation = _____ °C) (Corr. Factor = _____ °C) (Final = _____ °C)

- 6) Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)


Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

RECEIVED BY: <u> </u>	PRINT NAME <u> </u>	COMPANY/TITLE <u>Eurofins Eaton Analytical</u>	DATE <u>3-28-17</u>	TIME <u>1915</u>
--	--	--	---------------------	------------------

District	School	Building No	Building Desc	Building Use	Year Built	street	City	zip	County	Number of Containers per building
Parker Unified School District	Le Pera Elementary School	1001	A Building	Shop, Maintenance	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1002	B Building	Storage, Bus Bay, Maintenance	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1003	C Building	Maintenance, Mechanical	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1004	D Building	Cafeteria	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1005	E Building	Library, Offices, Computer Labs	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1006	F Building	Classrooms	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1007	G Building	Greenhouse	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1008	H Building	Classrooms	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1009	J Building	Classrooms	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1010	K Building	Gymnasium	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1011	L Building	Classrooms	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1012	M Building	Music Classrooms	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1013	P Building	Pressure Tank Building	1980	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1014	Q Building	Old Gymnasium	1965	P O Box 1089	Parker	85371	La Paz	2
Parker Unified School District	Le Pera Elementary School	1015	Teacherage	Teacher Housing	1980	P O Box 1089	Parker	85371	La Paz	2
Total Containers										30







	Boys Locker	Girls Locker	M	Rm.27	Rm.26
				Chorus	Ms. Alencio Band



L	Rm.25	Rm.24
	Mrs. Mele 8-1	Mr. Thompson Gr.6
		Rm.22

Rm.21	H	Rm.19
Mr. McKenzie 8-2	Mrs. Smith Self-Contained	Mr. Haddad 7-1
7-2 Mrs. Schmidt Rm.16	Ms. Rocco Speech Rm.17	Mr. Haddad Health/PE Rm.18

Rm.15	Rm.14	Rm.13	Mrs. Sharnowski Gr.1 Rm.12
Mrs. Goldsberry Gr.2	Mrs. McKenzie Gr.3	Mrs. Johnson Gr.3	Mrs. Oliver KG Rm.11
Rm.8	Rm.9	Art Room Rm.10	



Jan	Rm.7	Rm.6	Rm.5	Rm.4
Men	Mrs. Walt Gr.5	Ms. Marcy Gr.5	Schneider Beneke	
Women	Mrs. MacFarland Gr.4	Mrs. Wolf Resource	Reading Reading	
Mrs. Schneider	Rm.1	Rm.2	Rm.3	
Ms. Kobbie				

Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Laboratory Comments
Report: 647901

Arizona Department of Environmental Quality
David Burchard
1110 West Washington Street
Phoenix, AZ 85007

Arizona Department of Environmental Quality
David Burchard
1110 West Washington Street
Phoenix, AZ 85007

Samples Received on:
03/28/2017 1915

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
04/01/2017 12:24	Lead Total ICAP/MS	201703290267 <u>004035</u>	0.58	15	ug/L	0.5
04/01/2017 12:25	Lead Total ICAP/MS	201703290268 <u>004066</u>	2.6	15	ug/L	0.5
04/01/2017 12:26	Lead Total ICAP/MS	201703290269 <u>004033</u>	2.8	15	ug/L	0.5
04/01/2017 12:27	Lead Total ICAP/MS	201703290270 <u>004039</u>	5.2	15	ug/L	0.5
04/01/2017 12:27	Lead Total ICAP/MS	201703290271 <u>004051</u>	11	15	ug/L	0.5
04/01/2017 12:28	Lead Total ICAP/MS	201703290272 <u>004073</u>	1.0	15	ug/L	0.5
04/01/2017 12:29	Lead Total ICAP/MS	201703290273 <u>004034</u>	2.8	15	ug/L	0.5
04/01/2017 12:31	Lead Total ICAP/MS	201703290274 <u>004067</u>	3.0	15	ug/L	0.5
04/01/2017 12:32	Lead Total ICAP/MS	201703290275 <u>004053</u>	2.3	15	ug/L	0.5
04/01/2017 12:36	Lead Total ICAP/MS	201703290276 <u>004063</u>	0.97	15	ug/L	0.5
04/01/2017 12:38	Lead Total ICAP/MS	201703290277 <u>004061</u>	2.4	15	ug/L	0.5
04/01/2017 12:41	Lead Total ICAP/MS	201703290278 <u>004080</u>	0.64	15	ug/L	0.5
04/01/2017 12:42	Lead Total ICAP/MS	201703290279 <u>004065</u>	3.7	15	ug/L	0.5
04/01/2017 12:42	Lead Total ICAP/MS	201703290280 <u>004079</u>	13	15	ug/L	0.5
04/01/2017 12:43	Lead Total ICAP/MS	201703290281 <u>004077</u>	6.8	15	ug/L	0.5
		201703290282 <u>004064</u>				

SUMMARY OF POSITIVE DATA ONLY

Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Laboratory Hits
Report: 647901

Arizona Department of Environmental Quality
David Burchard
1110 West Washington Street
Phoenix, AZ 85007

Samples Received on:
03/28/2017 1915

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
04/01/2017 12:44	Lead Total ICAP/MS		36	15	ug/L	0.5
	201703290283	<u>004058</u>				
04/01/2017 12:45	Lead Total ICAP/MS		21	15	ug/L	0.5
	201703290284	<u>004068</u>				
04/01/2017 12:45	Lead Total ICAP/MS		0.84	15	ug/L	0.5
	201703290285	<u>004047</u>				
04/01/2017 12:46	Lead Total ICAP/MS		5.0	15	ug/L	0.5
	201703290286	<u>004062</u>				
04/01/2017 12:47	Lead Total ICAP/MS		13	15	ug/L	0.5
	201703290287	<u>004070</u>				
04/01/2017 12:52	Lead Total ICAP/MS		15	15	ug/L	0.5
	201703290288	<u>004046</u>				
04/01/2017 12:52	Lead Total ICAP/MS		8.2	15	ug/L	0.5
	201703290289	<u>004052</u>				
04/01/2017 12:53	Lead Total ICAP/MS		1.2	15	ug/L	0.5

SUMMARY OF POSITIVE DATA ONLY

Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Laboratory Data
Report: 647901

Arizona Department of Environmental Quality
David Burchard
1110 West Washington Street
Phoenix, AZ 85007

Samples Received on:
03/28/2017 1915

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
004035 (201703290267)						Sampled on 03/24/2017 0600			
Sample Type: Faucet Facility ID: P Building Sample Point ID: Main Water Line									
EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:24	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	0.58	ug/L	0.5	1
004066 (201703290268)						Sampled on 03/24/2017 0612			
Sample Type: Faucet Sink #2 Facility ID: D Sample Point ID: Kitchen									
EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:25	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	2.6	ug/L	0.5	1
004033 (201703290269)						Sampled on 03/24/2017 0613			
Sample Type: Faucet Sink #1 Facility ID: D Sample Point ID: Kitchen									
EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:26	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	2.8	ug/L	0.5	1
004039 (201703290270)						Sampled on 03/24/2017 0617			
Sample Type: Sink Faucet #1 Facility ID: B Sample Point ID: Shop Sink									
EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:27	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	5.2	ug/L	0.5	1
004051 (201703290271)						Sampled on 03/24/2017 0619			
Sample Type: Sink Facility ID: B Sample Point ID: Bathroom Sink									
EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:27	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	11	ug/L	0.5	1
004073 (201703290272)						Sampled on 03/24/2017 0624			
Sample Type: Sink Facility ID: E Sample Point ID: Lounge									
EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:28	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	1.0	ug/L	0.5	1
004034 (201703290273)						Sampled on 03/24/2017 0628			
Sample Type: Sink Facility ID: E Sample Point ID: Health Aid									
EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:29	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	2.8	ug/L	0.5	1
004067 (201703290274)						Sampled on 03/24/2017 0633			

Rounding on totals after summation.
(c) - indicates calculated results

Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Laboratory Data
Report: 647901

Arizona Department of Environmental Quality
David Burchard
1110 West Washington Street
Phoenix, AZ 85007

Samples Received on:
03/28/2017 1915

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Sample Type: Faucet/Fountain Facility ID: F Sample Point ID: Room #7 EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:31	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	3.0	ug/L	0.5	1
004053 (201703290275)						Sampled on 03/24/2017 0636			
Sample Type: Fountain Drinking Facility ID: F Sample Point ID: 5 EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:32	982172	983049	(EPA 200.8)	Lead Total ICAP/MS	2.3	ug/L	0.5	1
004063 (201703290276)						Sampled on 03/24/2017 0640			
Sample Type: Drinking Fountain Facility ID: J Sample Point ID: 9 EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:36	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	0.97	ug/L	0.5	1
004061 (201703290277)						Sampled on 03/24/2017 0642			
Sample Type: Drinking Fountain Facility ID: J Sample Point ID: 14 EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:38	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	2.4	ug/L	0.5	1
004080 (201703290278)						Sampled on 03/24/2017 0645			
Sample Type: Outside Drinking Fountain Facility ID: K Sample Point ID: GYM EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:41	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	0.64	ug/L	0.5	1
004065 (201703290279)						Sampled on 03/24/2017 0647			
Sample Type: Sink Facility ID: K Sample Point ID: Men's Restroom Sink EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:42	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	3.7	ug/L	0.5	1
004079 (201703290280)						Sampled on 03/24/2017 0650			
Sample Type: Drinking Fountain Facility ID: C Sample Point ID: Not Provided EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:42	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	13	ug/L	0.5	1
004077 (201703290281)						Sampled on 03/24/2017 0652			

Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Laboratory Data
Report: 647901

Arizona Department of Environmental Quality
David Burchard
1110 West Washington Street
Phoenix, AZ 85007

Samples Received on:
03/28/2017 1915

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Sample Type: Restroom Sink Facility ID: C Sample Point ID: Restroom Sink EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:43	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	6.8	ug/L	0.5	1
004064 (201703290282)						Sampled on 03/24/2017 0655			
Sample Type: Sink Facility ID: H Sample Point ID: 18 EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:44	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	36	ug/L	0.5	1
004058 (201703290283)						Sampled on 03/24/2017 0658			
Sample Type: Sink Facility ID: H Sample Point ID: 19 EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:45	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	21	ug/L	0.5	1
004068 (201703290284)						Sampled on 03/24/2017 0700			
Sample Type: Fountain Facility ID: L Sample Point ID: 23 EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:45	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	0.84	ug/L	0.5	1
004047 (201703290285)						Sampled on 03/24/2017 0703			
Sample Type: 25 Facility ID: L Sample Point ID: Not Provided EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:46	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	5.0	ug/L	0.5	1
004062 (201703290286)						Sampled on 03/24/2017 0717			
Sample Type: Drinking Fountain Facility ID: A Sample Point ID: Maintenance Shop EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:47	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	13	ug/L	0.5	1
004070 (201703290287)						Sampled on 03/24/2017 0719			
Sample Type: Maintenance Shop Sink Facility ID: A Sample Point ID: Maintenance Shop EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:52	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	15	ug/L	0.5	1
004046 (201703290288)						Sampled on 03/24/2017 1122			

Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Laboratory Data
Report: 647901

Arizona Department of Environmental Quality
David Burchard
1110 West Washington Street
Phoenix, AZ 85007

Samples Received on:
03/28/2017 1915

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Sample Type: Sink Facility ID: Housing 18803 Sample Point ID: Kitchen EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:52	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	8.2	ug/L	0.5	1
<u>004052 (201703290289)</u>						Sampled on 03/24/2017 1135			
Sample Type: Sink Tap Facility ID: Housing 18791 Sample Point ID: Kitchen EPA 200.8 - ICPMS Metals									
03/30/17	04/01/17 12:53	982172	983050	(EPA 200.8)	Lead Total ICAP/MS	1.2	ug/L	0.5	1

Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Arizona Department of Environmental Quality

ICPMS Metals**Prep Batch: 982172 Analytical Batch: 983049**

201703290267	004035
201703290268	004066
201703290269	004033
201703290270	004039
201703290271	004051
201703290272	004073
201703290273	004034
201703290274	004067
201703290275	004053

Analysis Date: 04/01/2017

Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD

ICPMS Metals**Prep Batch: 982172 Analytical Batch: 983050**

201703290276	004063
201703290277	004061
201703290278	004080
201703290279	004065
201703290280	004079
201703290281	004077
201703290282	004064
201703290283	004058
201703290284	004068
201703290285	004047
201703290286	004062
201703290287	004070
201703290288	004046
201703290289	004052

Analysis Date: 04/01/2017

Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD
Analyzed by: RPD

Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Arizona Department of Environmental Quality

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield (%)	Limits (%)	RPDLimit (%)	RPD%
ICPMS Metals by EPA 200.8									
Analytical Batch: 983049					Analysis Date: 04/01/2017				
LCS1	Lead Total ICAP/MS		20	20.5	ug/L	103	(85-115)		
LCS2	Lead Total ICAP/MS		20	20.8	ug/L	104	(85-115)	20	1.5
MBLK	Lead Total ICAP/MS			<0.25	ug/L				
MRL_CHK	Lead Total ICAP/MS		0.5	0.544	ug/L	109	(50-150)		
MS_201703280917	Lead Total ICAP/MS	13	20	34.2	ug/L	106	(70-130)		
MS2_201703280936	Lead Total ICAP/MS	1.8	20	24.2	ug/L	112	(70-130)		
MSD_201703280917	Lead Total ICAP/MS	13	20	34.5	ug/L	108	(70-130)	20	0.87
MSD2_201703280936	Lead Total ICAP/MS	1.8	20	23.8	ug/L	110	(70-130)	20	1.7
ICPMS Metals by EPA 200.8									
Analytical Batch: 983050					Analysis Date: 04/01/2017				
LCS1	Lead Total ICAP/MS		20	20.6	ug/L	103	(85-115)		
LCS2	Lead Total ICAP/MS		20	20.6	ug/L	103	(85-115)	20	0.0
MBLK	Lead Total ICAP/MS			<0.25	ug/L				
MRL_CHK	Lead Total ICAP/MS		0.5	0.528	ug/L	106	(50-150)		
MS_201703290276	Lead Total ICAP/MS	0.97	20	23.3	ug/L	112	(70-130)		
MS2_201703290286	Lead Total ICAP/MS	13	20	36.2	ug/L	116	(70-130)		
MSD_201703290276	Lead Total ICAP/MS	0.97	20	23.4	ug/L	112	(70-130)	20	0.43
MSD2_201703290286	Lead Total ICAP/MS	13	20	35.9	ug/L	114	(70-130)	20	0.83

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.