

750 Royal Oaks Drive, Suite 100  
Monrovia, California 91016-3629  
Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)



## Laboratory Report

for

Arizona Department of Environmental Quality  
1110 West Washington Street  
Phoenix, AZ 85007  
Attention: David Burchard

Date of Issue  
04/24/2017



Eurofins Eaton  
Analytical

TDF: Thomas.D.French  
Project Manager



Report: 654025  
Project: PARKER-USD  
ADHS License #: AZ0778  
Group: Parker High School  
PO#: PO#: ADEQ16-116686:3

\* Accredited in accordance with TNI 2009 and ISO/IEC 17025:2005.

\* Laboratory certifies that the test results meet all **TNI 2009 and ISO/IEC 17025:2005** requirements unless noted under the individual analysis.

\* Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

\* Test results relate only to the sample(s) tested.

\* This report shall not be reproduced except in full, without the written approval of the laboratory.

# STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Mississippi	Certified
Arizona	AZ0778	Montana	Cert 0035
Arkansas	Certified	Nebraska	Certified
California-Monrovia-ELAP	2813	Nevada	CA00006-2016
California-Colton- ELAP	2812	New Hampshire *	2959
California-Folsom- ELAP	2820	New Jersey *	CA 008
California-Fresno- ELAP	2966	New Mexico	Certified
Colorado	Certified	New York *	11320
Connecticut	PH-0107	North Carolina	06701
Delaware	CA 006	North Dakota	R-009
Florida *	E871024	Oregon (Primary AB) *	ORELAP 4034
Georgia	947	Pennsylvania *	68-565
Guam	16-003r	Puerto Rico	Certified
Hawaii	Certified	Rhode Island	LAO00326
Idaho	Certified	South Carolina	87016
Illinois *	200033	South Dakota	Certified
Indiana	C-CA-01	Tennessee	TN02839
Kansas *	E-10268	Texas *	T104704230-15-9
Kentucky	90107	Utah *	CA000062016-10
Louisiana *	LA16003	Vermont	VT0114
Maine	CA0006	Virginia *	460260
Maryland	224	Washington	C838
Commonwealth of Northern Marianas Is.	MP0004	Wyoming	Certified
Massachusetts	M-CA006	EPA Region 5	Certified
Michigan	9906	Los Angeles County Sanitation Districts	10264

\* NELAP/TNI Recognized Accreditation Bodies



ISO 17025 Accredited Method List

The tests listed below are accredited and meet the requirements of ISO 17025 as verified by the ANSI-ASQ National Accreditation Board/ANAB.

Refer to Certificate and scope of accreditation (AT 1807) found at: <http://www.eatonanalytical.com>

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
1,4-Dioxane	EPA 522	x		x
2,3,7,8-TCDD	Modified EPA 1613B	x		x
Acrylamide	In House Method (2440)	x		x
Alkalinity	SM 2320B	x	x	x
Ammonia	EPA 350.1		x	x
Ammonia	SM 4500-NH3 H		x	x
Anions and DBPs by IC	EPA 300.0	x	x	x
Anions and DBPs by IC	EPA 300.1	x		x
Asbestos	EPA 100.2	x	x	
Bicarbonate Alkalinity as HCO <sub>3</sub>	SM 2320B	x	x	x
BOD / CBOD	SM 5210B		x	x
Bromate	In House Method (2447)	x		x
Carbamates	EPA 531.2	x		x
Carbonate as CO <sub>3</sub>	SM 2330B	x	x	x
Carbonyls	EPA 556	x		x
COD	EPA 410.4 / SM 5220D		x	
Chloramines	SM 4500-CL G	x	x	x
Chlorinated Acids	EPA 515.4	x		x
Chlorinated Acids	EPA 555	x		x
Chlorine Dioxide	SM 4500-CLO <sub>2</sub> D	x		x
Chlorine -Total/Free/ Combined Residual	SM 4500-Cl G	x	x	x
Conductivity	EPA 120.1		x	
Conductivity	SM 2510B	x	x	x
Corrosivity (Langelier Index)	SM 2330B	x		x
Cryptosporidium	EPA 1623	x		x
Cyanide, Amenable	SM 4500-CN G	x	x	
Cyanide, Free	SM 4500CN F	x	x	x
Cyanide, Total	EPA 335.4	x	x	x
Cyanogen Chloride (screen)	In House Method (2470)	x		x
Diquat and Paraquat	EPA 549.2	x		x
DBP/HAA	SM 6251B	x		x
Dissolved Oxygen	SM 4500-O G		x	x
DOC	SM 5310C	x		x
E. Coli (MTF/EC+MUG)		x		x
E. Coli	CFR 141.21(f)(6)(i)	x		x
E. Coli	SM 9223		x	
E. Coli (Enumeration)	SM 9221B.1/ SM 9221F	x		x
E. Coli (Enumeration)	SM 9223B	x		x
EDB/DCBP	EPA 504.1	x		
EDB/DBCP and DBP	EPA 551.1	x		x
EDTA and NTA	In House Method (2454)	x		x
Endothall	EPA 548.1	x		x
Endothall	In-house Method (2445)	x		x
Enterococci	SM 9230B	x	x	
Fecal Coliform	SM 9221 E (MTF/EC)	x		
Fecal Coliform	SM 9221C, E (MTF/EC)		x	
Fecal Coliform (Enumeration)	SM 9221E (MTF/EC)	x		x
Fecal Coliform with Chlorine Present	SM 9221E		x	
Fecal Streptococci	SM 9230B	x	x	
Fluoride	SM 4500-F C	x	x	x
Giardia	EPA 1623	x		x
Glyphosate	EPA 547	x		x
Gross Alpha/Beta	EPA 900.0	x	x	x
Gross Alpha Coprecipitation	SM 7110 C	x	x	x
Hardness	SM 2340B	x	x	x
Heterotrophic Bacteria	In House Method (2439)	x		x
Heterotrophic Bacteria	SM 9215 B	x		x
Hexavalent Chromium	EPA 218.6	x	x	x

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environmental (Drinking Water)	Environmental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
Hexavalent Chromium	EPA 218.7	x		x
Hexavalent Chromium	SM 3500-Cr B		x	
Hormones	EPA 539	x		x
Hydroxide as OH Calc.	SM 2330B	x		x
Kjeldahl Nitrogen	EPA 351.2		x	
Legionella	CDC Legionella	x		x
Mercury	EPA 245.1	x	x	x
Metals	EPA 200.7 / 200.8	x	x	x
Microcystin LR	ELISA (2360)	x		x
NDMA	EPA 521	x		x
NDMA	TQ In house method based on EPA 521 (2425)	x		x
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x	x
OCL, Pesticides/PCB	EPA 505	x		x
Ortho Phosphate	EPA 365.1	x	x	x
Ortho Phosphate	SM 4500P E			x
Ortho Phosphorous	SM 4500P E	x		
Oxyhalides Disinfection Byproducts	EPA 317.0	x		x
Perchlorate	EPA 331.0	x		x
Perchlorate (low and high)	EPA 314.0	x		x
Perfluorinated Alkyl Acids	EPA 537	x		x
pH	EPA 150.1	x		
pH	SM 4500-H+B	x	x	x
Phenylurea Pesticides/ Herbicides	In House Method, based on EPA 532 (2448)	x		x
Pseudomonas	IDEXX Pseudalert (2461)	x		x
Radium-226	GA Institute of Tech	x		x
Radium-228	GA Institute of Tech	x		x
Radon-222	SM 7500RN	x		x
Residue, Filterable	SM 2540C	x	x	x
Residue, Non-filterable	SM 2540D		x	
Residue, Total	SM 2540B		x	x
Residue, Volatile	EPA 160.4		x	
Semi-VOC	EPA 525.2	x		x
Semi-VOC	EPA 625		x	x
Silica	SM 4500-Si D	x	x	
Silica	SM 4500-SiO <sub>2</sub> C	x	x	
Sulfide	SM 4500-S <sup>-</sup> D		x	
Sulfite	SM 4500-SO <sub>3</sub> B	x	x	x
Surfactants	SM 5540C	x	x	x
Taste and Odor Analytes	SM 6040E	x		x
Total Coliform (P/A)	SM 9221 A, B	x		x
Total Coliform (Enumeration)	SM 9221 A, B, C	x		x
Total Coliform / E. coli	Colisure SM 9223	x		x
Total Coliform	SM 9221B		x	
Total Coliform with Chlorine Present	SM 9221B		x	
Total Coliform / E.coli (P/A and Enumeration)	SM 9223	x		x
TOC	SM 5310C	x	x	x
TOX	SM 5320B		x	
Total Phenols	EPA 420.1		x	
Total Phenols	EPA 420.4	x	x	x
Total Phosphorous	SM 4500 P E		x	
Turbidity	EPA 180.1	x	x	x
Turbidity	SM 2130B	x	x	
Uranium by ICP/MS	EPA 200.8	x		x
UV 254	SM 5910B	x		
VOC	EPA 524.2/EPA 524.3	x		x
VOC	EPA 624		x	x
VOC	EPA SW 846 8260	x		x
VOC	In House Method (2411)	x		x
Yeast and Mold	SM 9610	x		x

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 654025  
Project: PARKER-USD  
Sample Group: Parker High School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Scott Vintus

The following samples were received from you on **April 17, 2017 at 1147**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
<u>201704170618</u>	K1001-001	04/11/2017 0600
	Sample Type: Drinking Fountain Facility ID: Alt School Sample Point ID: Kitchen	
	@ICPMS	Freight - Outbound
		Freight - Return
<u>201704170619</u>	1001-01	04/11/2017 0545
	Sample Type: Drinking Fountain Facility ID: Old Main Sample Point ID: Main Hall	
	@ICPMS	
<u>201704170620</u>	1001-02	04/11/2017 0545
	Sample Type: Tap Facility ID: Old Main Sample Point ID: Teacher Loung	
	@ICPMS	
<u>201704170621</u>	1004-01	04/11/2017 0550
	Sample Type: Drinking Fountain Facility ID: Administration Sample Point ID: Office	
	@ICPMS	
<u>201704170622</u>	1004-02	04/11/2017 0550
	Sample Type: Tap Facility ID: Admin Sample Point ID: Office	
	@ICPMS	
<u>201704170623</u>	1005-01	04/11/2017 0600
	Sample Type: Drinking Fountain Facility ID: Room G2-RR Sample Point ID: Room G2	
	@ICPMS	
<u>201704170624</u>	1005-02	04/11/2017 0605
	Sample Type: Drinking Fountain Facility ID: Room G2 Sample Point ID: Room G2	
	@ICPMS	
<u>201704170625</u>	1007-01 A	04/11/2017 0610

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 654025  
Project: PARKER-USD  
Sample Group: Parker High School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Scott Vintus

The following samples were received from you on **April 17, 2017 at 1147**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	Sample Type: Drinking Fountain Facility ID: Room G8-G9 Sample Point ID: Room G9 @ICPMS	
201704170626	1007-01 B	04/11/2017 0610
	Sample Type: Drinking Fountain Facility ID: Room G8-G9 Sample Point ID: Room G9 @ICPMS	
201704170627	1009-01	04/11/2017 0615
	Sample Type: Drinking Fountain Facility ID: Room 92 Sample Point ID: Room 92 @ICPMS	
201704170628	1009-02	04/11/2017 0615
	Sample Type: Tap Facility ID: Room 92 Sample Point ID: Art Room @ICPMS	
201704170629	1012-01	04/11/2017 0720
	Sample Type: Tap Facility ID: Ag Shop Sample Point ID: Ag Shop @ICPMS	
201704170630	1012-02	04/11/2017 0720
	Sample Type: Tap Facility ID: Ag Shop Sample Point ID: Ag Shop @ICPMS	
201704170631	1013-01	04/11/2017 0635
	Sample Type: Tap Facility ID: Maintenance Sample Point ID: Shop @ICPMS	
201704170632	1013-02	04/11/2017 0635
	Sample Type: Tap Facility ID: Maintenance Sample Point ID: Shop	

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 654025  
Project: PARKER-USD  
Sample Group: Parker High School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Scott Vintus

The following samples were received from you on **April 17, 2017 at 1147**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	@ICPMS	
201704170633	1014-01	04/11/2017 0620
	Sample Type: Drinking Fountain Facility ID: Old Gym Sample Point ID: Old Gym	
	@ICPMS	
201704170634	1014-02	04/11/2017 0620
	Sample Type: Drinking Fountain Facility ID: Old Gym Sample Point ID: Old Gym	
	@ICPMS	
201704170635	1015-01	04/11/2017 0650
	Sample Type: Drinking Fountain Facility ID: Auto Shop Sample Point ID: Auto Shop	
	@ICPMS	
201704170636	1015-02	04/11/2017 0650
	Sample Type: Tap Facility ID: Auto Shop Sample Point ID: Auto Shop	
	@ICPMS	
201704170637	1021-01	04/11/2017 0645
	Sample Type: Drinking Fountain Facility ID: 72-88 Classroom Library Sample Point ID: #75	
	@ICPMS	
201704170638	1021-02	04/11/2017 0645
	Sample Type: Drinking Fountain Facility ID: 72-88 Sample Point ID: #78	
	@ICPMS	
201704170639	1022-01	04/11/2017 0630
	Sample Type: Drinking Fountain Facility ID: New Gym Sample Point ID: Lobby	
	@ICPMS	
201704170640	1022-02	04/11/2017 0630

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 654025  
Project: PARKER-USD  
Sample Group: Parker High School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Scott Vintus

The following samples were received from you on **April 17, 2017 at 1147**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	Sample Type: Drinking Fountain Facility ID: New Gym Sample Point ID: Not Provided @ICPMS	
<u>201704170641</u>	1023-01	04/11/2017 0635
	Sample Type: Drinking Fountain Facility ID: Room 101-106 Sample Point ID: 101 @ICPMS	
<u>201704170642</u>	1024-01	04/11/2017 0730
	Sample Type: Drinking Fountain Facility ID: Locker Room Sample Point ID: Boys @ICPMS	
<u>201704170643</u>	1024-02	04/11/2017 0730
	Sample Type: Drinking Fountain Facility ID: Loccker Room Sample Point ID: Girls @ICPMS	
<u>201704170644</u>	1025-01	04/11/2017 0740
	Sample Type: Tap Facility ID: Laundry Sample Point ID: Only @ICPMS	
<u>201704170645</u>	1025-02	04/11/2017 0735
	Sample Type: Tap Facility ID: Laundry Sample Point ID: Only @ICPMS	
<u>201704170646</u>	1028-01	04/11/2017 0745
	Sample Type: Drinking Fountain Facility ID: Restrooms Sample Point ID: RR N @ICPMS	
<u>201704170647</u>	1028-02	04/11/2017 0745
	Sample Type: Drinking Fountain Facility ID: Restrooms Sample Point ID: RR N	

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 654025  
Project: PARKER-USD  
Sample Group: Parker High School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Scott Vintus

The following samples were received from you on **April 17, 2017 at 1147**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	@ICPMS	
201704170648	1030-01	04/11/2017 0600
	Sample Type: Tap Facility ID: Bus Barn Sample Point ID: Not Provided	
	@ICPMS	
201704170649	1030-02	04/11/2017 0600
	Sample Type: Tap Facility ID: Bus Barn Sample Point ID: Not Provided	
	@ICPMS	
201704170650	1033-01	04/11/2017 0710
	Sample Type: Tap Facility ID: District Office Sample Point ID: Center	
	@ICPMS	
201704170651	1033-02	04/11/2017 0710
	Sample Type: Tap Facility ID: District Office Sample Point ID: Back	
	@ICPMS	
201704170652	1034-01	04/11/2017 0715
	Sample Type: Tap Facility ID: Federal Sample Point ID: Only	
	@ICPMS	
201704170653	1034-02	04/11/2017 0715
	Sample Type: Tap Facility ID: Federal Sample Point ID: Only	
	@ICPMS	
201704170654	1035-01	04/11/2017 0715
	Sample Type: Tap Facility ID: Business Office Sample Point ID: Only	
	@ICPMS	
201704170655	1035-02	04/11/2017 0715

## Acknowledgement of Samples Received

Addr: **Arizona Department of Environmental Quality**  
1110 West Washington Street  
Phoenix, AZ 85007

Attn: David Burchard  
Phone: (602) 771-4298

Client ID: ADEQ-LEAD  
Folder #: 654025  
Project: PARKER-USD  
Sample Group: Parker High School

Project Manager: Thomas.D.French  
Phone: (480) 778-1558  
PO #: ADEQ16-116686:3  
Sampler: Scott Vintus

The following samples were received from you on **April 17, 2017 at 1147**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	Sample Type: Tap Facility ID: Business Office Sample Point ID: Only @ICPMS	
<u>201704170656</u>	1036-01	04/11/2017 0605
	Sample Type: Tap Facility ID: Mobile Home Sample Point ID: Kitchen @ICPMS	
<u>201704170657</u>	1036-02	04/11/2017 0605
	Sample Type: Tap Facility ID: Mobile Home Sample Point ID: Bath @ICPMS	
<u>201704170658</u>	1037-01	04/11/2017 0650
	Sample Type: Drinking Fountain Facility ID: Cafeteria Sample Point ID: Front @ICPMS	
<u>201704170659</u>	1038-01	04/11/2017 0630
	Sample Type: Tap Facility ID: Green House Sample Point ID: Not Provided @ICPMS	

## Test Description


@ICPMS -- ICPMS Metals

**Collection Log**  
*for experienced sample collectors*

654025


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Alternative School
Building (name/number)	Alt School
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Kitchen
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	K1001-001
Date of Collection	4-11-17
Time of Collection	6:00
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	22.4 °C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Old main
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	main Hall
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1001-01
Date of Collection	4-11-17
Time of Collection	5:45
Printed Name of Sample Collector	Scott J. Inters
Signature Sample Collector	

Notes Sample collector:	
-------------------------	--

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Old main
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Teacher lounge
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1001-02
Date of Collection	4-11-17
Time of Collection	5:45
Printed Name of Sample Collector	Scott Vinkus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Administration
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Office
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1004-01
Date of Collection	4-11-16
Time of Collection	5:50
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/16 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Admin
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Office
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1004-02
Date of Collection	4-11
Time of Collection	8:50
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/11/17 11:17
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 62 - RR
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Room 62
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1005-01
Date of Collection	4-11-17
Time of Collection	6:00
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 02
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	RR Room 02
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1005-02
Date of Collection	4-11
Time of Collection	0:05
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/11/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 68-69
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Room 69
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1007-01
Date of Collection	4-11
Time of Collection	6:10
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:	Rec'd 2 containers with same description sampled @ 6:10 ID 1007-01 on both bottles.
-------------------------	---

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	JR
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 68-69
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Room 69
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1007-02
Date of Collection	4-11-17
Time of Collection	6:10
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:	<p>Did not Received. 2 bottle with ID 1007-01 sampled @ 6:10.</p>
-------------------------	---

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 92
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Room 92
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1009-01
Date of Collection	4-11
Time of Collection	6:15
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 11:47
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 42
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Art Room
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1009-02
Date of Collection	4-11
Time of Collection	6:15
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/14 11:47
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	AG Shop
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	AG Shop
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1012 - 01
Date of Collection	4/11
Time of Collection	7:20
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	AG Shop
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	AG Shop
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1012-02
Date of Collection	4/11
Time of Collection	7:20
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Maintenance
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Shop
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1013-01
Date of Collection	4-12-17
Time of Collection	6:35
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Maintenance
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Shop
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1013-02
Date of Collection	4-12-17
Time of Collection	6:35
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*




**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Old Gym
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Old Gym
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1014-01
Date of Collection	4-11-17
Time of Collection	6:20
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Old Gym
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Old Gym
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1014-02
Date of Collection	4-11-17
Time of Collection	6:20
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Auto Shop
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Auto Shop
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1015-01
Date of Collection	4-11
Time of Collection	6:50
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Auto Shop
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Auto Shop
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1005-02
Date of Collection	4-11
Time of Collection	6:50
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	72-88 Classroom Library
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	#25
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	10-21-01
Date of Collection	4-11
Time of Collection	6:45
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/11/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	72-88
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	#78
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1021-02
Date of Collection	4-11
Time of Collection	6:45
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/11/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	New Gym
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Lobby
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1022-01
Date of Collection	4-11-17
Time of Collection	8:20
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	New Gym
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1022-02
Date of Collection	4-11
Time of Collection	6:30
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 11:47
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 101-106
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	101
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1023-01
Date of Collection	4-11
Time of Collection	6:35
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/19 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Lecture Rooms
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Boys
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1024-01
Date of Collection	4-11
Time of Collection	7:30
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1:47
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Locker Rooms
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Bo Girls
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1024-02
Date of Collection	4-11
Time of Collection	7:30
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Laundry
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	only
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1025-01
Date of Collection	4-11
Time of Collection	7:40
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Laundry
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	only
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1025-02
Date of Collection	4-11
Time of Collection	7:35
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Rest Room 5
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	RR N
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1028-01
Date of Collection	4-11
Time of Collection	7:45
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Rest Rooms
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	RR10
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1028-02
Date of Collection	4-11
Time of Collection	7:45
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Bus Barn
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1030--01
Date of Collection	4-12-17
Time of Collection	6:00
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Bus Barn
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1030-02
Date of Collection	4-12-17
Time of Collection	6:00
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	District Office
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Center
Sample Identification Number ( <b>Write the number here and on sample container</b> )	1033-01
Date of Collection	4-11
Time of Collection	7:10
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	District Office
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Back
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1033-02
Date of Collection	4-11
Time of Collection	7:10
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 11:47
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Federal
Type of Fixture (tap, drinking fountain etc.)	Tap
Location of Fixture (example, room number)	only
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1034-01
Date of Collection	4-11
Time of Collection	7:15
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Federal
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	only
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1034-02
Date of Collection	4-11
Time of Collection	7:15
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Business Office
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	only
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1035-01
Date of Collection	4-11
Time of Collection	7:15
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Business Office
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	only
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1035-02
Date of Collection	4-11
Time of Collection	7:15
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/11/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Mobile Home
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Kitchen
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1036-01
Date of Collection	9-12-17
Time of Collection	8:05
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	9/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Mobile Home
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Bath
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1036-02
Date of Collection	4/12/17
Time of Collection	6:05
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Cafeteria
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Front
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1037-01
Date of Collection	4-11
Time of Collection	6:50
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Green House
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1038-01
Date of Collection	4-12-17
Time of Collection	6:20
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:	
-------------------------	--

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room -27-29
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1002-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
no water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	AR
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 27-29
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1002-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintas
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 30-32
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1003-03
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 30-32
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1003-04
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	
Signature Sample Collector	

Notes Sample collector:
no water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/10 1147
Signature	JR
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

*for experienced sample collectors*


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 66-67
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1006-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

NO water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	7/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 66-67
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1006-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	<u>Scott</u>

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	<u>[Signature]</u>
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 70-71
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1008-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
no water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only


Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 70-71
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1008-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
NO water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

*for experienced sample collectors*


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 93
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1010 - 01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Room 93
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1010-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
NO water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 12:11:47
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	A16 CLASS ROOM # 94
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1011-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

*for experienced sample collectors*


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	AG Classroom #91
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#16
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1016-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only


Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#16
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1016-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water ✓

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/19/17
Signature	 1147
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#17
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1047-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	9/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#17
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1017-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#18
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1018-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only


Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#18
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1018-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	H19
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1019-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#19
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1019-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	40-43
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1020-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	40-43
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1020-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17
Signature	 1147
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Athletic Storage
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1026-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

NO water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Athletic Storage
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1026-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

NO water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#28
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1027-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	# 28
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1027-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

no water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	#30
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1029-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log

for experienced sample collectors


Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Storage Shed
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	1031-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

NO water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log


*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Storage Shed
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1031-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_


*These samples were collected for lead screening purposes only and cannot be used for compliance.*

## Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Storage Building
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1032-01
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:

100 water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 JK 1147
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log


for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling.

Name of School District	Parker Unified School District #27
School Name	Parker High School
Building (name/number)	Storage Building
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number ( <u>Write the number here and on sample container</u> )	1032-02
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	Scott Vintus
Signature Sample Collector	

Notes Sample collector:
NO water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	4/17/17 11:47
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



eurofins

Eaton Analytical

# INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number:

SAMPLE TEMP RECEIVED:

SAMPLES REC'D DAY OF COLLECTION? ☐

IR Gun ID = 5091A (Observation = 22.6 °C) (Corr. Factor -0.2 °C) (Final = 22.4 °C)

TYPE OF ICE: Real ☒ Synthetic ☐ No Ice ☒ CONDITION OF ICE: Frozen ☐ Partially Frozen ☐ Thawed ☐ N/A ☒

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other:                     

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = <u>          </u> °C) (Corr. Factor <u>          </u> °C) (Final = <u>          </u> °C)	2 = (Observation = <u>          </u> °C) (Corr. Factor <u>          </u> °C) (Final = <u>          </u> °C)
3 = (Observation = <u>          </u> °C) (Corr. Factor <u>          </u> °C) (Final = <u>          </u> °C)	4 = (Observation = <u>          </u> °C) (Corr. Factor <u>          </u> °C) (Final = <u>          </u> °C)

4) UCMR3: 524.3: (Observation =            °C) (Corr. Factor            °C) (Final =            °C)  
(non-GLEC)

522: (Observation =            °C) (Corr. Factor            °C) (Final =            °C)

≤ 10°C if received within 48 hours of sample collection (not the same business day); ≤ 6°C if received after 48 hours of sample collection. Measure temperature for each method above.

5) LT2: Giardia /Cryptosporidium: <20 °C, not frozen (received after 8 hours of sample collection)

E. Coli: < 10°C, not frozen (if received after 2 hours of sample collection)

Giardia/Crypto: (Observation =            °C) (Corr. Factor            °C) (Final =            °C)

E. Coli: (Observation =            °C) (Corr. Factor            °C) (Final =            °C)

6) Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

RECEIVED BY: <u>fr</u>	SIGNATURE <u>Joseph</u>	PRINT NAME	COMPANY/TITLE	DATE	TIME
		Eurofins Eaton Analytical		4/14/17	1147






District	School	Building No	Building Desc	Building Use	Year Built	street	City	zip	County	Number of Containers per building
Parker Unified School District	Parker Alternative School	1001	Classrooms	Classrooms	1995	unknown	Parker	85344	La Paz	1
Parker Unified School District	Parker High School	1001	#1 Old Main	Dist. SpEd, Classrooms, Bookstore	1936	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1002	2A Rooms 27-29	Counseling	1952	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1003	2B Rooms 30-32	Classrooms, Attendance	1952	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1004	Room 3A Administration	High School Principal, AP	1952	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1005	#4 Room 62 and RR	Classrooms, RR	1968	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1006	#5 Rooms 66 & 67	Classrooms	1972	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1007	#6 Rooms 68 & 69	Classrooms	1961	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1008	# 7 Rooms 70-71	Classrooms	1968	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1009	#8 Room 92 Art Room	Classroom	1969	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1010	#9 Room 93 Business	Classroom	1970	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1011	#10 Classrooms (AG)	Classrooms	1973	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1012	#11 Room 96 VoAg Shop	Classroom, Shop	1973	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1013	#23 Room 97 Maintenance	District Wide Maint.	1983	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1014	#13 Fuqua Gym 33, 34, 44, 46	Classrooms, Food Service	1962	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1015	#15 Room 24	Classrooms, shops	1967	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1016	#16 Rooms 22,23 - DEMO	Classroom, Maintenance - Removed for DC project	1967	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1017	#17 Rooms	Classrooms -	1967	P O Box 1089	Parker	85344-1089	La Paz	2



School District			18-19 - DEMO	Removed for DC project	1089	1089	
Parker Unified School District	Parker High School	1018	#18 Room 20 - DEMO	Teachers Lounge - Removed for DC project	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1019	#19 Room 17 - DEMO	Classroom - Removed for DC project	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1020	#12 40-43 Classrooms	Classrooms	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1021	#21 Rooms 72-88	Classrooms, Library	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1022	#22 Room 56 Gymnasium	Gymnasium	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1023	#24 Classrooms 101-106	Classrooms, Computer Lab	P O Box 1089	1089	1
Parker Unified School District	Parker High School	1024	#25 Locker Rooms	Locker Rooms	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1025	#26 Laundry, Weights, Wrestling	Athletic Facilities	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1026	#27 Athletic Storage	Athletic Storage	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1027	#28 Fieldhouse Storage	Storage	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1028	#29 Rest Rooms	Rest Rooms	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1029	#30 Storage Shed	Athletic Storage	P O Box 1089	1089	1
Parker Unified School District	Parker High School	1030	Bus Garage	District Transportation	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1031	Storage Shed	District Transportation	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1032	Storage Building	Transportation Storage	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1033	DO #1 Supt. Offices	District Administration	P O Box 1089	1089	2
Parker Unified School District	Parker High School	1034	DO #2 State, Federal Projects	District programs	P O Box 1089	1089	2

Parker Unified School District	Parker High School	1035	DO #3 Business Offices	District Business	1978	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1036	Mobile Home	Teacherage	1985	P O Box 1089	Parker	85344-1089	La Paz	2
Parker Unified School District	Parker High School	1037	Multipurpose Building	Cafeteria, Music, Drama, Assembly	2004	P O Box 1089	Parker	85344-1089	La Paz	1
Parker Unified School District	Parker High School	1038	Greenhouse	Ag. Greenhouse	2004	P O Box 1089	Parker	85344-1089	La Paz	1
<b>Total Containers</b>										<b>73</b>







1026

1026

Shrine

1031

01  
Bus barn  
02  
1030

Locker rooms

10  
20

1024

20  
10  
Field Hoses

1025

1036

02  
Mobile  
10

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

**Laboratory Comments**  
**Report: 654025**

Arizona Department of Environmental Quality  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

---



Tel: (626) 386-1100  
 Fax: (626) 386-1101  
 1 800 566 LABS (1 800 566 5227)

**Laboratory Hits  
 Report: 654025**

**Arizona Department of Environmental Quality**  
 David Burchard  
 1110 West Washington Street  
 Phoenix, AZ 85007

Samples Received on:  
 04/17/2017 1147

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
04/21/2017 12:38	<b>201704170623</b> Lead Total ICAP/MS	<b><u>1005-01</u></b>	1.6	15	ug/L	0.5
04/21/2017 12:38	<b>201704170624</b> Lead Total ICAP/MS	<b><u>1005-02</u></b>	22	15	ug/L	0.5
04/21/2017 12:41	<b>201704170628</b> Lead Total ICAP/MS	<b><u>1009-02</u></b>	9.7	15	ug/L	0.5
04/21/2017 12:48	<b>201704170632</b> Lead Total ICAP/MS	<b><u>1013-02</u></b>	1.0	15	ug/L	0.5
04/21/2017 12:51	<b>201704170636</b> Lead Total ICAP/MS	<b><u>1015-02</u></b>	1.6	15	ug/L	0.5
04/21/2017 13:08	<b>201704170648</b> Lead Total ICAP/MS	<b><u>1030-01</u></b>	2.0	15	ug/L	0.5
04/21/2017 13:11	<b>201704170650</b> Lead Total ICAP/MS	<b><u>1033-01</u></b>	1.2	15	ug/L	0.5
04/21/2017 13:12	<b>201704170651</b> Lead Total ICAP/MS	<b><u>1033-02</u></b>	1.6	15	ug/L	0.5
04/21/2017 13:16	<b>201704170654</b> Lead Total ICAP/MS	<b><u>1035-01</u></b>	0.94	15	ug/L	0.5
04/21/2017 13:25	<b>201704170659</b> Lead Total ICAP/MS	<b><u>1038-01</u></b>	8.2	15	ug/L	0.5

**SUMMARY OF POSITIVE DATA ONLY**

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data  
Report: 654025

Arizona Department of Environmental Quality  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
04/17/2017 1147

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
<b>K1001-001 (201704170618)</b>						<b>Sampled on 04/11/2017 0600</b>			
Sample Type: Drinking Fountain Facility ID: Alt School Sample Point ID: Kitchen									
<b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:27	987352	988653	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1001-01 (201704170619)</b>						<b>Sampled on 04/11/2017 0545</b>			
Sample Type: Drinking Fountain Facility ID: Old Main Sample Point ID: Main Hall									
<b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:31	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1001-02 (201704170620)</b>						<b>Sampled on 04/11/2017 0545</b>			
Sample Type: Tap Facility ID: Old Main Sample Point ID: Teacher Loung									
<b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:34	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1004-01 (201704170621)</b>						<b>Sampled on 04/11/2017 0550</b>			
Sample Type: Drinking Fountain Facility ID: Administration Sample Point ID: Office									
<b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:34	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1004-02 (201704170622)</b>						<b>Sampled on 04/11/2017 0550</b>			
Sample Type: Tap Facility ID: Admin Sample Point ID: Office									
<b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:37	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1005-01 (201704170623)</b>						<b>Sampled on 04/11/2017 0600</b>			
Sample Type: Drinking Fountain Facility ID: Room G2-RR Sample Point ID: Room G2									
<b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:38	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	1.6	ug/L	0.5	1
<b>1005-02 (201704170624)</b>						<b>Sampled on 04/11/2017 0605</b>			
Sample Type: Drinking Fountain Facility ID: Room G2 Sample Point ID: Room G2									
<b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:38	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	22	ug/L	0.5	1
<b>1007-01 A (201704170625)</b>						<b>Sampled on 04/11/2017 0610</b>			

Rounding on totals after summation.  
(c) - indicates calculated results

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data  
Report: 654025

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
04/17/2017 1147

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Sample Type: Drinking Fountain Facility ID: Room G8-G9 Sample Point ID: Room G9 <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:39	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>1007-01 B (201704170626)</u></b>						<b>Sampled on 04/11/2017 0610</b>			
Sample Type: Drinking Fountain Facility ID: Room G8-G9 Sample Point ID: Room G9 <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:40	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>1009-01 (201704170627)</u></b>						<b>Sampled on 04/11/2017 0615</b>			
Sample Type: Drinking Fountain Facility ID: Room 92 Sample Point ID: Room 92 <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:41	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>1009-02 (201704170628)</u></b>						<b>Sampled on 04/11/2017 0615</b>			
Sample Type: Tap Facility ID: Room 92 Sample Point ID: Art Room <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:41	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	9.7	ug/L	0.5	1
<b><u>1012-01 (201704170629)</u></b>						<b>Sampled on 04/11/2017 0720</b>			
Sample Type: Tap Facility ID: Ag Shop Sample Point ID: Ag Shop <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:42	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>1012-02 (201704170630)</u></b>						<b>Sampled on 04/11/2017 0720</b>			
Sample Type: Tap Facility ID: Ag Shop Sample Point ID: Ag Shop <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:46	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>1013-01 (201704170631)</u></b>						<b>Sampled on 04/11/2017 0635</b>			
Sample Type: Tap Facility ID: Maintenance Sample Point ID: Shop <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 12:47	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b><u>1013-02 (201704170632)</u></b>						<b>Sampled on 04/11/2017 0635</b>			



Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data  
Report: 654025

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
04/17/2017 1147

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Sample Type: Tap Facility ID: Maintenance Sample Point ID: Shop EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 12:48	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	1.0	ug/L	0.5	1
1014-01 (201704170633)						Sampled on 04/11/2017 0620			
Sample Type: Drinking Fountain Facility ID: Old Gym Sample Point ID: Old Gym EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 12:49	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1014-02 (201704170634)						Sampled on 04/11/2017 0620			
Sample Type: Drinking Fountain Facility ID: Old Gym Sample Point ID: Old Gym EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 12:49	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1015-01 (201704170635)						Sampled on 04/11/2017 0650			
Sample Type: Drinking Fountain Facility ID: Auto Shop Sample Point ID: Auto Shop EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 12:50	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1015-02 (201704170636)						Sampled on 04/11/2017 0650			
Sample Type: Tap Facility ID: Auto Shop Sample Point ID: Auto Shop EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 12:51	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	1.6	ug/L	0.5	1
1021-01 (201704170637)						Sampled on 04/11/2017 0645			
Sample Type: Drinking Fountain Facility ID: 72-88 Classroom Library Sample Point ID: #75 EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 12:52	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1021-02 (201704170638)						Sampled on 04/11/2017 0645			
Sample Type: Drinking Fountain Facility ID: 72-88 Sample Point ID: #78 EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 12:52	987352	988655	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1022-01 (201704170639)						Sampled on 04/11/2017 0630			

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data  
Report: 654025

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
04/17/2017 1147

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Sample Type: Drinking Fountain Facility ID: New Gym Sample Point ID: Lobby EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 12:58	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1022-02 (201704170640)						Sampled on 04/11/2017 0630			
Sample Type: Drinking Fountain Facility ID: New Gym Sample Point ID: Not Provided EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:00	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1023-01 (201704170641)						Sampled on 04/11/2017 0635			
Sample Type: Drinking Fountain Facility ID: Room 101-106 Sample Point ID: 101 EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:01	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1024-01 (201704170642)						Sampled on 04/11/2017 0730			
Sample Type: Drinking Fountain Facility ID: Locker Room Sample Point ID: Boys EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:02	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1024-02 (201704170643)						Sampled on 04/11/2017 0730			
Sample Type: Drinking Fountain Facility ID: Loccker Room Sample Point ID: Girls EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:03	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1025-01 (201704170644)						Sampled on 04/11/2017 0740			
Sample Type: Tap Facility ID: Laundry Sample Point ID: Only EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:05	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1025-02 (201704170645)						Sampled on 04/11/2017 0735			
Sample Type: Tap Facility ID: Laundry Sample Point ID: Only EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:06	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1028-01 (201704170646)						Sampled on 04/11/2017 0745			

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data  
Report: 654025

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
04/17/2017 1147

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Sample Type: Drinking Fountain Facility ID: Restrooms Sample Point ID: RR N <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 13:07	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1028-02 (201704170647)</b>						<b>Sampled on 04/11/2017 0745</b>			
Sample Type: Drinking Fountain Facility ID: Restrooms Sample Point ID: RR N <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 13:07	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1030-01 (201704170648)</b>						<b>Sampled on 04/11/2017 0600</b>			
Sample Type: Tap Facility ID: Bus Barn Sample Point ID: Not Provided <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 13:08	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	2.0	ug/L	0.5	1
<b>1030-02 (201704170649)</b>						<b>Sampled on 04/11/2017 0600</b>			
Sample Type: Tap Facility ID: Bus Barn Sample Point ID: Not Provided <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 13:09	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1033-01 (201704170650)</b>						<b>Sampled on 04/11/2017 0710</b>			
Sample Type: Tap Facility ID: District Office Sample Point ID: Center <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 13:11	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	1.2	ug/L	0.5	1
<b>1033-02 (201704170651)</b>						<b>Sampled on 04/11/2017 0710</b>			
Sample Type: Tap Facility ID: District Office Sample Point ID: Back <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 13:12	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	1.6	ug/L	0.5	1
<b>1034-01 (201704170652)</b>						<b>Sampled on 04/11/2017 0715</b>			
Sample Type: Tap Facility ID: Federal Sample Point ID: Only <b>EPA 200.8 - ICPMS Metals</b>									
04/18/17	04/21/17 13:15	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
<b>1034-02 (201704170653)</b>						<b>Sampled on 04/11/2017 0715</b>			

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory Data  
Report: 654025

**Arizona Department of Environmental Quality**  
David Burchard  
1110 West Washington Street  
Phoenix, AZ 85007

Samples Received on:  
04/17/2017 1147

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Sample Type: Tap Facility ID: Federal Sample Point ID: Only EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:15	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1035-01 (201704170654)						Sampled on 04/11/2017 0715			
Sample Type: Tap Facility ID: Business Office Sample Point ID: Only EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:16	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	0.94	ug/L	0.5	1
1035-02 (201704170655)						Sampled on 04/11/2017 0715			
Sample Type: Tap Facility ID: Business Office Sample Point ID: Only EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:17	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1036-01 (201704170656)						Sampled on 04/11/2017 0605			
Sample Type: Tap Facility ID: Mobile Home Sample Point ID: Kitchen EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:18	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1036-02 (201704170657)						Sampled on 04/11/2017 0605			
Sample Type: Tap Facility ID: Mobile Home Sample Point ID: Bath EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:19	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1037-01 (201704170658)						Sampled on 04/11/2017 0650			
Sample Type: Drinking Fountain Facility ID: Cafeteria Sample Point ID: Front EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:19	987352	988657	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	0.5	1
1038-01 (201704170659)						Sampled on 04/11/2017 0630			
Sample Type: Tap Facility ID: Green House Sample Point ID: Not Provided EPA 200.8 - ICPMS Metals									
04/18/17	04/21/17 13:25	987352	988662	(EPA 200.8)	Lead Total ICAP/MS	8.2	ug/L	0.5	1



Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Arizona Department of Environmental Quality

#### ICPMS Metals

**Prep Batch: 987352 Analytical Batch: 988653**

201704170618 K1001-001

**Analysis Date: 04/21/2017**

Analyzed by: RPD

#### ICPMS Metals

**Prep Batch: 987352 Analytical Batch: 988655**

201704170619	1001-01
201704170620	1001-02
201704170621	1004-01
201704170622	1004-02
201704170623	1005-01
201704170624	1005-02
201704170625	1007-01 A
201704170626	1007-01 B
201704170627	1009-01
201704170628	1009-02
201704170629	1012-01
201704170630	1012-02
201704170631	1013-01
201704170632	1013-02
201704170633	1014-01
201704170634	1014-02
201704170635	1015-01
201704170636	1015-02
201704170637	1021-01
201704170638	1021-02

**Analysis Date: 04/21/2017**

Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD

#### ICPMS Metals

**Prep Batch: 987352 Analytical Batch: 988657**

201704170639	1022-01
201704170640	1022-02
201704170641	1023-01
201704170642	1024-01
201704170643	1024-02
201704170644	1025-01
201704170645	1025-02
201704170646	1028-01
201704170647	1028-02
201704170648	1030-01
201704170649	1030-02
201704170650	1033-01
201704170651	1033-02
201704170652	1034-01
201704170653	1034-02
201704170654	1035-01
201704170655	1035-02
201704170656	1036-01

**Analysis Date: 04/21/2017**

Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD  
Analyzed by: RPD

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Arizona Department of Environmental Quality

---

201704170657	1036-02
201704170658	1037-01

Analyzed by: RPD  
Analyzed by: RPD

**ICPMS Metals**

**Prep Batch: 987352   Analytical Batch: 988662**

**Analysis Date: 04/21/2017**

201704170659	1038-01
--------------	---------

Analyzed by: RPD

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Laboratory QC  
Report: 654025

Arizona Department of Environmental Quality

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield (%)	Limits (%)	RPDLimit (%)	RPD%
<b>ICPMS Metals by EPA 200.8</b>									
<b>Analytical Batch: 988653</b>					<b>Analysis Date: 04/21/2017</b>				
LCS1	Lead Total ICAP/MS		20	20.2	ug/L	101	(85-115)		
LCS2	Lead Total ICAP/MS		20	20.2	ug/L	101	(85-115)	20	0.0
MBLK	Lead Total ICAP/MS			<0.25	ug/L				
MRL_CHK	Lead Total ICAP/MS		0.5	0.530	ug/L	106	(50-150)		
MS_201704140571	Lead Total ICAP/MS	2.1	20	23.2	ug/L	105	(70-130)		
MS2_201704170604	Lead Total ICAP/MS	3.5	20	25.6	ug/L	111	(70-130)		
MSD_201704140571	Lead Total ICAP/MS	2.1	20	23.5	ug/L	107	(70-130)	20	1.3
MSD2_201704170604	Lead Total ICAP/MS	3.5	20	25.2	ug/L	109	(70-130)	20	2.0
<b>ICPMS Metals by EPA 200.8</b>									
<b>Analytical Batch: 988655</b>					<b>Analysis Date: 04/21/2017</b>				
LCS1	Lead Total ICAP/MS		20	20.4	ug/L	102	(85-115)		
LCS2	Lead Total ICAP/MS		20	20.4	ug/L	102	(85-115)	20	0.0
MBLK	Lead Total ICAP/MS			<0.25	ug/L				
MRL_CHK	Lead Total ICAP/MS		0.5	0.526	ug/L	105	(50-150)		
MS_201704170619	Lead Total ICAP/MS	ND	20	22.4	ug/L	112	(70-130)		
MS2_201704170629	Lead Total ICAP/MS	ND	20	21.9	ug/L	110	(70-130)		
MSD_201704170619	Lead Total ICAP/MS	ND	20	22.3	ug/L	112	(70-130)	20	0.45
MSD2_201704170629	Lead Total ICAP/MS	ND	20	22.1	ug/L	111	(70-130)	20	0.91
<b>ICPMS Metals by EPA 200.8</b>									
<b>Analytical Batch: 988657</b>					<b>Analysis Date: 04/21/2017</b>				
LCS1	Lead Total ICAP/MS		20	20.3	ug/L	102	(85-115)		
LCS2	Lead Total ICAP/MS		20	20.5	ug/L	103	(85-115)	20	0.98
MBLK	Lead Total ICAP/MS			<0.25	ug/L				
MRL_CHK	Lead Total ICAP/MS		0.5	0.539	ug/L	108	(50-150)		
MS_201704170639	Lead Total ICAP/MS	ND	20	22.1	ug/L	110	(70-130)		
MS2_201704170649	Lead Total ICAP/MS	ND	20	22.2	ug/L	111	(70-130)		
MSD_201704170639	Lead Total ICAP/MS	ND	20	22.0	ug/L	110	(70-130)	20	0.45
MSD2_201704170649	Lead Total ICAP/MS	ND	20	22.1	ug/L	110	(70-130)	20	0.90
<b>ICPMS Metals by EPA 200.8</b>									
<b>Analytical Batch: 988662</b>					<b>Analysis Date: 04/21/2017</b>				
LCS1	Lead Total ICAP/MS		20	20.4	ug/L	102	(85-115)		
LCS2	Lead Total ICAP/MS		20	20.2	ug/L	101	(85-115)	20	0.99
MBLK	Lead Total ICAP/MS			<0.25	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100  
Fax: (626) 386-1101  
1 800 566 LABS (1 800 566 5227)

Arizona Department of Environmental Quality

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield (%)	Limits (%)	RPDLimit (%)	RPD%
MRL_CHK	Lead Total ICAP/MS		0.5	0.537	ug/L	107	(50-150)		
MS_201704170659	Lead Total ICAP/MS	8.2	20	30.5	ug/L	111	(70-130)		
MS2_201704190906	Lead Total ICAP/MS	16	20	37.3	ug/L	106	(70-130)		
MSD_201704170659	Lead Total ICAP/MS	8.2	20	29.8	ug/L	108	(70-130)	20	2.3
MSD2_201704190906	Lead Total ICAP/MS	16	20	37.3	ug/L	107	(70-130)	20	0.0

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.