


Scottsdale Unified
 SCHOOL DISTRICT
 Cochise Elementary School
 New Blueprint Work, E/F
 TMA Systems July 28, 2009



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73256

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Date Sampled: 03/07/2017

Time Sampled: 06:50

Date Received: 03/07/2017

Report Date: 04/12/2017


Sample ID: AH17-0509

Location ID: Lead in Schools

Location Description:

Cochise Elem- Bldg A Nurse DF- A

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	3.6		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73257

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Date Sampled: 03/07/2017

Time Sampled: 06:52

Date Received: 03/07/2017

Report Date: 04/12/2017


Sample ID: AH17-0510

Location Description:

Location ID: Lead in Schools

Cochise Elem- Bldg E Library DF- B

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73258

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0511

Location ID: Lead in Schools

Date Sampled: 03/07/2017

Time Sampled: 06:54


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Cochise Elem- Bldg B Outdoor DF- C

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73259

Date Sampled: 03/07/2017

Time Sampled: 06:56

Date Received: 03/07/2017

Report Date: 04/12/2017

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0512

Location Description:

Location ID: Lead in Schools

Cochise Elem- Bldg A PreK DF- D

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	1.1		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73260

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0513

Location ID: Lead in Schools

Date Sampled: 03/07/2017

Time Sampled: 06:58


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Cochise Elem- Bldg C Outdoor DF- E

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	< 1.0		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424



Water Quality Laboratory

8787 E. Hualapai Dr.
PO Box 25089
Scottsdale, AZ 85255

- CERTIFICATE OF ANALYSIS -

Lab # AB73261

Krystal Heyer

City of Scottsdale

8787 E. Hualapai Drive

Scottsdale, AZ 85255

Sample ID: AH17-0514

Location ID: Lead in Schools

Date Sampled: 03/07/2017

Time Sampled: 07:00


Date Received: 03/07/2017

Report Date: 04/12/2017

Location Description:

Cochise Elem- Bldg D Kitchen Sink- F

Test	Method	Result	Data Qualifier	DF	Units	PQL	Analysis Date
Lead, Pb	EPA 200.8	4.5		1.00	ug/L	1.0	04/06/2017


Authorized Signature
License #AZ0424