

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Phoenix

4625 East Cotton Ctr Blvd

Suite 189

Phoenix, AZ 85040

Tel: (602)437-3340

TestAmerica Job ID: 550-79645-1

TestAmerica Sample Delivery Group: Payson High School

Client Project/Site: Pb in DW/Payson Unified School District

For:

Arizona Dept of Environmental Quality

1110 W. Washington St., MC5415B-1

Phoenix, Arizona 85007

Attn: David A Burchard



Authorized for release by:

4/6/2017 3:28:43 PM

Jannel Franklin, Project Manager I

(732)593-2551

jannel.franklin@testamericainc.com

Designee for

Susan Armijo, Project Manager II

(602)659-7664

susan.armijo@testamericainc.com

LINKS

Review your project
results through

TotalAccess

Have a Question?



Visit us at:

www.testamericainc.com

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Table of Contents

Cover Page	1
Table of Contents	2
Definitions/Glossary	3
Case Narrative	4
Sample Summary	5
Detection Summary	6
Client Sample Results	9
QC Sample Results	13
QC Association Summary	16
Lab Chronicle	19
Certification Summary	24
Method Summary	25
Chain of Custody	26
Receipt Checklists	56



Definitions/Glossary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Case Narrative

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Job ID: 550-79645-1

Laboratory: TestAmerica Phoenix

Narrative

Job Narrative 550-79645-1

Comments

No additional comments.

Receipt

The samples were received on 3/22/2017 10:00 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 21.9° C.

Receipt Exceptions

The following samples for metals were received unpreserved and were preserved upon receipt to the laboratory: PHS /SL-01 (550-79645-1), PHS /W-01 (550-79645-2), PHS /M-01 (550-79645-3), PHS /T-02 (550-79645-4), PHS /T-01 (550-79645-5), PHS /AG-01 (550-79645-6), PHS /Q-01 (550-79645-7), PHS /D-01 (550-79645-8), PHS /C-01 (550-79645-9), PHS /A-01 (550-79645-10), PHS /A-02 (550-79645-11), PHS /B-01 (550-79645-12), PHS /T-01 (550-79645-13), PHS /I-01 (550-79645-14), PHS /I-02 (550-79645-15), PHS /OG-02 (550-79645-16), PHS /OG-01 (550-79645-17), PHS /OG-03 (550-79645-18), PHS /F-02 (550-79645-19), PHS /F-01 (550-79645-20), PHS /SB-01 (550-79645-21), PHS /DM-01 (550-79645-22), PHS /DM-02 (550-79645-23), PHS /DM-03 (550-79645-24) and PHS /DM-04 (550-79645-25). Regulatory documents require a 24-hour waiting period from the time of the addition of the acid preservative to the time of digestion.

Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Sample Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
550-79645-1	PHS /SL-01	Drinking Water	03/21/17 06:43	03/22/17 10:00
550-79645-2	PHS /W-01	Drinking Water	03/21/17 06:37	03/22/17 10:00
550-79645-3	PHS /M-01	Drinking Water	03/21/17 06:10	03/22/17 10:00
550-79645-4	PHS /T-02	Drinking Water	03/21/17 06:20	03/22/17 10:00
550-79645-5	PHS /T-01	Drinking Water	03/21/17 06:16	03/22/17 10:00
550-79645-6	PHS /AG-01	Drinking Water	03/21/17 06:32	03/22/17 10:00
550-79645-7	PHS /Q-01	Drinking Water	03/21/17 06:44	03/22/17 10:00
550-79645-8	PHS /D-01	Drinking Water	03/21/17 06:40	03/22/17 10:00
550-79645-9	PHS /C-01	Drinking Water	03/21/17 06:37	03/22/17 10:00
550-79645-10	PHS /A-01	Drinking Water	03/21/17 06:22	03/22/17 10:00
550-79645-11	PHS /A-02	Drinking Water	03/21/17 06:23	03/22/17 10:00
550-79645-12	PHS /B-01	Drinking Water	03/21/17 06:25	03/22/17 10:00
550-79645-13	PHS /T-01	Drinking Water	03/21/17 06:30	03/22/17 10:00
550-79645-14	PHS /I-01	Drinking Water	03/21/17 06:33	03/22/17 10:00
550-79645-15	PHS /I-02	Drinking Water	03/21/17 06:35	03/22/17 10:00
550-79645-16	PHS /OG-02	Drinking Water	03/21/17 06:36	03/22/17 10:00
550-79645-17	PHS /OG-01	Drinking Water	03/21/17 06:37	03/22/17 10:00
550-79645-18	PHS /OG-03	Drinking Water	03/21/17 06:38	03/22/17 10:00
550-79645-19	PHS /F-02	Drinking Water	03/21/17 06:41	03/22/17 10:00
550-79645-20	PHS /F-01	Drinking Water	03/21/17 06:42	03/22/17 10:00
550-79645-21	PHS /SB-01	Drinking Water	03/21/17 06:47	03/22/17 10:00
550-79645-22	PHS /DM-01	Drinking Water	03/21/17 06:47	03/22/17 10:00
550-79645-23	PHS /DM-02	Drinking Water	03/21/17 06:45	03/22/17 10:00
550-79645-24	PHS /DM-03	Drinking Water	03/21/17 06:24	03/22/17 10:00
550-79645-25	PHS /DM-04	Drinking Water	03/21/17 06:27	03/22/17 10:00

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /SL-01

Lab Sample ID: 550-79645-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.6		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /W-01

Lab Sample ID: 550-79645-2

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.86		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /M-01

Lab Sample ID: 550-79645-3

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /T-02

Lab Sample ID: 550-79645-4

No Detections.

Client Sample ID: PHS /T-01

Lab Sample ID: 550-79645-5

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.7		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /AG-01

Lab Sample ID: 550-79645-6

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.88		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /Q-01

Lab Sample ID: 550-79645-7

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	25		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /D-01

Lab Sample ID: 550-79645-8

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.80		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /C-01

Lab Sample ID: 550-79645-9

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.6		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /A-01

Lab Sample ID: 550-79645-10

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.0		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /A-02

Lab Sample ID: 550-79645-11

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.69		0.50	ppb	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /B-01

Lab Sample ID: 550-79645-12

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /T-01

Lab Sample ID: 550-79645-13

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	27		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /I-01

Lab Sample ID: 550-79645-14

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.4		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /I-02

Lab Sample ID: 550-79645-15

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	19		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /OG-02

Lab Sample ID: 550-79645-16

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.7		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /OG-01

Lab Sample ID: 550-79645-17

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.8		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /OG-03

Lab Sample ID: 550-79645-18

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.7		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /F-02

Lab Sample ID: 550-79645-19

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.1		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /F-01

Lab Sample ID: 550-79645-20

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /SB-01

Lab Sample ID: 550-79645-21

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.3		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /DM-01

Lab Sample ID: 550-79645-22

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead								

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /DM-01 (Continued)

Lab Sample ID: 550-79645-22

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.8		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /DM-02

Lab Sample ID: 550-79645-23

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /DM-03

Lab Sample ID: 550-79645-24

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	24		0.50	ppb	1		200.8	Total/NA

Client Sample ID: PHS /DM-04

Lab Sample ID: 550-79645-25

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50	ppb	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /SL-01

Date Collected: 03/21/17 06:43

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-1

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		0.50	ppb		03/28/17 10:35	03/31/17 20:37	1

Client Sample ID: PHS /W-01

Date Collected: 03/21/17 06:37

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-2

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.86		0.50	ppb		03/28/17 10:35	03/31/17 20:35	1

Client Sample ID: PHS /M-01

Date Collected: 03/21/17 06:10

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-3

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3		0.50	ppb		03/28/17 10:35	03/31/17 20:33	1

Client Sample ID: PHS /T-02

Date Collected: 03/21/17 06:20

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-4

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/28/17 10:35	03/31/17 20:31	1

Client Sample ID: PHS /T-01

Date Collected: 03/21/17 06:16

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-5

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		0.50	ppb		03/28/17 10:35	03/31/17 20:29	1

Client Sample ID: PHS /AG-01

Date Collected: 03/21/17 06:32

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-6

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.88		0.50	ppb		03/28/17 10:35	03/31/17 20:47	1

Client Sample ID: PHS /Q-01

Date Collected: 03/21/17 06:44

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-7

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	25		0.50	ppb		03/28/17 10:35	03/31/17 20:45	1

TestAmerica Phoenix

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /D-01

Date Collected: 03/21/17 06:40

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-8

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.80		0.50	ppb		03/28/17 10:35	03/31/17 20:43	1

Client Sample ID: PHS /C-01

Date Collected: 03/21/17 06:37

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-9

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.6		0.50	ppb		03/28/17 10:35	03/31/17 20:41	1

Client Sample ID: PHS /A-01

Date Collected: 03/21/17 06:22

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-10

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.0		0.50	ppb		03/28/17 10:35	03/31/17 20:39	1

Client Sample ID: PHS /A-02

Date Collected: 03/21/17 06:23

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-11

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.69		0.50	ppb		03/28/17 10:23	03/31/17 18:16	1

Client Sample ID: PHS /B-01

Date Collected: 03/21/17 06:25

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-12

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50	ppb		03/28/17 10:23	03/31/17 18:14	1

Client Sample ID: PHS /T-01

Date Collected: 03/21/17 06:30

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-13

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	27		0.50	ppb		03/28/17 10:23	03/31/17 18:12	1

Client Sample ID: PHS /I-01

Date Collected: 03/21/17 06:33

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-14

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.4		0.50	ppb		03/28/17 10:23	03/31/17 18:10	1

TestAmerica Phoenix

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /I-02

Date Collected: 03/21/17 06:35

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-15

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	19		0.50	ppb		03/28/17 10:23	03/31/17 18:04	1

Client Sample ID: PHS /OG-02

Date Collected: 03/21/17 06:36

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-16

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		0.50	ppb		03/28/17 10:23	03/31/17 18:31	1

Client Sample ID: PHS /OG-01

Date Collected: 03/21/17 06:37

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-17

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		0.50	ppb		03/28/17 10:23	03/31/17 18:25	1

Client Sample ID: PHS /OG-03

Date Collected: 03/21/17 06:38

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-18

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		0.50	ppb		03/28/17 10:23	03/31/17 18:23	1

Client Sample ID: PHS /F-02

Date Collected: 03/21/17 06:41

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-19

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.1		0.50	ppb		03/28/17 10:29	03/31/17 19:19	1

Client Sample ID: PHS /F-01

Date Collected: 03/21/17 06:42

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-20

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50	ppb		03/28/17 10:29	03/31/17 19:17	1

Client Sample ID: PHS /SB-01

Date Collected: 03/21/17 06:47

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-21

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.3		0.50	ppb		03/28/17 10:29	03/31/17 19:38	1

TestAmerica Phoenix

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /DM-01

Date Collected: 03/21/17 06:47

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-22

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		0.50	ppb		03/28/17 10:29	03/31/17 19:36	1

Client Sample ID: PHS /DM-02

Date Collected: 03/21/17 06:45

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-23

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5		0.50	ppb		03/29/17 05:29	04/04/17 14:39	1

Client Sample ID: PHS /DM-03

Date Collected: 03/21/17 06:24

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-24

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	24		0.50	ppb		03/29/17 05:29	04/04/17 14:45	1

Client Sample ID: PHS /DM-04

Date Collected: 03/21/17 06:27

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-25

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50	ppb		03/29/17 05:29	04/04/17 14:46	1

QC Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 550-113419/1-A

Matrix: Water

Analysis Batch: 113812

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 113419

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/28/17 10:23	03/31/17 17:55	1

Lab Sample ID: LCS 550-113419/4-A

Matrix: Water

Analysis Batch: 113812

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 113419

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	91.6		ppb		92	85 - 115

Lab Sample ID: LCSD 550-113419/5-A

Matrix: Water

Analysis Batch: 113812

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 113419

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	100	88.8		ppb		89	85 - 115	3	20

Lab Sample ID: 550-79645-15 MS

Matrix: Drinking Water

Analysis Batch: 113812

Client Sample ID: PHS /I-02

Prep Type: Total/NA

Prep Batch: 113419

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	19		100	104		ppb		85	70 - 130

Lab Sample ID: 550-79645-15 MSD

Matrix: Drinking Water

Analysis Batch: 113812

Client Sample ID: PHS /I-02

Prep Type: Total/NA

Prep Batch: 113419

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	19		100	106		ppb		87	70 - 130	1	20

Lab Sample ID: MB 550-113420/1-A

Matrix: Water

Analysis Batch: 113814

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 113420

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/28/17 10:29	03/31/17 18:54	1

Lab Sample ID: LCS 550-113420/4-A

Matrix: Water

Analysis Batch: 113814

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 113420

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	102		ppb		102	85 - 115

Lab Sample ID: LCSD 550-113420/5-A

Matrix: Water

Analysis Batch: 113814

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 113420

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	100	97.3		ppb		97	85 - 115	5	20

TestAmerica Phoenix

QC Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Lab Sample ID: 550-79646-A-5-B MS
Matrix: Water
Analysis Batch: 113814

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 113420

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	5.4		100	101		ppb		95	70 - 130

Lab Sample ID: 550-79646-A-5-C MSD
Matrix: Water
Analysis Batch: 113814

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 113420

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	5.4		100	104		ppb		99	70 - 130	4	20

Lab Sample ID: MB 550-113422/1-A
Matrix: Water
Analysis Batch: 113813

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 113422

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/28/17 10:35	03/31/17 19:53	1

Lab Sample ID: LCS 550-113422/4-A
Matrix: Water
Analysis Batch: 113813

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 113422

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	105		ppb		105	85 - 115

Lab Sample ID: LCSD 550-113422/5-A
Matrix: Water
Analysis Batch: 113813

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 113422

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	100	104		ppb		104	85 - 115	1	20

Lab Sample ID: 550-79648-A-1-B MS
Matrix: Water
Analysis Batch: 113813

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 113422

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	1.7		100	102		ppb		100	70 - 130

Lab Sample ID: 550-79648-A-1-C MSD
Matrix: Water
Analysis Batch: 113813

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 113422

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	1.7		100	103		ppb		101	70 - 130	1	20

Lab Sample ID: MB 550-113481/1-A
Matrix: Water
Analysis Batch: 113999

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 113481

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/29/17 05:29	04/04/17 14:04	1

TestAmerica Phoenix

QC Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Method: 200.8 - Metals (ICP/MS) (Continued)

Lab Sample ID: LCS 550-113481/4-A
Matrix: Water
Analysis Batch: 113999

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 113481

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	97.7		ppb		98	85 - 115

Lab Sample ID: LCSD 550-113481/5-A
Matrix: Water
Analysis Batch: 113999

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 113481

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Lead	100	100		ppb		100	85 - 115	3	20

Lab Sample ID: 550-79670-A-21-B MS
Matrix: Water
Analysis Batch: 113999

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 113481

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	1.3		100	94.2		ppb		93	70 - 130

Lab Sample ID: 550-79670-A-21-C MSD
Matrix: Water
Analysis Batch: 113999

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 113481

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Lead	1.3		100	93.2		ppb		92	70 - 130	1	20

QC Association Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Metals

Prep Batch: 113419

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79645-11	PHS /A-02	Total/NA	Drinking Water	200.8	
550-79645-12	PHS /B-01	Total/NA	Drinking Water	200.8	
550-79645-13	PHS /T-01	Total/NA	Drinking Water	200.8	
550-79645-14	PHS /I-01	Total/NA	Drinking Water	200.8	
550-79645-15	PHS /I-02	Total/NA	Drinking Water	200.8	
550-79645-16	PHS /OG-02	Total/NA	Drinking Water	200.8	
550-79645-17	PHS /OG-01	Total/NA	Drinking Water	200.8	
550-79645-18	PHS /OG-03	Total/NA	Drinking Water	200.8	
MB 550-113419/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-113419/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-113419/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-79645-15 MS	PHS /I-02	Total/NA	Drinking Water	200.8	
550-79645-15 MSD	PHS /I-02	Total/NA	Drinking Water	200.8	

Prep Batch: 113420

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79645-19	PHS /F-02	Total/NA	Drinking Water	200.8	
550-79645-20	PHS /F-01	Total/NA	Drinking Water	200.8	
550-79645-21	PHS /SB-01	Total/NA	Drinking Water	200.8	
550-79645-22	PHS /DM-01	Total/NA	Drinking Water	200.8	
MB 550-113420/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-113420/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-113420/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-79646-A-5-B MS	Matrix Spike	Total/NA	Water	200.8	
550-79646-A-5-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

Prep Batch: 113422

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79645-1	PHS /SL-01	Total/NA	Drinking Water	200.8	
550-79645-2	PHS /W-01	Total/NA	Drinking Water	200.8	
550-79645-3	PHS /M-01	Total/NA	Drinking Water	200.8	
550-79645-4	PHS /T-02	Total/NA	Drinking Water	200.8	
550-79645-5	PHS /T-01	Total/NA	Drinking Water	200.8	
550-79645-6	PHS /AG-01	Total/NA	Drinking Water	200.8	
550-79645-7	PHS /Q-01	Total/NA	Drinking Water	200.8	
550-79645-8	PHS /D-01	Total/NA	Drinking Water	200.8	
550-79645-9	PHS /C-01	Total/NA	Drinking Water	200.8	
550-79645-10	PHS /A-01	Total/NA	Drinking Water	200.8	
MB 550-113422/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-113422/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-113422/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-79648-A-1-B MS	Matrix Spike	Total/NA	Water	200.8	
550-79648-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

Prep Batch: 113481

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79645-23	PHS /DM-02	Total/NA	Drinking Water	200.8	
550-79645-24	PHS /DM-03	Total/NA	Drinking Water	200.8	
550-79645-25	PHS /DM-04	Total/NA	Drinking Water	200.8	
MB 550-113481/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-113481/4-A	Lab Control Sample	Total/NA	Water	200.8	

TestAmerica Phoenix

QC Association Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Metals (Continued)

Prep Batch: 113481 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCSD 550-113481/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-79670-A-21-B MS	Matrix Spike	Total/NA	Water	200.8	
550-79670-A-21-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

Analysis Batch: 113812

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79645-11	PHS /A-02	Total/NA	Drinking Water	200.8	113419
550-79645-12	PHS /B-01	Total/NA	Drinking Water	200.8	113419
550-79645-13	PHS /T-01	Total/NA	Drinking Water	200.8	113419
550-79645-14	PHS /I-01	Total/NA	Drinking Water	200.8	113419
550-79645-15	PHS /I-02	Total/NA	Drinking Water	200.8	113419
550-79645-16	PHS /OG-02	Total/NA	Drinking Water	200.8	113419
550-79645-17	PHS /OG-01	Total/NA	Drinking Water	200.8	113419
550-79645-18	PHS /OG-03	Total/NA	Drinking Water	200.8	113419
MB 550-113419/1-A	Method Blank	Total/NA	Water	200.8	113419
LCS 550-113419/4-A	Lab Control Sample	Total/NA	Water	200.8	113419
LCSD 550-113419/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	113419
550-79645-15 MS	PHS /I-02	Total/NA	Drinking Water	200.8	113419
550-79645-15 MSD	PHS /I-02	Total/NA	Drinking Water	200.8	113419

Analysis Batch: 113813

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79645-1	PHS /SL-01	Total/NA	Drinking Water	200.8	113422
550-79645-2	PHS /W-01	Total/NA	Drinking Water	200.8	113422
550-79645-3	PHS /M-01	Total/NA	Drinking Water	200.8	113422
550-79645-4	PHS /T-02	Total/NA	Drinking Water	200.8	113422
550-79645-5	PHS /T-01	Total/NA	Drinking Water	200.8	113422
550-79645-6	PHS /AG-01	Total/NA	Drinking Water	200.8	113422
550-79645-7	PHS /Q-01	Total/NA	Drinking Water	200.8	113422
550-79645-8	PHS /D-01	Total/NA	Drinking Water	200.8	113422
550-79645-9	PHS /C-01	Total/NA	Drinking Water	200.8	113422
550-79645-10	PHS /A-01	Total/NA	Drinking Water	200.8	113422
MB 550-113422/1-A	Method Blank	Total/NA	Water	200.8	113422
LCS 550-113422/4-A	Lab Control Sample	Total/NA	Water	200.8	113422
LCSD 550-113422/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	113422
550-79648-A-1-B MS	Matrix Spike	Total/NA	Water	200.8	113422
550-79648-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	113422

Analysis Batch: 113814

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79645-19	PHS /F-02	Total/NA	Drinking Water	200.8	113420
550-79645-20	PHS /F-01	Total/NA	Drinking Water	200.8	113420
550-79645-21	PHS /SB-01	Total/NA	Drinking Water	200.8	113420
550-79645-22	PHS /DM-01	Total/NA	Drinking Water	200.8	113420
MB 550-113420/1-A	Method Blank	Total/NA	Water	200.8	113420
LCS 550-113420/4-A	Lab Control Sample	Total/NA	Water	200.8	113420
LCSD 550-113420/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	113420
550-79646-A-5-B MS	Matrix Spike	Total/NA	Water	200.8	113420
550-79646-A-5-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	113420

TestAmerica Phoenix

QC Association Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Metals (Continued)

Analysis Batch: 113999

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-79645-23	PHS /DM-02	Total/NA	Drinking Water	200.8	113481
550-79645-24	PHS /DM-03	Total/NA	Drinking Water	200.8	113481
550-79645-25	PHS /DM-04	Total/NA	Drinking Water	200.8	113481
MB 550-113481/1-A	Method Blank	Total/NA	Water	200.8	113481
LCS 550-113481/4-A	Lab Control Sample	Total/NA	Water	200.8	113481
LCSD 550-113481/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	113481
550-79670-A-21-B MS	Matrix Spike	Total/NA	Water	200.8	113481
550-79670-A-21-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	113481

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /SL-01

Date Collected: 03/21/17 06:43

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-1

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:37	TEK	TAL PHX

Client Sample ID: PHS /W-01

Date Collected: 03/21/17 06:37

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-2

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:35	TEK	TAL PHX

Client Sample ID: PHS /M-01

Date Collected: 03/21/17 06:10

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-3

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:33	TEK	TAL PHX

Client Sample ID: PHS /T-02

Date Collected: 03/21/17 06:20

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-4

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:31	TEK	TAL PHX

Client Sample ID: PHS /T-01

Date Collected: 03/21/17 06:16

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-5

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:29	TEK	TAL PHX

Client Sample ID: PHS /AG-01

Date Collected: 03/21/17 06:32

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-6

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:47	TEK	TAL PHX

TestAmerica Phoenix

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /Q-01

Date Collected: 03/21/17 06:44

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-7

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:45	TEK	TAL PHX

Client Sample ID: PHS /D-01

Date Collected: 03/21/17 06:40

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-8

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:43	TEK	TAL PHX

Client Sample ID: PHS /C-01

Date Collected: 03/21/17 06:37

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-9

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:41	TEK	TAL PHX

Client Sample ID: PHS /A-01

Date Collected: 03/21/17 06:22

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-10

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113422	03/28/17 10:35	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113813	03/31/17 20:39	TEK	TAL PHX

Client Sample ID: PHS /A-02

Date Collected: 03/21/17 06:23

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-11

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113419	03/28/17 10:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113812	03/31/17 18:16	TEK	TAL PHX

Client Sample ID: PHS /B-01

Date Collected: 03/21/17 06:25

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-12

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113419	03/28/17 10:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113812	03/31/17 18:14	TEK	TAL PHX

TestAmerica Phoenix

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /T-01

Date Collected: 03/21/17 06:30

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-13

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113419	03/28/17 10:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113812	03/31/17 18:12	TEK	TAL PHX

Client Sample ID: PHS /I-01

Date Collected: 03/21/17 06:33

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-14

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113419	03/28/17 10:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113812	03/31/17 18:10	TEK	TAL PHX

Client Sample ID: PHS /I-02

Date Collected: 03/21/17 06:35

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-15

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113419	03/28/17 10:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113812	03/31/17 18:04	TEK	TAL PHX

Client Sample ID: PHS /OG-02

Date Collected: 03/21/17 06:36

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-16

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113419	03/28/17 10:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113812	03/31/17 18:31	TEK	TAL PHX

Client Sample ID: PHS /OG-01

Date Collected: 03/21/17 06:37

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-17

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113419	03/28/17 10:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113812	03/31/17 18:25	TEK	TAL PHX

Client Sample ID: PHS /OG-03

Date Collected: 03/21/17 06:38

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-18

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113419	03/28/17 10:23	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113812	03/31/17 18:23	TEK	TAL PHX

TestAmerica Phoenix

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /F-02

Date Collected: 03/21/17 06:41

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-19

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113420	03/28/17 10:29	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113814	03/31/17 19:19	TEK	TAL PHX

Client Sample ID: PHS /F-01

Date Collected: 03/21/17 06:42

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-20

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113420	03/28/17 10:29	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113814	03/31/17 19:17	TEK	TAL PHX

Client Sample ID: PHS /SB-01

Date Collected: 03/21/17 06:47

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-21

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113420	03/28/17 10:29	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113814	03/31/17 19:38	TEK	TAL PHX

Client Sample ID: PHS /DM-01

Date Collected: 03/21/17 06:47

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-22

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113420	03/28/17 10:29	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113814	03/31/17 19:36	TEK	TAL PHX

Client Sample ID: PHS /DM-02

Date Collected: 03/21/17 06:45

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-23

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113481	03/29/17 05:29	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113999	04/04/17 14:39	TEK	TAL PHX

Client Sample ID: PHS /DM-03

Date Collected: 03/21/17 06:24

Date Received: 03/22/17 10:00

Lab Sample ID: 550-79645-24

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113481	03/29/17 05:29	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113999	04/04/17 14:45	TEK	TAL PHX

TestAmerica Phoenix

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Client Sample ID: PHS /DM-04

Lab Sample ID: 550-79645-25

Date Collected: 03/21/17 06:27

Matrix: Drinking Water

Date Received: 03/22/17 10:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			113481	03/29/17 05:29	SGO	TAL PHX
Total/NA	Analysis	200.8		1	113999	04/04/17 14:46	TEK	TAL PHX

Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

Accreditation/Certification Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Laboratory: TestAmerica Phoenix

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	EPA Region	Identification Number	Expiration Date
Arizona	State Program	9	AZ0728	06-09-17

Analysis Method	Prep Method	Matrix	Analyte
-----------------	-------------	--------	---------

Method Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW/Payson Unified School District

TestAmerica Job ID: 550-79645-1
SDG: Payson High School

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	TAL PHX

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:


TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

79645

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.


- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	STEM LAB
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/SL-01
Date of Collection	3/21/17
Time of Collection	6:43 AM
Printed Name of Sample Collector	ROBERT WILCOX
Signature Sample Collector	

550-79645 Chain of Custody



Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	3-22-16 1000
Signature	
Notes: 21.9°C NO LCB FFE Ar	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


①

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAULSEN UNIFIED SCHOOL DISTRICT #10
School Name	PAULSEN HIGH SCHOOL
Building (name/number)	AUTOS/WOODSHOP
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	O/S OF BATHROOMS
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/W -01
Date of Collection	3/21/17
Time of Collection	6:37 am
Printed Name of Sample Collector	ROBERT WILCOX
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

②


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	MAINTENANCE/WAREHOUSE
Type of Fixture (tap, drinking fountain etc.)	BOTTLE FILLER
Location of Fixture (example, room number)	MAINTENANCE SHOP
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/M - 01
Date of Collection	2/21/17
Time of Collection	6:10 AM
Printed Name of Sample Collector	ROBERT WILCOX
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

③


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	TRANSPORTATION
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	OFFICES
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/T-02
Date of Collection	3/21/17
Time of Collection	6:20 AM
Printed Name of Sample Collector	MARSHALL MARTIN
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

④


1
2
3
4
5
6
7
8
9
10
11
12
13
14

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PAISON UNIFIED SCHOOL DISTRICT #10
School Name	PAISON HIGH SCHOOL
Building (name/number)	TRANSPORTATION
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	GARAGE/SHOP
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/T - 01
Date of Collection	3/21/17
Time of Collection	6:16
Printed Name of Sample Collector	ROBERT WILCOX
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____




These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PRYSON UNITED SCHOOL DISTRICT #10
School Name	PRYSON HIGH SCHOOL
Building (name/number)	AG BUILDING
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/AG-01
Date of Collection	3/21/17
Time of Collection	6:32 am
Printed Name of Sample Collector	ROBERT WILCOX
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

6


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PRYSON UNIFIED SCHOOL DISTRICT #10
School Name	PRYSON HIGH SCHOOL
Building (name/number)	QUAD BUILDING
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/Q-01
Date of Collection	03-21-2017
Time of Collection	0644
Printed Name of Sample Collector	MARTIN MARTIN
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____




These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	RAYSON UNIFIED SCHOOL DISTRICT #10
School Name	RAYSON HIGH SCHOOL
Building (name/number)	D BUILDING
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CAFETERIA
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/D-01
Date of Collection	03-21-2017
Time of Collection	0640
Printed Name of Sample Collector	MARSHALL MARTIN
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____




These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	C BUILDING
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/C-01
Date of Collection	03-21-2017
Time of Collection	0637
Printed Name of Sample Collector	MARSHALL MARTIN
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

9


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PRISON UNITED SCHOOL DISTRICT #10
School Name	PRISON HIGH SCHOOL
Building (name/number)	A BUILDING
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	"OLD MAIN" A3
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/A - 01
Date of Collection	March 21
Time of Collection	6:22 am
Printed Name of Sample Collector	JAMES LOGAN
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

10


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	A BUILDING / ADDITION / ADMIN
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	NURSE'S OFFICE
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/A-02
Date of Collection	March 21
Time of Collection	6:23 AM
Printed Name of Sample Collector	James Lazzarini
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

11


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PRAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PRAYSON HIGH SCHOOL
Building (name/number)	B BUILDING
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	HALLWAY
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/B-01
Date of Collection	MARCH 21
Time of Collection	6:25 AM
Printed Name of Sample Collector	JAMES LEONARD
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

12

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PRYSON UNIFIED SCHOOL DISTRICT #10
School Name	PRYSON HIGH SCHOOL
Building (name/number)	BUILDING T - TECH DEPT
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/T-01
Date of Collection	March 21
Time of Collection	6:30 AM
Printed Name of Sample Collector	JAMES HERRINGTON
Signature Sample Collector	James R

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

(B)


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	AUDITORIUM
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	LOBBY
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/I-01
Date of Collection	March 21
Time of Collection	6:33 am
Printed Name of Sample Collector	JAMES LOANSON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

19


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PRYSEN UNIFIED SCHOOL DISTRICT #10
School Name	PRYSEN HIGH SCHOOL
Building (name/number)	AUDITORIUM (THEATRE BATHS)
Type of Fixture (tap, drinking fountain etc.)	
Location of Fixture (example, room number)	AUDITORIUM DRESSING ROOMS
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/I-02
Date of Collection	March 21
Time of Collection	6:35 AM
Printed Name of Sample Collector	Juanita Lopez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


15

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	OLD GYM
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	BATHROOM LOBBY
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/OG-02
Date of Collection	March 21
Time of Collection	6:36 am
Printed Name of Sample Collector	JAMES L. HARRISON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


110

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	OLD GYM
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	VARSITY LOCKER RM
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/OG-01
Date of Collection	March 21
Time of Collection	6:57 AM
Printed Name of Sample Collector	James Lawrence
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


(17)

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PRYSON UNIFIED SCHOOL DISTRICT #10
School Name	PRYSON HIGH SCHOOL
Building (name/number)	OLD GYM
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	TRAINING ROOM
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/OG-03
Date of Collection	March 21
Time of Collection	6:38 AM
Printed Name of Sample Collector	Jamie L. Brown
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

18


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	RAYSON UNIFIED SCHOOL DISTRICT #10
School Name	RAYSON HIGH SCHOOL
Building (name/number)	TRACK SHACK
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	EXTERIOR, FOOTBALL FIELD
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/F-02
Date of Collection	March 21
Time of Collection	6:41 am
Printed Name of Sample Collector	James Garza
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


19

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	FOOTBALL RESTROOMS
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EXTERIOR
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/F-01
Date of Collection	March 21
Time of Collection	6:42 AM
Printed Name of Sample Collector	James Larson
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.




Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	BASEBALL SNACK BAR
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	SNACK BAR
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	PHS/SB-01
Date of Collection	March 21
Time of Collection	6:47 AM
Printed Name of Sample Collector	Thomas Harrison
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

21

ALSO Four More!

(22)

PHS / DM -01

3-21-17 0647

(23)

PHS / DM -02

3-21-17 0645

(24)

PHS / DM -03

3-21-17 0624

(25)

PHS / DM -04


3-21-17 0627

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	DOMES
Type of Fixture (tap, drinking fountain etc.)	N/A
Location of Fixture (example, room number)	SE DOME ENTRY
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	N/A
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	ROBERT WILCOX
Signature Sample Collector	

Notes Sample collector:	NO WATER @ THIS ENTRANCE
-------------------------	--------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	PAYSON UNIFIED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	IN-SCHOOL-SUSPENSION
Type of Fixture (tap, drinking fountain etc.)	N/A
Location of Fixture (example, room number)	N/A
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	N/A
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	ROBERT WILCOX
Signature Sample Collector	

Notes Sample collector: THIS BUILDING NO LONGER EXISTS

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PARSON UNITED SCHOOL DISTRICT #10
School Name	PARSON HIGH SCHOOL
Building (name/number)	EAST WING (REPLACED)
Type of Fixture (tap, drinking fountain etc.)	N/A
Location of Fixture (example, room number)	N/A
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	N/A
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	ROBERT WILCOX
Signature Sample Collector	

Notes Sample collector: BUILDING NO LONGER EXISTS

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	PAYSON UNITED SCHOOL DISTRICT #10
School Name	PAYSON HIGH SCHOOL
Building (name/number)	BLACK BOX THEATRE
Type of Fixture (tap, drinking fountain etc.)	NO WATER -
Location of Fixture (example, room number)	N/A
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	N/A
Date of Collection	
Time of Collection	
Printed Name of Sample Collector	ROBERT N WILCOX
Signature Sample Collector	

Notes Sample collector: NO WATER @ THIS BUILDING

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Payson Unified District
ATTN: Leslie Herdeman/Maintenance Department
409 W. Longhorn Road
Payson, AZ 85541

Payson Unified District	Payson High School	1001	Softball Snack Bar, Restrooms	SINK Restrooms	1986	P O Box 919	Payson	85547-0919	Gila	440 sq FT	2
Payson Unified District	Payson High School	1002	OLD Gym ? Varsity Locker Room	SINK Restrooms	1986	P O Box 919	Payson	85547-0919	Gila		2
Payson Unified District	Payson High School	1003	LOBBY Old Gym	FOUNTAIN Gymnasium	1967	P O Box 919	Payson	85547-0919	Gila		2
Payson Unified District	Payson High School	1004	WEIGHTS/ TRAINING Rm Wrestling Room	Gymnasium	1974	P O Box 919	Payson	85547-0919	Gila		2
Payson Unified District	Payson High School	1005	AUDITORIUM Dressing Rooms Theater Restrooms	Restrooms	1999	P O Box 919	Payson	85547-0919	Gila	469 sq FT	1
Payson Unified District	Payson High School	1006	Maintenance, Warehouse	FOUNTAIN District Administration	1987	P O Box 919	Payson	85547-0919	Gila		2
Payson Unified District	Payson High School	1007	GARAGE Transportation	SINK District Administration	1973	P O Box 919	Payson	85547-0919	Gila		2
Payson Unified District	Payson High School	1008	GARAGE OFFICES Transportation-2	FOUNTAIN District Administration	1990	P O Box 919	Payson	85547-0919	Gila		1
Payson Unified District	Payson High School	1009	LOBBY Auditorium	FOUNTAIN Auditorium	1986	P O Box 919	Payson	85547-0919	Gila		2
Payson Unified District	Payson High School	1010	SW CORNER Football Restrooms	FOUNTAIN Restrooms	1985	P O Box 919	Payson	85547-0919	Gila		2

Payson Unified District	Payson High School	1011	ADDITIONAL ATHLETIC STORAGE FOOTBALL FIELD TRACK SHACK	Storage	1986	P O Box 919	Payson	85547-0919	Gila	2
Payson Unified District	Payson High School	1012	Black Box Theatre	Classroom	1999	P O Box 919	Payson	85547-0919	Gila	NO WATER 1
Payson Unified District	Payson High School	1013	Autos/Woodshop Vocational Education	Classroom, Shop	1981	P O Box 919	Payson	85547-0919	7201 sq ft Gila	2
Payson Unified District	Payson High School	1014	TRAINING RM Multi-Purpose Dome	Gymnasium	1996	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1015	ADMIN BLDG A-BUILDING Principals Building	IT BUILDING Administration	1987	P O Box 919	Payson	85547-0919	1724 sq ft Gila	2
Payson Unified District	Payson High School	1016	MAIN A-BUILDING Old Main	Classroom	1965	P O Box 919	Payson	85547-0919	Gila	2
Payson Unified District	Payson High School	1017	QUAD? Coaches Storage	Storage	1982	P O Box 919	Payson	85547-0919	957 sq ft Gila	2
Payson Unified District	Payson High School	1018	STEM LAB CADD Lab	Classroom	1995	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1019	C Building	Classroom	1995	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1020	East Wing - REPLACED	OLD AG Classroom	1958	P O Box 919	Payson	85547-0919	0 sq ft Gila	NO WATER 2

Payson Unified District	Payson High School	1023	In-School Suspension - REPLACED	Classroom	1984	P O Box 919	Payson	85547-0919	0 SC FT Gila	NO WATER 2
Payson Unified District	Payson High School	1024	B-BUILDING	Classroom	1985	P O Box 919	Payson	85547-0919	Gila	2
Payson Unified District	Payson High School	1030	NE Dome Entry	FOUNTAIN North/East Entry	2003	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1031	NW Dome Entry	North/West Entry	2003	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1032	SE Dome Entry	South/East Entry	2003	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1033	SW Dome Entry	FOUNTAIN South/West Entry	2003	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1034	D-BUILDING or FOUNTAIN SINK CF Building	Cafeteria / Classrooms	2003	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1035	A-BUILDING Addition to Old Main	Bookstore, restrooms, offices	2006	P O Box 919	Payson	85547-0919	Gila	1
Payson Unified District	Payson High School	1036	AG CTE Building	Agriculture	2011	P O Box 919	Payson	85547-0919	Gila	1
Total Containers										45

Login Sample Receipt Checklist

Client: Arizona Dept of Environmental Quality

Job Number: 550-79645-1

SDG Number: Payson High School

Login Number: 79645

List Number: 1

Creator: Vilaboy, Monica

List Source: TestAmerica Phoenix

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	Check done at department level as required.