

TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Phoenix

4625 East Cotton Ctr Blvd

Suite 189

Phoenix, AZ 85040

Tel: (602)437-3340

TestAmerica Job ID: 550-84901-1

TestAmerica SDG: Alternative Center, Intermediate, & Rice School

Client Project/Site: Pb in DW / San Carlos Unified District


For:

Arizona Dept of Environmental Quality

1110 W. Washington St., MC5415B-1

Phoenix, Arizona 85007

Attn: David A Burchard



Authorized for release by:

6/29/2017 3:50:45 PM

Sarah Arney, Project Manager I

(602)437-3340

sarah.arney@testamericainc.com

LINKS

Review your project results through

TotalAccess

Have a Question?



Visit us at:

www.testamericainc.com

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14



Table of Contents

Cover Page	1
Table of Contents	2
Definitions/Glossary	3
Case Narrative	4
Sample Summary	5
Detection Summary	6
Client Sample Results	8
QC Sample Results	10
QC Association Summary	11
Lab Chronicle	12
Certification Summary	14
Method Summary	15
Chain of Custody	16
Receipt Checklists	27

Definitions/Glossary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

Case Narrative

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Job ID: 550-84901-1

Laboratory: TestAmerica Phoenix

Narrative

Job Narrative 550-84901-1

Comments

No additional comments.

Receipt

The samples were received on 6/23/2017 10:30 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 35.6° C.

Receipt Exceptions

The following samples for metals were received unpreserved and were preserved upon receipt to the laboratory: A-1 (550-84901-1), C-02 (550-84901-2), C-01 (550-84901-3), K-1 (550-84901-4), R01 (550-84901-5), R02 (550-84901-6), R03 (550-84901-7), R04 (550-84901-8), R07 (550-84901-9), R06 (550-84901-10) and R05 (550-84901-11). Regulatory documents require a 24-hour waiting period from the time of the addition of the acid preservative to the time of digestion.

Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Sample Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
550-84901-1	A-1	Water	06/22/17 07:45	06/23/17 10:30
550-84901-2	C-02	Water	06/22/17 06:12	06/23/17 10:30
550-84901-3	C-01	Water	06/22/17 06:10	06/23/17 10:30
550-84901-4	K-1	Water	06/22/17 06:30	06/23/17 10:30
550-84901-5	R01	Water	06/22/17 06:40	06/23/17 10:30
550-84901-6	R02	Water	06/22/17 06:35	06/23/17 10:30
550-84901-7	R03	Water	06/22/17 07:02	06/23/17 10:30
550-84901-8	R04	Water	06/22/17 07:10	06/23/17 10:30
550-84901-9	R07	Water	06/22/17 07:20	06/23/17 10:30
550-84901-10	R06	Water	06/22/17 07:30	06/23/17 10:30
550-84901-11	R05	Water	06/22/17 07:40	06/23/17 10:30

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Client Sample ID: A-1

Lab Sample ID: 550-84901-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.6		0.50	ppb	1		200.8	Total/NA

Client Sample ID: C-02

Lab Sample ID: 550-84901-2

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.69		0.50	ppb	1		200.8	Total/NA

Client Sample ID: C-01

Lab Sample ID: 550-84901-3

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.2		0.50	ppb	1		200.8	Total/NA

Client Sample ID: K-1

Lab Sample ID: 550-84901-4

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50	ppb	1		200.8	Total/NA

Client Sample ID: R01

Lab Sample ID: 550-84901-5

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.70		0.50	ppb	1		200.8	Total/NA

Client Sample ID: R02

Lab Sample ID: 550-84901-6

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50	ppb	1		200.8	Total/NA

Client Sample ID: R03

Lab Sample ID: 550-84901-7

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	15		0.50	ppb	1		200.8	Total/NA

Client Sample ID: R04

Lab Sample ID: 550-84901-8

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.7		0.50	ppb	1		200.8	Total/NA

Client Sample ID: R07

Lab Sample ID: 550-84901-9

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50	ppb	1		200.8	Total/NA

Client Sample ID: R06

Lab Sample ID: 550-84901-10

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.68		0.50	ppb	1		200.8	Total/NA

Client Sample ID: R05

Lab Sample ID: 550-84901-11

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

Detection Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Client Sample ID: R05 (Continued)

Lab Sample ID: 550-84901-11

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.58		0.50	ppb	1		200.8	Total/NA

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

This Detection Summary does not include radiochemical test results.

Client Sample Results

Client: Arizona Dept of Environmental Quality
 Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
 SDG: Alternative Center, Intermediate, & Rice School

Client Sample ID: A-1
 Date Collected: 06/22/17 07:45
 Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-1
 Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.6		0.50	ppb		06/26/17 06:32	06/28/17 19:15	1

Client Sample ID: C-02
 Date Collected: 06/22/17 06:12
 Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-2
 Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.69		0.50	ppb		06/26/17 06:32	06/28/17 19:16	1

Client Sample ID: C-01
 Date Collected: 06/22/17 06:10
 Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-3
 Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.2		0.50	ppb		06/26/17 06:32	06/28/17 19:18	1

Client Sample ID: K-1
 Date Collected: 06/22/17 06:30
 Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-4
 Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5		0.50	ppb		06/26/17 06:32	06/28/17 19:20	1

Client Sample ID: R01
 Date Collected: 06/22/17 06:40
 Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-5
 Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.70		0.50	ppb		06/26/17 06:32	06/28/17 19:26	1

Client Sample ID: R02
 Date Collected: 06/22/17 06:35
 Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-6
 Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50	ppb		06/26/17 06:32	06/28/17 19:28	1

Client Sample ID: R03
 Date Collected: 06/22/17 07:02
 Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-7
 Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15		0.50	ppb		06/26/17 06:32	06/28/17 19:29	1

Client Sample Results

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Client Sample ID: R04
Date Collected: 06/22/17 07:10
Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-8
Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		0.50	ppb		06/26/17 06:32	06/28/17 19:31	1

Client Sample ID: R07
Date Collected: 06/22/17 07:20
Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-9
Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50	ppb		06/26/17 06:32	06/28/17 19:33	1

Client Sample ID: R06
Date Collected: 06/22/17 07:30
Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-10
Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.68		0.50	ppb		06/26/17 06:32	06/28/17 19:35	1

Client Sample ID: R05
Date Collected: 06/22/17 07:40
Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-11
Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.58		0.50	ppb		06/26/17 06:32	06/28/17 19:37	1

QC Sample Results

Client: Arizona Dept of Environmental Quality
 Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
 SDG: Alternative Center, Intermediate, & Rice School

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 550-120824/1-A
Matrix: Water
Analysis Batch: 121182

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 120824

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		06/26/17 06:32	06/28/17 18:58	1

Lab Sample ID: LCS 550-120824/4-A
Matrix: Water
Analysis Batch: 121182

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 120824

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Lead	100	97.5		ppb		97	85 - 115

Lab Sample ID: LCSD 550-120824/5-A
Matrix: Water
Analysis Batch: 121182

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 120824

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Lead	100	99.4		ppb		99	85 - 115	2	20

Lab Sample ID: 550-84938-A-1-B MS
Matrix: Water
Analysis Batch: 121182

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 120824

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Lead	0.50		100	97.2		ppb		97	70 - 130

Lab Sample ID: 550-84938-A-1-C MSD
Matrix: Water
Analysis Batch: 121182

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 120824

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Lead	0.50		100	98.7		ppb		98	70 - 130	2	20

QC Association Summary

Client: Arizona Dept of Environmental Quality
 Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
 SDG: Alternative Center, Intermediate, & Rice School

Metals

Prep Batch: 120824

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-84901-1	A-1	Total/NA	Water	200.8	
550-84901-2	C-02	Total/NA	Water	200.8	
550-84901-3	C-01	Total/NA	Water	200.8	
550-84901-4	K-1	Total/NA	Water	200.8	
550-84901-5	R01	Total/NA	Water	200.8	
550-84901-6	R02	Total/NA	Water	200.8	
550-84901-7	R03	Total/NA	Water	200.8	
550-84901-8	R04	Total/NA	Water	200.8	
550-84901-9	R07	Total/NA	Water	200.8	
550-84901-10	R06	Total/NA	Water	200.8	
550-84901-11	R05	Total/NA	Water	200.8	
MB 550-120824/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-120824/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-120824/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-84938-A-1-B MS	Matrix Spike	Total/NA	Water	200.8	
550-84938-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

Analysis Batch: 121182

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-84901-1	A-1	Total/NA	Water	200.8	120824
550-84901-2	C-02	Total/NA	Water	200.8	120824
550-84901-3	C-01	Total/NA	Water	200.8	120824
550-84901-4	K-1	Total/NA	Water	200.8	120824
550-84901-5	R01	Total/NA	Water	200.8	120824
550-84901-6	R02	Total/NA	Water	200.8	120824
550-84901-7	R03	Total/NA	Water	200.8	120824
550-84901-8	R04	Total/NA	Water	200.8	120824
550-84901-9	R07	Total/NA	Water	200.8	120824
550-84901-10	R06	Total/NA	Water	200.8	120824
550-84901-11	R05	Total/NA	Water	200.8	120824
MB 550-120824/1-A	Method Blank	Total/NA	Water	200.8	120824
LCS 550-120824/4-A	Lab Control Sample	Total/NA	Water	200.8	120824
LCSD 550-120824/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	120824
550-84938-A-1-B MS	Matrix Spike	Total/NA	Water	200.8	120824
550-84938-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	120824

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Client Sample ID: A-1

Date Collected: 06/22/17 07:45

Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:15	TEK	TAL PHX

Client Sample ID: C-02

Date Collected: 06/22/17 06:12

Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:16	TEK	TAL PHX

Client Sample ID: C-01

Date Collected: 06/22/17 06:10

Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-3

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:18	TEK	TAL PHX

Client Sample ID: K-1

Date Collected: 06/22/17 06:30

Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-4

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:20	TEK	TAL PHX

Client Sample ID: R01

Date Collected: 06/22/17 06:40

Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-5

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:26	TEK	TAL PHX

Client Sample ID: R02

Date Collected: 06/22/17 06:35

Date Received: 06/23/17 10:30

Lab Sample ID: 550-84901-6

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:28	TEK	TAL PHX

Lab Chronicle

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Client Sample ID: R03

Lab Sample ID: 550-84901-7

Date Collected: 06/22/17 07:02

Matrix: Water

Date Received: 06/23/17 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:29	TEK	TAL PHX

Client Sample ID: R04

Lab Sample ID: 550-84901-8

Date Collected: 06/22/17 07:10

Matrix: Water

Date Received: 06/23/17 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:31	TEK	TAL PHX

Client Sample ID: R07

Lab Sample ID: 550-84901-9

Date Collected: 06/22/17 07:20

Matrix: Water

Date Received: 06/23/17 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:33	TEK	TAL PHX

Client Sample ID: R06

Lab Sample ID: 550-84901-10

Date Collected: 06/22/17 07:30

Matrix: Water

Date Received: 06/23/17 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:35	TEK	TAL PHX

Client Sample ID: R05

Lab Sample ID: 550-84901-11

Date Collected: 06/22/17 07:40

Matrix: Water

Date Received: 06/23/17 10:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			120824	06/26/17 06:32	SGO	TAL PHX
Total/NA	Analysis	200.8		1	121182	06/28/17 19:37	TEK	TAL PHX

Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

Accreditation/Certification Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School

Laboratory: TestAmerica Phoenix

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	EPA Region	Identification Number	Expiration Date
Arizona	State Program	9	AZ0728	06-09-18

Analysis Method	Prep Method	Matrix	Analyte
-----------------	-------------	--------	---------

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Method Summary

Client: Arizona Dept of Environmental Quality
Project/Site: Pb in DW / San Carlos Unified District

TestAmerica Job ID: 550-84901-1
SDG: Alternative Center, Intermediate, & Rice School


Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	TAL PHX

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340



84901

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	ALTERNATIVE
Building (name/number)	OFFICE BUILDING
Type of Fixture (tap, drinking fountain etc.)	WASH SINK
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	A-1
Date of Collection	6-27-2017
Time of Collection	7:45 AM
Printed Name of Sample Collector	C M HUMPHREY
Signature Sample Collector	C M HUMPHREY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	6/23/17 10:30
Signature	
Notes:	35.60 no ice



For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE
Building (name/number)	AUX. CAFETERIA
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CAFETERIA
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	C-02
Date of Collection	6-22-2017
Time of Collection	6:12 AM
Printed Name of Sample Collector	CM HUMPHREY
Signature Sample Collector	CM HUMPHREY


Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE
Building (name/number)	AUX. CAFETERIA
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	KITCHEN AREA
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	C-01
Date of Collection	6-22-2017
Time of Collection	6:10 AM
Printed Name of Sample Collector	CM HUMPHREY
Signature Sample Collector	CM HUMPHREY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	KINDER BUILDING
Building (name/number)	MAIN BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 118
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	K-1
Date of Collection	6-22-2017
Time of Collection	6:30 AM
Printed Name of Sample Collector	CM HUMPHREY
Signature Sample Collector	CM HUMPHREY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE (MAIN BUILDING)
Building (name/number)	INTERMEDIATE
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 120
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	201
Date of Collection	6-22-2017
Time of Collection	6:40 AM
Printed Name of Sample Collector	CM HUMPHREY
Signature Sample Collector	CM HUMPHREY


Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE (MAIN BUILDING)
Building (name/number)	INTERMEDIATE
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CAFETERIA
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	202
Date of Collection	6-22-2017
Time of Collection	6:35 AM
Printed Name of Sample Collector	CM HUMPHREY
Signature Sample Collector	CM HUMPHREY


Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE (Gym)
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	GYMNASIUM
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	203
Date of Collection	6-27-2017
Time of Collection	7:02 AM
Printed Name of Sample Collector	CM HUMPHREY
Signature Sample Collector	CM HUMPHREY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE (Gym)
Building (name/number)	
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 117
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	R04
Date of Collection	6-22-2017
Time of Collection	7:10 AM
Printed Name of Sample Collector	C M HUMPHREY
Signature Sample Collector	C M HUMPHREY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE (BUILDING B)
Building (name/number)	BUILDING B
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	EAST HALL WAY
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	R07
Date of Collection	6-22-2017
Time of Collection	7:20 AM
Printed Name of Sample Collector	C M HUMPHREY
Signature Sample Collector	C M HUMPHREY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE (BUILDING A)
Building (name/number)	BUILDING A
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 128
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	206
Date of Collection	6-22-2011
Time of Collection	7:30 AM
Printed Name of Sample Collector	C M HUMPHREY
Signature Sample Collector	C M HUMPHREY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	SAN CARLOS UNIFIED
School Name	RICE (BUILDING A)
Building (name/number)	BUILDING A
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	
Sample Identification Number (<u>Write this number on the sample container and on this sheet</u>)	R05
Date of Collection	6-22-2017
Time of Collection	7:40 AM
Printed Name of Sample Collector	CM HUMPHREY
Signature Sample Collector	CM HUMPHREY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



Login Sample Receipt Checklist

Client: Arizona Dept of Environmental Quality

Job Number: 550-84901-1

SDG Number: Alternative Center, Intermediate, & Rice School

Login Number: 84901

List Source: TestAmerica Phoenix

List Number: 1

Creator: Allen, Chad P

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	False	Check done at department level as required.

