

# TestAmerica

THE LEADER IN ENVIRONMENTAL TESTING

## ANALYTICAL REPORT

TestAmerica Laboratories, Inc.

TestAmerica Phoenix

4625 East Cotton Ctr Blvd

Suite 189

Phoenix, AZ 85040

Tel: (602)437-3340

TestAmerica Job ID: 550-78329-1

TestAmerica Sample Delivery Group: Miami High School

Client Project/Site: Pb in DW / Miami Unified School District

For:

Arizona Dept of Environmental Quality

1110 W. Washington St., MC5415B-1

Phoenix, Arizona 85007

Attn: David A Burchard



Authorized for release by:

3/9/2017 4:47:22 PM

Susan Armijo, Project Manager II

(602)659-7664

[susan.armijo@testamericainc.com](mailto:susan.armijo@testamericainc.com)

### LINKS

Review your project  
results through

TotalAccess

Have a Question?



Visit us at:

[www.testamericainc.com](http://www.testamericainc.com)

*This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.*

*Results relate only to the items tested and the sample(s) as received by the laboratory.*

# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	2
Definitions/Glossary . . . . .	3
Case Narrative . . . . .	4
Sample Summary . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	9
QC Sample Results . . . . .	14
QC Association Summary . . . . .	16
Lab Chronicle . . . . .	18
Certification Summary . . . . .	24
Method Summary . . . . .	25
Chain of Custody . . . . .	26
Receipt Checklists . . . . .	57



## Definitions/Glossary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CNF	Contains no Free Liquid
DER	Duplicate error ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision level concentration
MDA	Minimum detectable activity
EDL	Estimated Detection Limit
MDC	Minimum detectable concentration
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
NC	Not Calculated
ND	Not detected at the reporting limit (or MDL or EDL if shown)
PQL	Practical Quantitation Limit
QC	Quality Control
RER	Relative error ratio
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

## Case Narrative

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

**Job ID: 550-78329-1**

**Laboratory: TestAmerica Phoenix**

### Narrative

#### Job Narrative 550-78329-1

### Comments

No additional comments.

### Receipt

The samples were received on 2/28/2017 10:45 AM; the samples arrived in good condition, properly preserved and, where required, on ice. The temperature of the cooler at receipt was 18.4° C.

### Receipt Exceptions

The following samples for metals were received unpreserved and were preserved upon receipt to the laboratory: HS-01 (550-78329-1), HS-02 (550-78329-2), HS-03 (550-78329-3), HS-04 (550-78329-4), HS-05 (550-78329-5), HS-06 (550-78329-6), HS-07 (550-78329-7), HS-08 (550-78329-8), HS-09 (550-78329-9), HS-10 (550-78329-10), HS-11 (550-78329-11), HS-12 (550-78329-12), HS-13 (550-78329-13), HS-14 (550-78329-14), HS-15 (550-78329-15), HS-16 (550-78329-16), HS-17 (550-78329-17), HS-18 (550-78329-18), HS-19 (550-78329-19), HS-20 (550-78329-20), HS-21 (550-78329-21), HS-22 (550-78329-22), HS-23 (550-78329-23), HS-24 (550-78329-24), HS-25 (550-78329-25), HS-26 (550-78329-26), HS-27 (550-78329-27), HS-28 (550-78329-28), HS-29 (550-78329-29), HS-30 (550-78329-30) and HS-31 (550-78329-31). Regulatory documents require a 24-hour waiting period from the time of the addition of the acid preservative to the time of digestion.

### Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

## Sample Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
550-78329-1	HS-01	Drinking Water	02/16/17 08:43	02/28/17 10:45
550-78329-2	HS-02	Drinking Water	02/16/17 08:45	02/28/17 10:45
550-78329-3	HS-03	Drinking Water	02/16/17 07:06	02/28/17 10:45
550-78329-4	HS-04	Drinking Water	02/16/17 07:39	02/28/17 10:45
550-78329-5	HS-05	Drinking Water	02/16/17 07:12	02/28/17 10:45
550-78329-6	HS-06	Drinking Water	02/16/17 07:19	02/28/17 10:45
550-78329-7	HS-07	Drinking Water	02/16/17 07:46	02/28/17 10:45
550-78329-8	HS-08	Drinking Water	02/16/17 07:07	02/28/17 10:45
550-78329-9	HS-09	Drinking Water	02/16/17 07:27	02/28/17 10:45
550-78329-10	HS-10	Drinking Water	02/16/17 07:26	02/28/17 10:45
550-78329-11	HS-11	Drinking Water	02/16/17 07:31	02/28/17 10:45
550-78329-12	HS-12	Drinking Water	02/16/17 07:37	02/28/17 10:45
550-78329-13	HS-13	Drinking Water	02/16/17 07:33	02/28/17 10:45
550-78329-14	HS-14	Drinking Water	02/16/17 07:18	02/28/17 10:45
550-78329-15	HS-15	Drinking Water	02/16/17 07:22	02/28/17 10:45
550-78329-16	HS-16	Drinking Water	02/16/17 07:37	02/28/17 10:45
550-78329-17	HS-17	Drinking Water	02/16/17 07:28	02/28/17 10:45
550-78329-18	HS-18	Drinking Water	02/16/17 07:49	02/28/17 10:45
550-78329-19	HS-19	Drinking Water	02/16/17 07:17	02/28/17 10:45
550-78329-20	HS-20	Drinking Water	02/16/17 07:40	02/28/17 10:45
550-78329-21	HS-21	Drinking Water	02/16/17 07:47	02/28/17 10:45
550-78329-22	HS-22	Drinking Water	02/16/17 07:58	02/28/17 10:45
550-78329-23	HS-23	Drinking Water	02/16/17 08:00	02/28/17 10:45
550-78329-24	HS-24	Drinking Water	02/16/17 07:55	02/28/17 10:45
550-78329-25	HS-25	Drinking Water	02/16/17 07:58	02/28/17 10:45
550-78329-26	HS-26	Drinking Water	02/16/17 07:49	02/28/17 10:45
550-78329-27	HS-27	Drinking Water	02/16/17 07:48	02/28/17 10:45
550-78329-28	HS-28	Drinking Water	02/16/17 07:26	02/28/17 10:45
550-78329-29	HS-29	Drinking Water	02/16/17 07:11	02/28/17 10:45
550-78329-30	HS-30	Drinking Water	02/16/17 07:17	02/28/17 10:45
550-78329-31	HS-31	Drinking Water	02/16/17 07:13	02/28/17 10:45

## Detection Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-01

Lab Sample ID: 550-78329-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-02

Lab Sample ID: 550-78329-2

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-03

Lab Sample ID: 550-78329-3

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.79		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-04

Lab Sample ID: 550-78329-4

No Detections.

### Client Sample ID: HS-05

Lab Sample ID: 550-78329-5

No Detections.

### Client Sample ID: HS-06

Lab Sample ID: 550-78329-6

No Detections.

### Client Sample ID: HS-07

Lab Sample ID: 550-78329-7

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.9		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-08

Lab Sample ID: 550-78329-8

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-09

Lab Sample ID: 550-78329-9

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	19		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-10

Lab Sample ID: 550-78329-10

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.74		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-11

Lab Sample ID: 550-78329-11

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-12

Lab Sample ID: 550-78329-12

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

## Detection Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-12 (Continued)

Lab Sample ID: 550-78329-12

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.64		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-13

Lab Sample ID: 550-78329-13

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.65		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-14

Lab Sample ID: 550-78329-14

No Detections.

### Client Sample ID: HS-15

Lab Sample ID: 550-78329-15

No Detections.

### Client Sample ID: HS-16

Lab Sample ID: 550-78329-16

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.9		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-17

Lab Sample ID: 550-78329-17

No Detections.

### Client Sample ID: HS-18

Lab Sample ID: 550-78329-18

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.82		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-19

Lab Sample ID: 550-78329-19

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-20

Lab Sample ID: 550-78329-20

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	47		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-21

Lab Sample ID: 550-78329-21

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.57		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-22

Lab Sample ID: 550-78329-22

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.9		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-23

Lab Sample ID: 550-78329-23

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix

## Detection Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-23 (Continued)

Lab Sample ID: 550-78329-23

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.0		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-24

Lab Sample ID: 550-78329-24

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.0		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-25

Lab Sample ID: 550-78329-25

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.6		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-26

Lab Sample ID: 550-78329-26

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-27

Lab Sample ID: 550-78329-27

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-28

Lab Sample ID: 550-78329-28

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	25		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-29

Lab Sample ID: 550-78329-29

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.91		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-30

Lab Sample ID: 550-78329-30

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50	ppb	1		200.8	Total/NA

### Client Sample ID: HS-31

Lab Sample ID: 550-78329-31

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.1		0.50	ppb	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

TestAmerica Phoenix



# Client Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

**Client Sample ID: HS-01**  
**Date Collected: 02/16/17 08:43**  
**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-1**  
**Matrix: Drinking Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5		0.50	ppb		03/07/17 09:34	03/08/17 21:12	1

**Client Sample ID: HS-02**  
**Date Collected: 02/16/17 08:45**  
**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-2**  
**Matrix: Drinking Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5		0.50	ppb		03/07/17 09:34	03/08/17 21:14	1

**Client Sample ID: HS-03**  
**Date Collected: 02/16/17 07:06**  
**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-3**  
**Matrix: Drinking Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.79		0.50	ppb		03/07/17 09:34	03/08/17 21:16	1

**Client Sample ID: HS-04**  
**Date Collected: 02/16/17 07:39**  
**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-4**  
**Matrix: Drinking Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/07/17 09:34	03/08/17 21:18	1

**Client Sample ID: HS-05**  
**Date Collected: 02/16/17 07:12**  
**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-5**  
**Matrix: Drinking Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/07/17 09:34	03/08/17 21:24	1

**Client Sample ID: HS-06**  
**Date Collected: 02/16/17 07:19**  
**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-6**  
**Matrix: Drinking Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/07/17 09:34	03/08/17 21:26	1

**Client Sample ID: HS-07**  
**Date Collected: 02/16/17 07:46**  
**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-7**  
**Matrix: Drinking Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		0.50	ppb		03/07/17 09:34	03/08/17 21:28	1

TestAmerica Phoenix

# Client Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

## Client Sample ID: HS-08

Date Collected: 02/16/17 07:07

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-8

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50	ppb		03/07/17 09:34	03/08/17 21:30	1

## Client Sample ID: HS-09

Date Collected: 02/16/17 07:27

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-9

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	19		0.50	ppb		03/07/17 09:34	03/08/17 21:32	1

## Client Sample ID: HS-10

Date Collected: 02/16/17 07:26

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-10

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.74		0.50	ppb		03/07/17 09:34	03/08/17 21:34	1

## Client Sample ID: HS-11

Date Collected: 02/16/17 07:31

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-11

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5		0.50	ppb		03/07/17 09:34	03/08/17 21:36	1

## Client Sample ID: HS-12

Date Collected: 02/16/17 07:37

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-12

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.64		0.50	ppb		03/07/17 09:34	03/08/17 21:38	1

## Client Sample ID: HS-13

Date Collected: 02/16/17 07:33

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-13

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.65		0.50	ppb		03/07/17 09:34	03/08/17 21:40	1

## Client Sample ID: HS-14

Date Collected: 02/16/17 07:18

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-14

Matrix: Drinking Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/07/17 09:34	03/08/17 21:42	1

TestAmerica Phoenix

## Client Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-15

Date Collected: 02/16/17 07:22

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-15

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb	—	03/07/17 09:40	03/08/17 21:57	1

### Client Sample ID: HS-16

Date Collected: 02/16/17 07:37

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-16

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9		0.50	ppb	—	03/07/17 09:40	03/08/17 22:03	1

### Client Sample ID: HS-17

Date Collected: 02/16/17 07:28

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-17

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb	—	03/07/17 09:40	03/08/17 22:05	1

### Client Sample ID: HS-18

Date Collected: 02/16/17 07:49

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-18

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.82		0.50	ppb	—	03/07/17 09:40	03/08/17 22:07	1

### Client Sample ID: HS-19

Date Collected: 02/16/17 07:17

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-19

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50	ppb	—	03/07/17 09:40	03/08/17 22:09	1

### Client Sample ID: HS-20

Date Collected: 02/16/17 07:40

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-20

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	47		0.50	ppb	—	03/07/17 09:40	03/08/17 22:11	1

### Client Sample ID: HS-21

Date Collected: 02/16/17 07:47

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-21

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.57		0.50	ppb	—	03/07/17 09:40	03/08/17 22:13	1

TestAmerica Phoenix

## Client Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-22

Date Collected: 02/16/17 07:58

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-22

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.9		0.50	ppb		03/07/17 09:40	03/08/17 22:15	1

### Client Sample ID: HS-23

Date Collected: 02/16/17 08:00

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-23

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.0		0.50	ppb		03/07/17 09:40	03/08/17 22:17	1

### Client Sample ID: HS-24

Date Collected: 02/16/17 07:55

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-24

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.0		0.50	ppb		03/07/17 09:40	03/08/17 22:19	1

### Client Sample ID: HS-25

Date Collected: 02/16/17 07:58

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-25

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		0.50	ppb		03/07/17 09:40	03/08/17 22:25	1

### Client Sample ID: HS-26

Date Collected: 02/16/17 07:49

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-26

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3		0.50	ppb		03/07/17 09:40	03/08/17 22:27	1

### Client Sample ID: HS-27

Date Collected: 02/16/17 07:48

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-27

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50	ppb		03/07/17 09:40	03/08/17 22:29	1

### Client Sample ID: HS-28

Date Collected: 02/16/17 07:26

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-28

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	25		0.50	ppb		03/07/17 09:40	03/08/17 22:31	1

TestAmerica Phoenix

## Client Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-29

Date Collected: 02/16/17 07:11

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-29

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.91		0.50	ppb		03/07/17 09:40	03/08/17 22:33	1

### Client Sample ID: HS-30

Date Collected: 02/16/17 07:17

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-30

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50	ppb		03/07/17 09:40	03/08/17 22:34	1

### Client Sample ID: HS-31

Date Collected: 02/16/17 07:13

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-31

Matrix: Drinking Water

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.1		0.50	ppb		03/07/17 09:40	03/08/17 22:37	1

# QC Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

## Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 550-111728/1-A  
Matrix: Water  
Analysis Batch: 111959

Client Sample ID: Method Blank  
Prep Type: Total/NA  
Prep Batch: 111728

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/07/17 09:34	03/08/17 20:47	1

Lab Sample ID: LCS 550-111728/4-A  
Matrix: Water  
Analysis Batch: 111959

Client Sample ID: Lab Control Sample  
Prep Type: Total/NA  
Prep Batch: 111728

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	102		ppb		102	85 - 115

Lab Sample ID: LCSD 550-111728/5-A  
Matrix: Water  
Analysis Batch: 111959

Client Sample ID: Lab Control Sample Dup  
Prep Type: Total/NA  
Prep Batch: 111728

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	100	101		ppb		101	85 - 115	1	20

Lab Sample ID: 550-78327-A-13-B MS  
Matrix: Water  
Analysis Batch: 111959

Client Sample ID: Matrix Spike  
Prep Type: Total/NA  
Prep Batch: 111728

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	0.67		100	97.9		ppb		97	70 - 130

Lab Sample ID: 550-78327-A-13-C MSD  
Matrix: Water  
Analysis Batch: 111959

Client Sample ID: Matrix Spike Duplicate  
Prep Type: Total/NA  
Prep Batch: 111728

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	0.67		100	97.5		ppb		97	70 - 130	0	20

Lab Sample ID: MB 550-111730/1-A  
Matrix: Water  
Analysis Batch: 111960

Client Sample ID: Method Blank  
Prep Type: Total/NA  
Prep Batch: 111730

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	ND		0.50	ppb		03/07/17 09:40	03/08/17 21:48	1

Lab Sample ID: LCS 550-111730/4-A  
Matrix: Water  
Analysis Batch: 111960

Client Sample ID: Lab Control Sample  
Prep Type: Total/NA  
Prep Batch: 111730

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	100	105		ppb		105	85 - 115

Lab Sample ID: LCSD 550-111730/5-A  
Matrix: Water  
Analysis Batch: 111960

Client Sample ID: Lab Control Sample Dup  
Prep Type: Total/NA  
Prep Batch: 111730

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	100	105		ppb		105	85 - 115	0	20

TestAmerica Phoenix

## QC Sample Results

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

Lab Sample ID: 550-78329-15 MS  
Matrix: Drinking Water  
Analysis Batch: 111960

Client Sample ID: HS-15  
Prep Type: Total/NA  
Prep Batch: 111730

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Lead	ND		100	102		ppb		102	70 - 130

Lab Sample ID: 550-78329-15 MSD  
Matrix: Drinking Water  
Analysis Batch: 111960

Client Sample ID: HS-15  
Prep Type: Total/NA  
Prep Batch: 111730

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Lead	ND		100	101		ppb		100	70 - 130	1	20

# QC Association Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

## Metals

### Prep Batch: 111728

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-78329-1	HS-01	Total/NA	Drinking Water	200.8	
550-78329-2	HS-02	Total/NA	Drinking Water	200.8	
550-78329-3	HS-03	Total/NA	Drinking Water	200.8	
550-78329-4	HS-04	Total/NA	Drinking Water	200.8	
550-78329-5	HS-05	Total/NA	Drinking Water	200.8	
550-78329-6	HS-06	Total/NA	Drinking Water	200.8	
550-78329-7	HS-07	Total/NA	Drinking Water	200.8	
550-78329-8	HS-08	Total/NA	Drinking Water	200.8	
550-78329-9	HS-09	Total/NA	Drinking Water	200.8	
550-78329-10	HS-10	Total/NA	Drinking Water	200.8	
550-78329-11	HS-11	Total/NA	Drinking Water	200.8	
550-78329-12	HS-12	Total/NA	Drinking Water	200.8	
550-78329-13	HS-13	Total/NA	Drinking Water	200.8	
550-78329-14	HS-14	Total/NA	Drinking Water	200.8	
MB 550-111728/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-111728/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-111728/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-78327-A-13-B MS	Matrix Spike	Total/NA	Water	200.8	
550-78327-A-13-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

### Prep Batch: 111730

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-78329-15	HS-15	Total/NA	Drinking Water	200.8	
550-78329-16	HS-16	Total/NA	Drinking Water	200.8	
550-78329-17	HS-17	Total/NA	Drinking Water	200.8	
550-78329-18	HS-18	Total/NA	Drinking Water	200.8	
550-78329-19	HS-19	Total/NA	Drinking Water	200.8	
550-78329-20	HS-20	Total/NA	Drinking Water	200.8	
550-78329-21	HS-21	Total/NA	Drinking Water	200.8	
550-78329-22	HS-22	Total/NA	Drinking Water	200.8	
550-78329-23	HS-23	Total/NA	Drinking Water	200.8	
550-78329-24	HS-24	Total/NA	Drinking Water	200.8	
550-78329-25	HS-25	Total/NA	Drinking Water	200.8	
550-78329-26	HS-26	Total/NA	Drinking Water	200.8	
550-78329-27	HS-27	Total/NA	Drinking Water	200.8	
550-78329-28	HS-28	Total/NA	Drinking Water	200.8	
550-78329-29	HS-29	Total/NA	Drinking Water	200.8	
550-78329-30	HS-30	Total/NA	Drinking Water	200.8	
550-78329-31	HS-31	Total/NA	Drinking Water	200.8	
MB 550-111730/1-A	Method Blank	Total/NA	Water	200.8	
LCS 550-111730/4-A	Lab Control Sample	Total/NA	Water	200.8	
LCSD 550-111730/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	
550-78329-15 MS	HS-15	Total/NA	Drinking Water	200.8	
550-78329-15 MSD	HS-15	Total/NA	Drinking Water	200.8	

### Analysis Batch: 111959

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-78329-1	HS-01	Total/NA	Drinking Water	200.8	111728
550-78329-2	HS-02	Total/NA	Drinking Water	200.8	111728
550-78329-3	HS-03	Total/NA	Drinking Water	200.8	111728
550-78329-4	HS-04	Total/NA	Drinking Water	200.8	111728

TestAmerica Phoenix



## QC Association Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Metals (Continued)

#### Analysis Batch: 111959 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-78329-5	HS-05	Total/NA	Drinking Water	200.8	111728
550-78329-6	HS-06	Total/NA	Drinking Water	200.8	111728
550-78329-7	HS-07	Total/NA	Drinking Water	200.8	111728
550-78329-8	HS-08	Total/NA	Drinking Water	200.8	111728
550-78329-9	HS-09	Total/NA	Drinking Water	200.8	111728
550-78329-10	HS-10	Total/NA	Drinking Water	200.8	111728
550-78329-11	HS-11	Total/NA	Drinking Water	200.8	111728
550-78329-12	HS-12	Total/NA	Drinking Water	200.8	111728
550-78329-13	HS-13	Total/NA	Drinking Water	200.8	111728
550-78329-14	HS-14	Total/NA	Drinking Water	200.8	111728
MB 550-111728/1-A	Method Blank	Total/NA	Water	200.8	111728
LCS 550-111728/4-A	Lab Control Sample	Total/NA	Water	200.8	111728
LCSD 550-111728/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	111728
550-78327-A-13-B MS	Matrix Spike	Total/NA	Water	200.8	111728
550-78327-A-13-C MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	111728

#### Analysis Batch: 111960

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
550-78329-15	HS-15	Total/NA	Drinking Water	200.8	111730
550-78329-16	HS-16	Total/NA	Drinking Water	200.8	111730
550-78329-17	HS-17	Total/NA	Drinking Water	200.8	111730
550-78329-18	HS-18	Total/NA	Drinking Water	200.8	111730
550-78329-19	HS-19	Total/NA	Drinking Water	200.8	111730
550-78329-20	HS-20	Total/NA	Drinking Water	200.8	111730
550-78329-21	HS-21	Total/NA	Drinking Water	200.8	111730
550-78329-22	HS-22	Total/NA	Drinking Water	200.8	111730
550-78329-23	HS-23	Total/NA	Drinking Water	200.8	111730
550-78329-24	HS-24	Total/NA	Drinking Water	200.8	111730
550-78329-25	HS-25	Total/NA	Drinking Water	200.8	111730
550-78329-26	HS-26	Total/NA	Drinking Water	200.8	111730
550-78329-27	HS-27	Total/NA	Drinking Water	200.8	111730
550-78329-28	HS-28	Total/NA	Drinking Water	200.8	111730
550-78329-29	HS-29	Total/NA	Drinking Water	200.8	111730
550-78329-30	HS-30	Total/NA	Drinking Water	200.8	111730
550-78329-31	HS-31	Total/NA	Drinking Water	200.8	111730
MB 550-111730/1-A	Method Blank	Total/NA	Water	200.8	111730
LCS 550-111730/4-A	Lab Control Sample	Total/NA	Water	200.8	111730
LCSD 550-111730/5-A	Lab Control Sample Dup	Total/NA	Water	200.8	111730
550-78329-15 MS	HS-15	Total/NA	Drinking Water	200.8	111730
550-78329-15 MSD	HS-15	Total/NA	Drinking Water	200.8	111730

## Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-01

Date Collected: 02/16/17 08:43

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-1

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:12	KLH	TAL PHX

### Client Sample ID: HS-02

Date Collected: 02/16/17 08:45

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-2

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:14	KLH	TAL PHX

### Client Sample ID: HS-03

Date Collected: 02/16/17 07:06

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-3

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:16	KLH	TAL PHX

### Client Sample ID: HS-04

Date Collected: 02/16/17 07:39

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-4

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:18	KLH	TAL PHX

### Client Sample ID: HS-05

Date Collected: 02/16/17 07:12

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-5

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:24	KLH	TAL PHX

### Client Sample ID: HS-06

Date Collected: 02/16/17 07:19

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-6

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:26	KLH	TAL PHX

TestAmerica Phoenix

## Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

**Client Sample ID: HS-07**

**Date Collected: 02/16/17 07:46**

**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-7**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:28	KLH	TAL PHX

**Client Sample ID: HS-08**

**Date Collected: 02/16/17 07:07**

**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-8**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:30	KLH	TAL PHX

**Client Sample ID: HS-09**

**Date Collected: 02/16/17 07:27**

**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-9**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:32	KLH	TAL PHX

**Client Sample ID: HS-10**

**Date Collected: 02/16/17 07:26**

**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-10**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:34	KLH	TAL PHX

**Client Sample ID: HS-11**

**Date Collected: 02/16/17 07:31**

**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-11**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:36	KLH	TAL PHX

**Client Sample ID: HS-12**

**Date Collected: 02/16/17 07:37**

**Date Received: 02/28/17 10:45**

**Lab Sample ID: 550-78329-12**

**Matrix: Drinking Water**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:38	KLH	TAL PHX

TestAmerica Phoenix

# Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

## Client Sample ID: HS-13

Date Collected: 02/16/17 07:33

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-13

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:40	KLH	TAL PHX

## Client Sample ID: HS-14

Date Collected: 02/16/17 07:18

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-14

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111728	03/07/17 09:34	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111959	03/08/17 21:42	KLH	TAL PHX

## Client Sample ID: HS-15

Date Collected: 02/16/17 07:22

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-15

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 21:57	KLH	TAL PHX

## Client Sample ID: HS-16

Date Collected: 02/16/17 07:37

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-16

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:03	KLH	TAL PHX

## Client Sample ID: HS-17

Date Collected: 02/16/17 07:28

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-17

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:05	KLH	TAL PHX

## Client Sample ID: HS-18

Date Collected: 02/16/17 07:49

Date Received: 02/28/17 10:45

## Lab Sample ID: 550-78329-18

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:07	KLH	TAL PHX

TestAmerica Phoenix

## Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-19

Date Collected: 02/16/17 07:17

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-19

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:09	KLH	TAL PHX

### Client Sample ID: HS-20

Date Collected: 02/16/17 07:40

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-20

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:11	KLH	TAL PHX

### Client Sample ID: HS-21

Date Collected: 02/16/17 07:47

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-21

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:13	KLH	TAL PHX

### Client Sample ID: HS-22

Date Collected: 02/16/17 07:58

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-22

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:15	KLH	TAL PHX

### Client Sample ID: HS-23

Date Collected: 02/16/17 08:00

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-23

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:17	KLH	TAL PHX

### Client Sample ID: HS-24

Date Collected: 02/16/17 07:55

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-24

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:19	KLH	TAL PHX

TestAmerica Phoenix

## Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Client Sample ID: HS-25

Date Collected: 02/16/17 07:58

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-25

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:25	KLH	TAL PHX

### Client Sample ID: HS-26

Date Collected: 02/16/17 07:49

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-26

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:27	KLH	TAL PHX

### Client Sample ID: HS-27

Date Collected: 02/16/17 07:48

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-27

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:29	KLH	TAL PHX

### Client Sample ID: HS-28

Date Collected: 02/16/17 07:26

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-28

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:31	KLH	TAL PHX

### Client Sample ID: HS-29

Date Collected: 02/16/17 07:11

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-29

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:33	KLH	TAL PHX

### Client Sample ID: HS-30

Date Collected: 02/16/17 07:17

Date Received: 02/28/17 10:45

### Lab Sample ID: 550-78329-30

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:34	KLH	TAL PHX

TestAmerica Phoenix

Lab Chronicle

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

Client Sample ID: HS-31  
Date Collected: 02/16/17 07:13  
Date Received: 02/28/17 10:45

Lab Sample ID: 550-78329-31  
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	200.8			111730	03/07/17 09:40	SGO	TAL PHX
Total/NA	Analysis	200.8		1	111960	03/08/17 22:37	KLH	TAL PHX

Laboratory References:  
TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

## Certification Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

### Laboratory: TestAmerica Phoenix

Unless otherwise noted, all analytes for this laboratory were covered under each certification below.

Authority	Program	EPA Region	Certification ID	Expiration Date
Arizona	State Program	9	AZ0728	06-09-17

Analysis Method	Prep Method	Matrix	Analyte
-----------------	-------------	--------	---------



## Method Summary

Client: Arizona Dept of Environmental Quality  
Project/Site: Pb in DW / Miami Unified School District

TestAmerica Job ID: 550-78329-1  
SDG: Miami High School

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	TAL PHX

### Protocol References:

EPA = US Environmental Protection Agency

### Laboratory References:

TAL PHX = TestAmerica Phoenix, 4625 East Cotton Ctr Blvd, Suite 189, Phoenix, AZ 85040, TEL (602)437-3340

78329

## Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	BUS BARN
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	BUS BARN OFFICE
Sample Identification Number ( <b>Write the number here and on sample container</b> )	HS-01
Date of Collection	2/16/17
Time of Collection	0843
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	Michael Leonard

550-78329 Chain of Custody



Notes Sample collector:

For Lab use only

Analyze this drinking water sample for lead
Date and Time Lab received
Signature
Notes:

For relinquishing samples upon delivery to labs only

Relinquished date and signature

FedEx → [Signature] 6:45 2/28/17 no ice 18.4m

These samples were collected for lead screening purposes only and cannot be used for compliance.




## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGHT SCHOOL
Building (name/number)	BUS BARN / MAINTENANCE
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	SOUTHWEST CORNER
Sample Identification Number ( <b>Write the number here and on sample container</b> )	HS - 02
Date of Collection	2/16/17
Time of Collection	0845
Printed Name of Sample Collector	Jason Schriackoff
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


2

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	MHS OFFICE
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	HALLWAY
Sample Identification Number ( <b>Write the number here and on sample container</b> )	HS-03
Date of Collection	2/16/17
Time of Collection	0706
Printed Name of Sample Collector	JASON SCHRIAKOFF
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


③

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	AUDITORIUM
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	LOBBY
Sample Identification Number ( <b>Write the number here and on sample container</b> )	HS-04
Date of Collection	2/16/17
Time of Collection	0739
Printed Name of Sample Collector	Jason Schriackoff
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


④

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	B-BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	1ST FLOOR
Sample Identification Number ( <u>Write the number here and on sample container</u> )	HS-05
Date of Collection	2/16/17
Time of Collection	0712
Printed Name of Sample Collector	Jason Schriackoff
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

5

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	B-BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	2ND FLOOR
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-06
Date of Collection	2/16/17
Time of Collection	0719
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	Michael Leonard

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


16

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	B-BUILDING
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	LAB ROOM 121
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-07
Date of Collection	2/16/17
Time of Collection	0746
Printed Name of Sample Collector	JASON SCHRIKOFF
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*





## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 46
School Name	MIAMI HIGH SCHOOL
Building (name/number)	HIGH SCHOOL OFFICE
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	NURSES OFFICE
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-08
Date of Collection	2-16-17
Time of Collection	07:07
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	<i>Michael Leonard</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

8

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	HIGH SCHOOL
Building (name/number)	DISTRICT OFFICE
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	GIRLS REST ROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-09
Date of Collection	2-16-17
Time of Collection	0727
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	Michael Leonard

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


9

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	Gym
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	LOBBY
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-10
Date of Collection	2/16/17
Time of Collection	0726
Printed Name of Sample Collector	Jason Schriackoff
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	Gym
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	GIRLS LOCKER ROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-11
Date of Collection	2/14/17
Time of Collection	0731
Printed Name of Sample Collector	Jason S. Riehoff
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	CAFETERIA
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	WASH BASIN SINK
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-12
Date of Collection	2/16/17
Time of Collection	0737
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	<i>Michael Leonard</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

12

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	K-BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	HALLWAY
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-13
Date of Collection	2-16-17
Time of Collection	0733
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	<i>Michael Leonard</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


13

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	B - BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	2 <sup>ND</sup> FLOOR
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS - 14
Date of Collection	2/16/17
Time of Collection	0718
Printed Name of Sample Collector	JASON SCHLIKOFF
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

14




## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 48
School Name	MIAMI HIGH SCHOOL
Building (name/number)	B - BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	2 <sup>ND</sup> FLOOR WEST
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS - 15
Date of Collection	2/16/17
Time of Collection	0722
Printed Name of Sample Collector	JASON SCHRIAKOFF
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

15




## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling


Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	CATERINA
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	MAIN FLOOR
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS - 16
Date of Collection	2/16/17
Time of Collection	0737
Printed Name of Sample Collector	Jason Schnaboff
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

 These samples were collected for lead screening purposes only and cannot be used for compliance.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

### Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	Gym
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	CONCESSION (WEST)
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-17
Date of Collection	2/16/17
Time of Collection	0728
Printed Name of Sample Collector	Rudy Camacho
Signature Sample Collector	Rudy Camacho

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

97

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 46
School Name	MIAMI HIGH SCHOOL
Building (name/number)	H - BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	DANCE ROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-18
Date of Collection	2-16-17
Time of Collection	0749
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	<i>Michael Leonard</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


18

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	A - BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	1ST FLOOR (WEST)
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-19
Date of Collection	2/16/17
Time of Collection	0717
Printed Name of Sample Collector	Jason Schriber
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	AUDITORIUM
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	WOMENS REST ROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-20
Date of Collection	2-16-17
Time of Collection	0740
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	Michael Leonard

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 46
School Name	MIAMI HIGH SCHOOL
Building (name/number)	LIBRARY D BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	LIBRARY
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS - 21
Date of Collection	2/16/17
Time of Collection	0747
Printed Name of Sample Collector	Jason Schriakoff
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


21

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	PRESS BOX FOOTBALL FIELD
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	GIRLS BATHROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS - 22
Date of Collection	2/16/17
Time of Collection	0758
Printed Name of Sample Collector	Jason Schriackoff
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

22




## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	PRESS BOX FOOTBALL FIELD
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Boys BATHROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-23
Date of Collection	2/16/17
Time of Collection	0800
Printed Name of Sample Collector	Jason Sohtiaikov
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

23



## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	TENNIS COURTS
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	TENNIS COURT ENTRANCE
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-24
Date of Collection	2/16/17
Time of Collection	0755
Printed Name of Sample Collector	Ruby Camacho
Signature Sample Collector	Ruby Camacho

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

24

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGHT SCHOOL
Building (name/number)	FIELD STORAGE
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	STORAGE SHED
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS - 25
Date of Collection	2/16/17
Time of Collection	0758
Printed Name of Sample Collector	RUDY CAMACHO
Signature Sample Collector	<i>Rudy Camacho</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

(25)

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGHT SCHOOL
Building (name/number)	H - BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	BAND ROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-26
Date of Collection	2-16-17
Time of Collection	0749
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	Michael Leonard

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


(26)

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	Gym PE ROOM
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	BOYS LOCKER ROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-27
Date of Collection	2/16/17
Time of Collection	0748
Printed Name of Sample Collector	JASON SCHRIKOFF
Signature Sample Collector	

Notes Sample collector:
-------------------------

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

27

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	DISTRICT OFFICE
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	BOYS RESTROOM
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-28
Date of Collection	2-16-17
Time of Collection	0726
Printed Name of Sample Collector	Rudy Camacho
Signature Sample Collector	Rudy Camacho

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

28

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	A-BUILDING
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Room 116
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	145-29
Date of Collection	2-16-17
Time of Collection	0711
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	Michael Leonard

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

29

## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	A - BUILDING
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	1ST FLOOR (WEST)
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-30
Date of Collection	2-16-17
Time of Collection	0717
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	Michael Leonard

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*





## Collection Log

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	MIAMI UNIFIED SCHOOL DISTRICT 40
School Name	MIAMI HIGH SCHOOL
Building (name/number)	A-BUKOIN
Type of Fixture (tap, drinking fountain etc.)	TAP
Location of Fixture (example, room number)	Rm 103
Sample Identification Number ( <b><u>Write the number here and on sample container</u></b> )	HS-31
Date of Collection	2-16-17
Time of Collection	0713
Printed Name of Sample Collector	Michael Leonard
Signature Sample Collector	Michael Leonard

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

31



## Login Sample Receipt Checklist

Client: Arizona Dept of Environmental Quality

Job Number: 550-78329-1

SDG Number: Miami High School

**Login Number: 78329**

**List Number: 1**

**Creator: Vilaboy, Monica**

**List Source: TestAmerica Phoenix**

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	Check done at department level as required.

