

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Adams Elementary School

Reported:
05/05/17 16:22

Analyte

1001-1 (7042685-01) Drinking Water (Grab) Sampled: 04/26/17 06:20 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:03	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7042685-02) Drinking Water (Grab) Sampled: 04/26/17 06:25 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:15	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7042685-03) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	6.6	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:18	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1002-2 (7042685-04) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	8.0	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:22	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1003-1 (7042685-05) Drinking Water (Grab) Sampled: 04/26/17 06:20 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:26	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-2 (7042685-06) Drinking Water (Grab) Sampled: 04/26/17 06:20 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:30	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-1 (7042685-07) Drinking Water (Grab) Sampled: 04/26/17 06:25 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.



Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 24

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Adams Elementary School

Reported:
05/05/17 16:22

1004-1 (7042685-07) Drinking Water (Grab) Sampled: 04/26/17 06:25 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	23	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:34	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1004-2 (7042685-08) Drinking Water (Grab) Sampled: 04/26/17 06:25 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	9.6	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:37	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1005-1 (7042685-09) Drinking Water (Grab) Sampled: 04/26/17 06:25 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:49	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1006-1 (7042685-10) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	16	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:53	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1006-2 (7042685-11) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	17	5.0	ug/L	1	B7E0979	05/02/17 10:37	05/03/17 14:57	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1007-1 (7042685-12) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0981	05/02/17 10:40	05/03/17 15:19	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1007-2 (7042685-13) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	11	5.0	ug/L	1	B7E0981	05/02/17 10:40	05/03/17 15:23	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1008-1 (7042685-14) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Adams Elementary School

Reported:
05/05/17 16:22

1008-1 (7042685-14) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	47	5.0	ug/L	1	B7E0981	05/02/17 10:40	05/03/17 15:35	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1009-1 (7042685-15) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	12	5.0	ug/L	1	B7E0981	05/02/17 10:40	05/03/17 15:38	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1011-1 (7042685-16) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0981	05/02/17 10:40	05/03/17 15:42	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1011-2 (7042685-17) Drinking Water (Grab) Sampled: 04/26/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0981	05/02/17 10:40	05/03/17 15:46	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1012-1 (7042685-18) Drinking Water (Grab) Sampled: 04/26/17 06:20 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0981	05/02/17 10:40	05/03/17 15:50	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1013-1 (7042685-19) Drinking Water (Grab) Sampled: 04/26/17 06:20 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	18	5.0	ug/L	1	B7E0981	05/02/17 10:40	05/03/17 15:54	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Sample Condition Upon Receipt:

Temperature: 6.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
• Printed Name of Sample Collector
• Signature Sample Collector

Mesa Unified District
Adams Elementary School
1001-1 Room 8
Drinking
Room 8
1001-1
4-26-17
6:20
Alan A. Alfaro

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received @ Lab 4/27/16 @ 1600

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1001-2
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain Room 6
Location of Fixture (example, room number)	Room 6
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-2
Date of Collection	4-26-17
Time of Collection	6:25 a.m.
Printed Name of Sample Collector	Ally A. H. H.
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042685-03

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Mesa Unified District
Adams Elementary School
1002-1 Room 27
DE J Sink 27
1002-1
4-26-17
6:30 am
Alana Alfieri
[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042685-04

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Mesa Unified District
Adams Elementary School
1002-2 Room 20
DEF Sink Room 20
1002-2
4-26-17
6:30 a.m.
Alan Adams

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Mesa Unified District
Adams Elementary School
1003-1 Room 10
DEF Sink 10
1003-1
4-26-17
6:20 a.m.
Alan Alfieri
Alan Alfieri

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Mesa Unified District
Adams Elementary School
1003-2
DF / Sink Room 17
1003-2
4-26-17
6:20 a.m.
Alan Alf. Jr.
AL

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

7042685-07

Mesa Unified District
Adams Elementary School
1004-1 12A music
DEF Sink 12A
1004-1
4-26-17
6:25 am
Alan Alf. Alf.
AL Alf

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

7042685 - 08

Mesa Unified District
Adams Elementary School
1004-2 Room 12
DFI Sink
Room 12
1004-2
4-26-17
6:25 a.m.
Al [Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042685 -09

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	Room 32 1005-1
Type of Fixture (tap, drinking fountain etc.)	Drinking 32
Location of Fixture (example, room number)	
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1
Date of Collection	4-26-17
Time of Collection	6:25 a.m.
Printed Name of Sample Collector	Alan Allen
Signature Sample Collector	AL

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Mesa Unified District
Adams Elementary School
1006-1
Drinking Fountain / SNK
1006-1
4-26-17
6:30
Alan Altieri
AL Altieri

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1006 - 2
Type of Fixture (tap, drinking fountain etc.)	DEF Sink
Location of Fixture (example, room number)	Room 48
Sample Identification Number (Write this number on the sample container and on this sheet)	1006 - 2
Date of Collection	4-26-17
Time of Collection	6:30 am
Printed Name of Sample Collector	Ally Altieri
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

7042685-12

Mesa Unified District
Adams Elementary School
1007-1
Room 50
DEF Sink
Room 50
1007-1
4-26-17
6:30 a.m.
Alan Albie

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042685 -13

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1007-2 Room 51
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	51
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-2
Date of Collection	4-26-17
Time of Collection	6:30 a.m.
Printed Name of Sample Collector	Alfonso Alfaro
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042685-14

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1008-1 Room 53
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	53
Sample Identification Number (Write this number on the sample container and on this sheet)	1008-1
Date of Collection	4-26-17
Time of Collection	6:30 a.m.
Printed Name of Sample Collector	Alan Affieci
Signature Sample Collector	Alan Affieci

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1009-1 Room 45
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain 45
Location of Fixture (example, room number)	
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-1
Date of Collection	4-26-17
Time of Collection	6:30 a.m.
Printed Name of Sample Collector	Alfonso Alfieri
Signature Sample Collector	AL Alfieri

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1011-1
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain Room 43
Location of Fixture (example, room number)	Room 43
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-1
Date of Collection	4-26-17
Time of Collection	6:30 a.m.
Printed Name of Sample Collector	Al
Signature Sample Collector	Al

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042485-17

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1011-2 Room 42
Type of Fixture (tap, drinking fountain etc.)	42
Location of Fixture (example, room number)	
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-2
Date of Collection	4-26-17
Time of Collection	6:30 a.m.
Printed Name of Sample Collector	Alan Alfieri
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1012-1 New PE Bldg
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	New PE Bldg
Sample Identification Number (Write this number on the sample container and on this sheet)	1012-1
Date of Collection	4-26-17
Time of Collection	6:20 a.m.
Printed Name of Sample Collector	Alan Altieri
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Adams Elementary School
Building (name/number)	1013-1
Type of Fixture (tap, drinking fountain etc.)	Kitchen Room
Location of Fixture (example, room number)	Sink Kitchen Room
Sample Identification Number (Write this number on the sample container and on this sheet)	1013-1
Date of Collection	4-26-17
Time of Collection	6:20 AM
Printed Name of Sample Collector	Atigeri
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7060655

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Adams Elementary School	1001	A1000	Admin/Media/Class	1963	2
Mesa Unified District	Adams Elementary School	1002	A2000	Classrooms	1966	2
Mesa Unified District	Adams Elementary School	1003	A3000	Cafeteria/Class	1963	2
Mesa Unified District	Adams Elementary School	1004	A4000	Central Plant	1985	2
Mesa Unified District	Adams Elementary School	1005	A5000	Classrooms	1997	1
Mesa Unified District	Adams Elementary School	1006	A6000 R-415	Classrooms	1985	2
Mesa Unified District	Adams Elementary School	1007	A7000 R-447	Classrooms	1987	2
Mesa Unified District	Adams Elementary School	1008	A8000 R-299	Classrooms	1992	1
Mesa Unified District	Adams Elementary School	1009	A9000 R-448	Classrooms	1992	1
Mesa Unified District	Adams Elementary School	1011	A11000 R-369	Classroom	1984	2
Mesa Unified District	Adams Elementary School	1012	A12000	Multipurpose room	2002	1
Mesa Unified District	Adams Elementary School	1013	A1300 ONE WATER	Kiln	1978	2-1
Address:	738 S Longmore, Mesa, AZ 85202				Number of Bottles Per Kit:	20-1

DF/sink

6 hours

only one water source

(19)