

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Hawthorne Elementary School

Reported:  
05/11/17 15:09

## Analyte

**1015 (7042769-01) Drinking Water (Grab) Sampled: 04/25/17 07:40 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	41	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 18:19	EPA 200.8	
------	----	-----	------	---	---------	----------------	----------------	-----------	--

**1001-1 (7042769-02) Drinking Water (Grab) Sampled: 04/25/17 06:58 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 18:23	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1001-2 (7042769-03) Drinking Water (Grab) Sampled: 04/25/17 07:25 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 18:26	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1002-1 (7042769-04) Drinking Water (Grab) Sampled: 04/26/17 07:25 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 18:30	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1002-2 (7042769-05) Drinking Water (Grab) Sampled: 04/26/17 07:27 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 18:34	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1003-1 (7042769-06) Drinking Water (Grab) Sampled: 04/25/17 07:00 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 18:38	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1003-2 (7042769-07) Drinking Water (Grab) Sampled: 04/25/17 07:01 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 19

**1003-2 (7042769-07) Drinking Water (Grab) Sampled: 04/25/17 07:01 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 18:42	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1005.-1 (7042769-08) Drinking Water (Grab) Sampled: 04/26/17 07:23 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 18:53	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1005.-2 (7042769-09) Drinking Water (Grab) Sampled: 04/26/17 07:40 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 19:05	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1016 (7042769-10) Drinking Water (Grab) Sampled: 04/25/17 06:55 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 19:08	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1017-1 (7042769-11) Drinking Water (Grab) Sampled: 04/25/17 07:05 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 19:12	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1018-1 (7042769-12) Drinking Water (Grab) Sampled: 04/25/17 07:13 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 19:16	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1018-2 (7042769-13) Drinking Water (Grab) Sampled: 04/25/17 07:17 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 19:20	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

**1006-1 (7042769-14) Drinking Water (Grab) Sampled: 04/26/17 07:30 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Hawthorne Elementary School

Reported:  
05/11/17 15:09

**1006-1 (7042769-14) Drinking Water (Grab) Sampled: 04/26/17 07:30 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

#### Total Metals

Lead	21	5.0	ug/L	1	B7E1224	05/07/17 11:21	05/08/17 19:24	EPA 200.8	
------	----	-----	------	---	---------	----------------	----------------	-----------	--

#### Sample Condition Upon Receipt:

Temperature: 26.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

#### Case Narrative:

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

#### Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log


7042769-01

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District  
School Name  
Building (name/number)  
Type of Fixture (tap, drinking fountain etc.)  
Location of Fixture (example, room number)  
Sample Identification Number (**Write this number on the sample container and on this sheet**)  
Date of Collection  
Time of Collection  
Printed Name of Sample Collector  
Signature Sample Collector

Mesa Unified District
Hawthorne Elementary School
1015
TAP/SINK
K.I.N Room
1015
4-25-2017
7:40 AM
STACEY DUCIVAGE


Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Rec'd @ Lab 4/28/17 1600 26.02	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>


Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Hawthorne Elementary School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / sink
Location of Fixture (example, room number)	Building 1 Room 7
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-1
Date of Collection	4-25-2017
Time of Collection	6:58 AM
Printed Name of Sample Collector	Steve Durivage
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042769-03

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Hawthorne Elementary School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Water Cooler
Location of Fixture (example, room number)	Building 1 Teachers Lounge
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-2
Date of Collection	4-25-2017
Time of Collection	7:25
Printed Name of Sample Collector	Steve Dyrivage
Signature Sample Collector	Steve Dyrivage

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042769-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Hawthorne Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Building 3 Room 19
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002-1
Date of Collection	4-26-2017
Time of Collection	7:25 AM
Printed Name of Sample Collector	Steve Durivage
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042769-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Hawthorne Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Building 3 Room 21
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002-2
Date of Collection	4-26-2017
Time of Collection	7:27 AM
Printed Name of Sample Collector	Steve Rucavage
Signature Sample Collector	Steve Rucavage

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District  
School Name  
Building (name/number)  
Type of Fixture (tap, drinking fountain etc.)  
Location of Fixture (example, room number)  
Sample Identification Number (**Write this number on the sample container and on this sheet**)  
Date of Collection  
Time of Collection  
Printed Name of Sample Collector  
Signature Sample Collector

Mesa Unified District
Hawthorne Elementary School
1003
Water Cooler
Building 2 MPR
1003-1
4-25-2017
7:00 AM
Steve Buravage
Steve Buravage

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

704276A-07

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District  
School Name  
Building (name/number)  
Type of Fixture (tap, drinking fountain etc.)  
Location of Fixture (example, room number)  
Sample Identification Number (**Write this number on the sample container and on this sheet**)

Mesa Unified District
Hawthorne Elementary School
1003
Drinking Fountain / Sink
Building 2 Room 12
1003-2
4-25-2017
7:01 AM
Steve Bursage
Steve Bursage

Date of Collection  
Time of Collection  
Printed Name of Sample Collector  
Signature Sample Collector

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District  
School Name  
Building (name/number)  
Type of Fixture (tap, drinking fountain etc.)  
Location of Fixture (example, room number)  
Sample Identification Number (**Write this number on the sample container and on this sheet**)  
Date of Collection  
Time of Collection  
Printed Name of Sample Collector  
Signature Sample Collector

Mesa Unified District
Hawthorne Elementary School
1005
Drinking Fountain
MELP Room 45
1005-1
4-26-2017
7:23 AM
Steve Durinaga
Jan 18

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District  
School Name  
Building (name/number)  
Type of Fixture (tap, drinking fountain etc.)  
Location of Fixture (example, room number)  
Sample Identification Number (**Write this number on the sample container and on this sheet**)  
Date of Collection  
Time of Collection  
Printed Name of Sample Collector  
Signature Sample Collector

Mesa Unified District
Hawthorne Elementary School
1005
Sink / Tap
MELP Room 45
1005-2
4-26-2017
7:40 AM
Steve Duryage
Steve D

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Hawthorne Elementary School
Building (name/number)	1016
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain/sink
Location of Fixture (example, room number)	Building 1 Nurse/near door
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1016
Date of Collection	4-25-2016
Time of Collection	6:55 AM
Printed Name of Sample Collector	Steve Durivage
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District  
School Name  
Building (name/number)  
Type of Fixture (tap, drinking fountain etc.)  
Location of Fixture (example, room number)  
Sample Identification Number (**Write this number on the sample container and on this sheet**)  
Date of Collection  
Time of Collection  
Printed Name of Sample Collector  
Signature Sample Collector

Mesa Unified District
Hawthorne Elementary School
1017
Drinking Fountain / Sink
Building 5 Room 36
1017-1
4-25-2017
7:05 Am
Steve Duvvage
Steve Duvvage

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

704276912

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Hawthorne Elementary School
Building (name/number)	1018
Type of Fixture (tap, drinking fountain etc.)	Outside Drinking Fountain
Location of Fixture (example, room number)	Building 4 Near Restrooms
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1018-1
Date of Collection	4-25-2017
Time of Collection	7:13 AM
Printed Name of Sample Collector	Steve Durivage
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042769-13

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Hawthorne Elementary School
Building (name/number)	1018
Type of Fixture (tap, drinking fountain etc.)	Water Cooler
Location of Fixture (example, room number)	Building 4, Small Gym, Shortest
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1018-2
Date of Collection	4-25-17
Time of Collection	7:17 AM
Printed Name of Sample Collector	Steve Durivage
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*




ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042789-14

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Hawthorne Elementary School
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Room 47
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1006-1
Date of Collection	4-26-2017
Time of Collection	7:30 AM
Printed Name of Sample Collector	Steve Dugan
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Hawthorne Elementary School	1001	A100 B1	Admin/Media/Class	1962	2
Mesa Unified District	Hawthorne Elementary School	1002	A200 B3	Classroom	1962	2
Mesa Unified District	Hawthorne Elementary School	1003	A300 B2	MPR/Classroom	1962	2
Mesa Unified District	Hawthorne Elementary School	1005	A500 R-542 MELP	Classroom	1985	2
Mesa Unified District	Hawthorne Elementary School	1015	A1500 Kiln	Kiln, Storage	1979	2
Mesa Unified District	Hawthorne Elementary School	1016	A1000 office	Office Addition (Addn. to Bldg 1001)	1999	1
Mesa Unified District	Hawthorne Elementary School	1017	A17000 B-5	MPR, Classroom	2003	1
Mesa Unified District	Hawthorne Elementary School	1018	A1900 B-4	Mechanical	1978	2
Mesa Unified District	Hawthorne Elementary School	1019/1006	A600, R274 Room 47	Classrooms	1988	1
Address: 630 N Hunt Dr. Mesa, AZ 85203					Number of Bottles Per Kit:	15

~~Building 3 1002 2~~  
~~MELP 1005 1~~  
~~Kinder PG 1006 1~~  
~~Kiln Room 1015 1~~

14

