

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Irving Elementary School

Reported:  
05/12/17 10:17

## Analyte

**1001-1 (7042778-01) Drinking Water (Grab) Sampled: 04/27/17 06:00 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 02:25	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1001-2 (7042778-02) Drinking Water (Grab) Sampled: 04/27/17 06:01 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 02:29	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1002-1 (7042778-03) Drinking Water (Grab) Sampled: 04/27/17 05:31 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 02:32	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1002-2 (7042778-04) Drinking Water (Grab) Sampled: 04/27/17 05:35 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 02:44	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1003-1 (7042778-05) Drinking Water (Grab) Sampled: 04/27/17 05:44 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 02:56	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1003-2 (7042778-06) Drinking Water (Grab) Sampled: 04/27/17 05:43 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	13	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 03:00	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1004-1 (7042778-07) Drinking Water (Grab) Sampled: 04/27/17 05:58 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 26

**1004-1 (7042778-07) Drinking Water (Grab) Sampled: 04/27/17 05:58 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 03:03	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1004-2 (7042778-08) Drinking Water (Grab) Sampled: 04/27/17 05:57 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 03:07	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1005-1 (7042778-09) Drinking Water (Grab) Sampled: 04/27/17 05:49 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	9.4	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 03:11	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**1005-2 (7042778-10) Drinking Water (Grab) Sampled: 04/27/17 05:48 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	14	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 03:15	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1006-1 (7042778-11) Drinking Water (Grab) Sampled: 04/27/17 05:48 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	11	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 03:19	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1006-2 (7042778-12) Drinking Water (Grab) Sampled: 04/27/17 05:47 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	6.8	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 03:23	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**1007-1 (7042778-13) Drinking Water (Grab) Sampled: 04/27/17 05:41 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	17	5.0	ug/L	1	B7E1239	05/09/17 11:45	05/10/17 03:26	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1007-2 (7042778-14) Drinking Water (Grab) Sampled: 04/27/17 05:40 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**1007-2 (7042778-14) Drinking Water (Grab) Sampled: 04/27/17 05:40 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	13	5.0	ug/L	1	B7E1240	05/09/17 11:47	05/10/17 03:57	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1008-1 (7042778-15) Drinking Water (Grab) Sampled: 04/27/17 05:38 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	17	5.0	ug/L	1	B7E1240	05/09/17 11:47	05/10/17 04:00	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1008-2 (7042778-16) Drinking Water (Grab) Sampled: 04/27/17 05:37 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	9.6	5.0	ug/L	1	B7E1240	05/09/17 11:47	05/10/17 04:04	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**1009-1 (7042778-17) Drinking Water (Grab) Sampled: 04/27/17 05:35 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1240	05/09/17 11:47	05/10/17 04:08	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1009-2 (7042778-18) Drinking Water (Grab) Sampled: 04/27/17 05:34 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	12	5.0	ug/L	1	B7E1240	05/09/17 11:47	05/10/17 04:12	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1010-1 (7042778-19) Drinking Water (Grab) Sampled: 04/27/17 05:52 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7E1240	05/09/17 11:47	05/10/17 04:16	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1010-2 (7042778-20) Drinking Water (Grab) Sampled: 04/27/17 05:53 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	12	5.0	ug/L	1	B7E1240	05/09/17 11:47	05/10/17 04:27	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1011 (7042778-21) Drinking Water (Grab) Sampled: 04/27/17 05:55 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Irving Elementary School

Reported:  
05/12/17 10:17

**1011 (7042778-21) Drinking Water (Grab) Sampled: 04/27/17 05:55 Received: 04/28/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

#### Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1240	05/09/17 11:47	05/10/17 04:31	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

#### Sample Condition Upon Receipt:

Temperature: 27.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

#### Case Narrative:

**Holding Times:** All holding times were met unless otherwise qualified.

**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.

**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".

*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

#### Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.




ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	1001 M.P. R
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Multi Purpose Room
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-1
Date of Collection	4-27-17
Time of Collection	6:00 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received @ lab 4/28/17 1600 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-02

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	Multi Purpose room
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Kitchen
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-2
Date of Collection	4-27-17
Time of Collection	6:01
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	<i>Terrie Villalba</i>

1001

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-03

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	E/F building 1002
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	E/F building between restrooms
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002-1
Date of Collection	4-27-17
Time of Collection	5:31 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log


**Collection Log**

*for experienced sample collectors*

7042778-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	E/F E-3 1002
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002-2
Date of Collection	4-27-17
Time of Collection	5:35 PM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042778-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	CID building 1003
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Between restrooms
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1003-1
Date of Collection	4-27-17
Time of Collection	5:44 AM
Printed Name of Sample Collector	Terrie Villalobos
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042778-06

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School D-3
Building (name/number)	<del>B-3</del> C/D building 1003
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1003-2
Date of Collection	4-27-17
Time of Collection	8:43 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-07

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	A/B building 1004
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Between restrooms
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1004-1
Date of Collection	4-27-17
Time of Collection	5:58 AM
Printed Name of Sample Collector	Terric Villalba
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

**For relinquishing samples upon delivery to labs only**

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-08

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	A/B A-1 1004
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1004-2
Date of Collection	4-27-17
Time of Collection	5:57 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	<i>Terrie Villalba</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-09

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-3 1005
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Class room
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1005-1
Date of Collection	4-27-17
Time of Collection	5:49 AM
Printed Name of Sample Collector	Fernie Villalba
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-10

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-4 Portable 1005
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1005-2
Date of Collection	4-27-17
Time of Collection	5:48 AM
Printed Name of Sample Collector	Terrie Villa/b
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-11

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-5 Portable 1006
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1006-1
Date of Collection	4-27-17
Time of Collection	5:48 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-12

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-6 Portable 1006
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1006-2
Date of Collection	4-27-17
Time of Collection	5:47 AM
Printed Name of Sample Collector	Terrie Villalobos
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042778-13

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-8 Portable 1007
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1007-1
Date of Collection	4-27-17
Time of Collection	8:41 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-14

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-7 Portable 1007
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1007-2
Date of Collection	4-27-17
Time of Collection	5:40 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-15

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-9 Portable 1008
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1008-1
Date of Collection	4-27-17
Time of Collection	5:38 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

**For relinquishing samples upon delivery to labs only**

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-14

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-10 Portable 1008
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Custodial Office
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1008 - 2
Date of Collection	4-27-17
Time of Collection	8:37 Am
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2



ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

702778-17

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-11 Portable 1009
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1009-1
Date of Collection	4-27-17
Time of Collection	5:35 AM
Printed Name of Sample Collector	Jennie Villalba
Signature Sample Collector	J. Villalba

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-18

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-12 Portable 1009
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1009-2
Date of Collection	4-27-17
Time of Collection	5:34 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042778-19

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-1 Portable 1011
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1010-1
Date of Collection	4-27-17
Time of Collection	5:52 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	<i>T. Villalba</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log


**Collection Log**

for experienced sample collectors

7042778-20

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	T-2 Portable 1011
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Classroom
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1010 IN 4/30/17 1011-2 bottle has ID of 1010-2
Date of Collection	4-27-17
Time of Collection	5:53 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Chain marked wrong bottle has sample to date * Did not receive bottle in 4/30/17 the same Used bottle to log IN 4/30/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042778-21

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Irving Elementary School
Building (name/number)	APB building 1011
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	Between restrooms on Primary Play
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1011
Date of Collection	4-27-17
Time of Collection	5:55 AM
Printed Name of Sample Collector	Terrie Villalba
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

7042778

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Irving Elementary School	1001	A2000	Classroom/Workroom	1978	2
Mesa Unified District	Irving Elementary School	1002	A1000	Admin/Media	1978	2
Mesa Unified District	Irving Elementary School	1003	A3000	Classroom/Workroom	1978	2
Mesa Unified District	Irving Elementary School	1004	A4000	Classroom/Workroom	1978	2
Mesa Unified District	Irving Elementary School	1005	A5000 / R-206	Classroom	1984	2
Mesa Unified District	Irving Elementary School	1006	A6000 / R-120	Classroom	1983	2
Mesa Unified District	Irving Elementary School	1007	A7000 / R-019	Classroom	1984	2
Mesa Unified District	Irving Elementary School	1008	A8000 / R-020	Classroom	1983	2
Mesa Unified District	Irving Elementary School	1009	A9000 / R-169	Classroom	1984	2
Mesa Unified District	Irving Elementary School	1010	A10000 / R-207	Classroom	1984	2
Mesa Unified District	Irving Elementary School	1011	A11000	Restroom	1998	1
Address:	3220 E Pueblo, Mesa, AZ 85204				Number of Bottles Per Kit:	21