

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Lehi Elementary School

Reported:
05/04/17 16:52

Analyte

1001-1 (7042312-01) Drinking Water (Grab) Sampled: 04/18/17 06:33 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1732	04/26/17 14:28	04/27/17 00:32	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7042312-02) Drinking Water (Grab) Sampled: 04/18/17 06:33 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1732	04/26/17 14:28	04/27/17 00:36	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7042312-03) Drinking Water (Grab) Sampled: 04/18/17 07:30 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1732	04/26/17 14:28	04/27/17 00:40	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-2 (7042312-04) Drinking Water (Grab) Sampled: 04/18/17 07:30 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:11	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-1 (7042312-05) Drinking Water (Grab) Sampled: 04/19/17 06:25 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	20	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:14	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1003-2 (7042312-06) Drinking Water (Grab) Sampled: 04/19/17 06:25 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	14	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:18	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1004-1 (7042312-07) Drinking Water (Grab) Sampled: 04/18/17 07:21 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 28

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Lehi Elementary School

Reported:
05/04/17 16:52

1004-1 (7042312-07) Drinking Water (Grab) Sampled: 04/18/17 07:21 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	5.7	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:22	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1004-2 (7042312-08) Drinking Water (Grab) Sampled: 04/18/17 07:21 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	27	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:26	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1005-1 (7042312-09) Drinking Water (Grab) Sampled: 04/18/17 07:18 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	18	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:30	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1005-2 (7042312-10) Drinking Water (Grab) Sampled: 04/18/17 07:18 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.0	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:33	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1006-1 (7042312-11) Drinking Water (Grab) Sampled: 04/18/17 07:15 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	5.5	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:37	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1006-2 (7042312-12) Drinking Water (Grab) Sampled: 04/18/17 06:54 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	14	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:49	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1007-1 (7042312-13) Drinking Water (Grab) Sampled: 04/18/17 06:54 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	37	5.0	ug/L	1	B7D1736	04/26/17 14:31	04/27/17 01:52	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1007-2 (7042312-14) Drinking Water (Grab) Sampled: 04/18/17 06:55 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

1007-2 (7042312-14) Drinking Water (Grab) Sampled: 04/18/17 06:55 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	23	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:02	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1008-1 (7042312-15) Drinking Water (Grab) Sampled: 04/18/17 06:53 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	20	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:06	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1008-2 (7042312-16) Drinking Water (Grab) Sampled: 04/18/17 06:55 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	31	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:17	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1009-1 (7042312-17) Drinking Water (Grab) Sampled: 04/18/17 06:53 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	11	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:21	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1009-2 (7042312-18) Drinking Water (Grab) Sampled: 04/18/17 06:53 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	15	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:25	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1010-1 (7042312-19) Drinking Water (Grab) Sampled: 04/18/17 06:51 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	15	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:29	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1010-2 (7042312-20) Drinking Water (Grab) Sampled: 04/18/17 06:51 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	11	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:32	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1012-1 (7042312-21) Drinking Water (Grab) Sampled: 04/18/17 06:49 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

1012-1 (7042312-21) Drinking Water (Grab) Sampled: 04/18/17 06:49 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	16	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:44	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1014-1 (7042312-22) Drinking Water (Grab) Sampled: 04/18/17 06:25 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:48	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1015-1 (7042312-23) Drinking Water (Grab) Sampled: 04/18/17 06:27 Received: 04/24/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 20:51	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042312-01

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	DRINKING fountain
Location of Fixture (example, room number)	NURSE office
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-1
Date of Collection	4/18/2017
Time of Collection	6:33 AM
Printed Name of Sample Collector	Mirna Martinez
Signature Sample Collector	Mirna Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved Lab 4/25/17 155

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1001 Nurse Office
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	Nurse Office
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-2
Date of Collection	4/18/2017
Time of Collection	6:33 AM
Printed Name of Sample Collector	Mirna Martinez
Signature Sample Collector	Mirna Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REF on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presented @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-03

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1002 LPB
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	MULTI PURPOSE ROOM
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-1
Date of Collection	4/18/2017
Time of Collection	7:30 AM
Printed Name of Sample Collector	Mirana Martinez
Signature Sample Collector	Mirana Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from Adea Rep on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presend @ Lab 4/24/17 1155
ms
4/25/17

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-04

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1002 M.P.R.
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Multipurpose Room
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-2
Date of Collection	4/18/2017
Time of Collection	7:30 AM
Printed Name of Sample Collector	Melina Martinez
Signature Sample Collector	Melina Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from Adea REP on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-05

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	CLASSROOM
Type of Fixture (tap, drinking fountain etc.)	1003 PORTABLE FI
Location of Fixture (example, room number)	TAP WATER
Sample Identification Number (Write this number on the sample container and on this sheet)	PORTABLE CLASSROOM FI CLASSROOM
Date of Collection	1003-1
Time of Collection	4/19/17
Printed Name of Sample Collector	6:25 AM
Signature Sample Collector	Miana Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presented @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Mesa Unified District
Lehi Elementary School
1003 Portable F1 CLASS ROOM
TAP WATER
Portable F1 CLASS ROOM
1003-2
4/19/17
6:25 AM
MIRNA MARTINEZ
MIRNA MARTINEZ

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from Adeq Rep on 4/24/17 at 1600	
20.00C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presumed @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1004 Portable F3
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Portable F3 F.T.P.
Sample Identification Number (Write this number on the sample container and on this sheet)	1004.1
Date of Collection	4/18/17
Time of Collection	7:21 AM
Printed Name of Sample Collector	Mirna Magtinez
Signature Sample Collector	Mirna Magtinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from Adeq REP on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presented Lab 4/25/17 1155

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-C

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1004 Portable F3
Type of Fixture (tap, drinking fountain etc.)	DRINKING fountain
Location of Fixture (example, room number)	Portable F3 F.T.P.
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-2
Date of Collection	4/18/17
Time of Collection	7:21 AM
Printed Name of Sample Collector	Milena Martinez
Signature Sample Collector	Milena Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ lab 4/25/17 JHS 1155

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-09

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1005 Portable G3
Type of Fixture (tap, drinking fountain etc.)	DRINKING fountain
Location of Fixture (example, room number)	PORTABLE G3
Sample Identification Number (Write this number on the sample container and on this sheet)	1005- ↑ From sample container w 4/25/17
Date of Collection	4/18/17
Time of Collection	7:18 AM
Printed Name of Sample Collector	Miana Martinez
Signature Sample Collector	Miana Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from Adeq on 4/24/17 at 1600
20.0°C	REP ON 4/25/17

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-10

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1005 Portables G3
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Portables G3
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-2
Date of Collection	4/18/2017
Time of Collection	7:18 AM
Printed Name of Sample Collector	MIRNA MARTINEZ
Signature Sample Collector	Mirna Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ REP on 4/24/17 at 1600	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presented @ lab 4/25/17 1155

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-11

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1006 Portable Classroom
Type of Fixture (tap, drinking fountain etc.)	DRINKING fountain
Location of Fixture (example, room number)	Portable classroom #1
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-1
Date of Collection	4/18/17
Time of Collection	7:15 AM
Printed Name of Sample Collector	Miana Martinez
Signature Sample Collector	Miana Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-1

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1007 Portable classroom
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	portable classroom H3
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-2
Date of Collection	4/18/17
Time of Collection	6:54 AM
Printed Name of Sample Collector	Melina Martinez
Signature Sample Collector	Melina Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from Adeq Rep on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presend @ lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-13

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1007 Portable Classroom
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Portable Classroom H3
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-21 Info from sample container
Date of Collection	4/18/17
Time of Collection	6:54 AM
Printed Name of Sample Collector	Melina Martinez
Signature Sample Collector	Melina Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ Ref on 4/24/17 at 1600	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Prescribed Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-1

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1008 Portable I I
Type of Fixture (tap, drinking fountain etc.)	DRINKING fountain
Location of Fixture (example, room number)	Portable I I
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-2
Date of Collection	4/18/17
Time of Collection	6:55
Printed Name of Sample Collector	Liliana Martinez
Signature Sample Collector	Liliana Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ REP on 4/24/17 at 1600	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Received @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-15

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1009 Portable classroom
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Portable classroom I-3
Sample Identification Number (Write this number on the sample container and on this sheet)	1008-1
Date of Collection	4/18/17
Time of Collection	6:53 AM
Printed Name of Sample Collector	Miana Martinez
Signature Sample Collector	Miana Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presented to lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-14

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1008 Portable #1
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Portable #1
Sample Identification Number (Write this number on the sample container and on this sheet)	1008-2
Date of Collection	4/18/17
Time of Collection	6:55 AM
Printed Name of Sample Collector	Kiana Martinez
Signature Sample Collector	Kiana Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ REP on 4/24/17 at 1600	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/25/17 11:55

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1009-1
Type of Fixture (tap, drinking fountain etc.)	1009-1 Portable Classroom
Location of Fixture (example, room number)	Drinking fountain
Sample Identification Number (Write this number on the sample container and on this sheet)	Portable classroom 43
Date of Collection	4/18/17
Time of Collection	7:00 AM
Printed Name of Sample Collector	Mirna Martinez
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
	20.0°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Received @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-18

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1009 Portable Classroom
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	Portable Classroom E3
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-2
Date of Collection	4/18/17
Time of Collection	6:53 AM
Printed Name of Sample Collector	Melina Martinez
Signature Sample Collector	Melina Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/25/17
1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7047312-19

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1010 Portable classroom
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Portable classroom #1
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-1
Date of Collection	4/18/17
Time of Collection	6:51 AM
Printed Name of Sample Collector	Rhina Martinez
Signature Sample Collector	Rhina Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved at Lab 4/25/17
1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1010 Portable classroom #1
Type of Fixture (tap, drinking fountain etc.)	DRINKING fountain
Location of Fixture (example, room number)	Portable Classroom #1
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-2
Date of Collection	4/18/17
Time of Collection	6:51 AM
Printed Name of Sample Collector	Miana Martinez
Signature Sample Collector	Miana Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ Rep on 4/24/17 at 1600 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042312-21

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1012 - CLASSROOM J1A
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	PORTABLES
Sample Identification Number (Write this number on the sample container and on this sheet)	1012-1
Date of Collection	4/18/2017
Time of Collection	6:49 AM
Printed Name of Sample Collector	MIRNA MARTINEZ
Signature Sample Collector	Mirna Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Released @ Lab 4/25/17 1155

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042312 -22

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1014 Music building.
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain.
Location of Fixture (example, room number)	North East of MPR.
Sample Identification Number (Write this number on the sample container and on this sheet)	1014-1
Date of Collection	4/18/2017
Time of Collection	6:25 AM
Printed Name of Sample Collector	MIRNA MARTINEZ
Signature Sample Collector	Mirna Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ REP ON 4/24/17 at 1600	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Presented @ Lab 4/25/17 USS

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042312-2

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lehi Elementary School
Building (name/number)	1015 - By Stand Alone Bathroom
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	By Stand Alone bathrooms
Sample Identification Number (Write this number on the sample container and on this sheet)	1015-1
Date of Collection	4/18/2017
Time of Collection	6:27 AM
Printed Name of Sample Collector	Mirna Martinez
Signature Sample Collector	Mirna Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ Rep on 4/24/17 at 1600	
20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

Preserved @ Lab 4/25/17 USS

7042312

District	School	Building No ↓	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Lehi Elementary School	1001	A1000	Admin/Class	1978	2
Mesa Unified District	Lehi Elementary School	1002	A2000	Multipurpose Bldg	1978	2
Mesa Unified District	Lehi Elementary School	1003	A3000 / R-170	Classroom	1983	2
Mesa Unified District	Lehi Elementary School	1004	A4000 / R-209	Family Tree Project	1984	2
Mesa Unified District	Lehi Elementary School	1005	A5000 / R-244	Classroom	1985	2
Mesa Unified District	Lehi Elementary School	1006	A6000 / R-245	Classroom	1985	2
Mesa Unified District	Lehi Elementary School	1007	A7000 / R-289	Classroom	1985	2
Mesa Unified District	Lehi Elementary School	1008	A8000 / R-283	Classroom	1985	2
Mesa Unified District	Lehi Elementary School	1009	A9000 / R-323	Classroom	1986	2
Mesa Unified District	Lehi Elementary School	1010	A10000 / R-322	Classroom	1986	2
Mesa Unified District	Lehi Elementary School	✓ 1012	A12000 / R-401	Classroom	1991	1
Mesa Unified District	Lehi Elementary School	✓ 1014	A14000	Music building	1998	1
Mesa Unified District	Lehi Elementary School	↓ 1015	A15000	Restroom Building	1998	1
Address:	2555 N Stapley Dr, Mesa, AZ 85203				Number of Bottles Per Kit:	23