

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Lincoln Elementary School

Reported:
05/08/17 11:46

Analyte

1001-1 (7042744-01) Drinking Water (Grab) Sampled: 04/18/17 06:08 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1191	05/05/17 09:15	05/05/17 18:36	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7042744-02) Drinking Water (Grab) Sampled: 04/18/17 06:04 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1191	05/05/17 09:15	05/05/17 18:42	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7042744-03) Drinking Water (Grab) Sampled: 04/18/17 05:38 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1191	05/05/17 09:15	05/05/17 18:44	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-2 (7042744-04) Drinking Water (Grab) Sampled: 04/18/17 05:34 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1191	05/05/17 09:15	05/05/17 18:46	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-1 (7042744-05) Drinking Water (Grab) Sampled: 04/18/17 05:51 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	36	5.0	ug/L	1	B7E1191	05/05/17 09:15	05/05/17 18:48	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1005-1 (7042744-06) Drinking Water (Grab) Sampled: 04/18/17 05:46 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:00	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1005-2 (7042744-07) Drinking Water (Grab) Sampled: 04/18/17 06:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 28

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Lincoln Elementary School

Reported:
05/08/17 11:46

1005-2 (7042744-07) Drinking Water (Grab) Sampled: 04/18/17 06:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:06	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1006-1 (7042744-08) Drinking Water (Grab) Sampled: 04/18/17 05:48 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:08	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1006-2 (7042744-09) Drinking Water (Grab) Sampled: 04/18/17 05:55 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:10	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1007-1 (7042744-10) Drinking Water (Grab) Sampled: 04/18/17 05:57 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:12	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1007-2 (7042744-11) Drinking Water (Grab) Sampled: 04/18/17 05:58 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:14	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1008-1 (7042744-12) Drinking Water (Grab) Sampled: 04/18/17 06:01 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:16	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1008-2 (7042744-13) Drinking Water (Grab) Sampled: 04/18/17 06:48 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:18	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009-1 (7042744-14) Drinking Water (Grab) Sampled: 04/18/17 06:10 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Lincoln Elementary School

Reported:
05/08/17 11:46

1009-1 (7042744-14) Drinking Water (Grab) Sampled: 04/18/17 06:10 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.2	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:20	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1011-1 (7042744-15) Drinking Water (Grab) Sampled: 04/18/17 06:06 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:22	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1013-1 (7042744-16) Drinking Water (Grab) Sampled: 04/18/17 06:17 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:32	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1013-2 (7042744-17) Drinking Water (Grab) Sampled: 04/18/17 06:14 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:34	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1014-1 (7042744-18) Drinking Water (Grab) Sampled: 04/18/17 06:19 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:36	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1014-2 (7042744-19) Drinking Water (Grab) Sampled: 04/18/17 06:37 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:38	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1015-1 (7042744-20) Drinking Water (Grab) Sampled: 04/18/17 06:22 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	5.9	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:40	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1015-2 (7042744-21) Drinking Water (Grab) Sampled: 04/18/17 06:40 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Lincoln Elementary School

Reported:
05/08/17 11:46

1015-2 (7042744-21) Drinking Water (Grab) Sampled: 04/18/17 06:40 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:42	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1016-1 (7042744-22) Drinking Water (Grab) Sampled: 04/18/17 06:12 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:44	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1017-1 (7042744-23) Drinking Water (Grab) Sampled: 04/18/17 05:42 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1192	05/05/17 09:30	05/05/17 19:46	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 27.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	east side by restrooms, by rooms 19, 23
Sample Identification Number (Write this number on the sample container and on this sheet)	1001 - 1
Date of Collection	4/18/17
Time of Collection	6:08
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
Recvd Lab 4/27/17 1600 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)

7042744-02

Mesa Unified District
Lincoln Elementary School
1001
drinking fountain
west side by rooms 22, 26
1001-2
4/18/17
6:04 am
Bonnie Roberts
Bonnie Roberts

Date of Collection
Time of Collection

Printed Name of Sample Collector
Signature Sample Collector

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Recvd @ Lab 4/27/17 1600 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	tap-sink
Location of Fixture (example, room number)	bathroom in the music room - MPR
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-1
Date of Collection	4/18/17
Time of Collection	5:38 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	<i>Bonnie Roberts</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Rec'd @ lab 4/27/17 1000 27.29	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042744-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	tap - sink
Location of Fixture (example, room number)	restroom in the kitchen
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-2
Date of Collection	4/18/17
Time of Collection	5:34 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
Rec'd @ 4/27/17 1000 27.20C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042744-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)

Mesa Unified District
Lincoln Elementary School
1003
sink
Media Center
1003-1
4/18/17
5:51 am
Bonnie Roberts
Bonnie Roberts

Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received Lab 4/17/17 1600 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1005
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	east side by restrooms, by rooms 15, 11
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1
Date of Collection	4/18/17
Time of Collection	5:46 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
Rec'd @ Lab 4/27/17 1600 27.22	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1005
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	west side outside wall by rooms 14, 18
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-2
Date of Collection	4/18/17
Time of Collection	6:00 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
Recvd @ Lab 4/27/17 1600 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042744-06

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1006 Office
Type of Fixture (tap, drinking fountain etc.)	cold drinking fountain
Location of Fixture (example, room number)	in the hallway by teachers mailboxes
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-1
Date of Collection	4/18/17
Time of Collection	5:48 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
Received lab 4/27/17 1000 27.200	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1006 office
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	North outside wall by rooms 1 and 2
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-2
Date of Collection	4/18/17
Time of Collection	5:55 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	<i>Bonnie Roberts</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Recvd @ lab 4/27/17 1600 27.200

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042744-10

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1007
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	East side outside wall by restrooms, rooms 7,3
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-1
Date of Collection	4/18/17
Time of Collection	5:57 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received Lab 4/27/17 1600 27.20C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1007
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	west, outside wall by rooms 10, 6
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-2
Date of Collection	4/18/17
Time of Collection	5:58 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	<i>Bonnie Roberts</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Recvd @ lab 4/18/17 1600 27.2°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042744-12

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1008
Type of Fixture (tap, drinking fountain etc.)	cold drinking fountain
Location of Fixture (example, room number)	in the breezeway of the 2-story building
Sample Identification Number (Write this number on the sample container and on this sheet)	1008-1
Date of Collection	4/18/17
Time of Collection	6:01 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received @ Lab 4/27/17 1600 27.200	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042744-13

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1008
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	upstairs, two-story building in room 47
Sample Identification Number (Write this number on the sample container and on this sheet)	1008-2
Date of Collection	4/18/17
Time of Collection	6:48 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
Rec'd @ Lab 4/27/17 1000 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1009
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	inside of portable room 29, 30
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-1
Date of Collection	4/18/17
Time of Collection	6:10 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received @ lab 4/27/17 1600 27.200	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1011 Orchestra room
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	inside room 53
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-1
Date of Collection	4/18/17
Time of Collection	6:06 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Recvd @ Lab 4/27/17 1600 27.20C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1013
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	girls restroom, West portables by rooms 49-50
Sample Identification Number (Write this number on the sample container and on this sheet)	1013-1
Date of Collection	4/18/17
Time of Collection	6:17 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Rec'd @ lab 4/27/17 1600 27.20C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042744 - 11

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	P.E. fenced basketball court
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	east side of fencing
Sample Identification Number (Write this number on the sample container and on this sheet)	1013-2
Date of Collection	4/18/17
Time of Collection	6:14 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received @ Lab 4/18/17 11:00 27.2°C

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7012744-18

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1014
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	west portables room 49
Sample Identification Number (Write this number on the sample container and on this sheet)	1014-1
Date of Collection	4/18/17
Time of Collection	6:19 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	
Received @ Lab 4/18/17 1000 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

2042744-19

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1014
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	West Portables room 50
Sample Identification Number (Write this number on the sample container and on this sheet)	1014-2
Date of Collection	4/18/17
Time of Collection	6:37 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Rec'd @ Lab 4/27/17 1600 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042744-20

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1015
Type of Fixture (tap, drinking fountain etc.)	sink
Location of Fixture (example, room number)	West portables room 51
Sample Identification Number (Write this number on the sample container and on this sheet)	1015-1
Date of Collection	4/18/17
Time of Collection	6:22 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Recvd @ Lab 4/27/17 11000 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Lincoln Elementary School
Building (name/number)	1015
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	NW outside wall of Kinder-U room 52
Sample Identification Number (Write this number on the sample container and on this sheet)	1015-2
Date of Collection	4/18/17
Time of Collection	6:40 am
Printed Name of Sample Collector	Bonnie Roberts
Signature Sample Collector	Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received lab 4/27/17 1600 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042744-22

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)

Mesa Unified District
Lincoln Elementary School
1016
cold drinking fountain
inside west wall of cougar cave 1016
1016-1
4/18/17
6:12 am
Bonnie Roberts
Bonnie Roberts

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received @ lab 4/18/17 1600 27.20C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)

7042244-23

Mesa Unified District
Lincoln Elementary School
1017
cold drinking fountain
west wall in the MPR
1017-1
4/18/17
5:42 am
Bonnie Roberts
Bonnie Roberts

Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received @ lab 4/17/17 1600 27.2°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7042744

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building	
Mesa Unified District	Lincoln Elementary School	1001	A1000	Classroom	1958	2	✓
Mesa Unified District	Lincoln Elementary School	1002	A2000	Multipurpose/Class	1958	2	✓
Mesa Unified District	Lincoln Elementary School	1003	A3000	Media Center/Computer	1970	X ①	✓
Mesa Unified District	Lincoln Elementary School	1005 ✓	A5000	Classroom	1958	2	✓
Mesa Unified District	Lincoln Elementary School	1006	A6000	Classroom/Admin	1958	2	✓
Mesa Unified District	Lincoln Elementary School	1007	A7000	Classroom	1958	2	✓
Mesa Unified District	Lincoln Elementary School	1008	A8000	Classroom	1996	X ②	✓
Mesa Unified District	Lincoln Elementary School	1009	A9000 / R-300	Classroom	1986	X ①	✓
Mesa Unified District	Lincoln Elementary School	1011	A11000 / R-037 - Added back in	Classroom - Previously reported as REPLACED	1983	X ①	✓
Mesa Unified District	Lincoln Elementary School	1013	A13000 / R-150	Restroom	1983	X ①	
Mesa Unified District	Lincoln Elementary School	1014	A14000 / R-426	Family Tree Project	1985	2	✓
Mesa Unified District	Lincoln Elementary School	1015	A15000 / R-437	Classroom	1991	X ②	✓
Mesa Unified District	Lincoln Elementary School	1017	A16000	MPR	2002	1	
Address:	Lincoln E Lincoln E	1013 1015	outside drinking fountain recess recess			Number of Bottles Per Kit:	② 23
930 S Sirrine, Mesa, AZ 85210							