

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ 85007

Project: School Lead Testing Screening  
Project Number: Longfellow Elementary School

Reported:  
05/04/17 17:00

## Analyte

**1001-1 (7042313-01) Drinking Water (Grab) Sampled: 04/18/17 06:04 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 21:03	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1001-2 (7042313-02) Drinking Water (Grab) Sampled: 04/18/17 06:07 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 21:07	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1002-1 (7042313-03) Drinking Water (Grab) Sampled: 04/18/17 06:11 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 21:11	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1002-2 (7042313-04) Drinking Water (Grab) Sampled: 04/18/17 06:13 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 21:14	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1003-1 (7042313-05) Drinking Water (Grab) Sampled: 04/18/17 06:20 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 21:18	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1003-2 (7042313-06) Drinking Water (Grab) Sampled: 04/18/17 06:21 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

## Total Metals

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 21:22	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1011-1 (7042313-07) Drinking Water (Grab) Sampled: 04/19/17 06:05 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

*Anna Teter*

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 21

**1011-1 (7042313-07) Drinking Water (Grab) Sampled: 04/19/17 06:05 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1827	04/28/17 13:23	04/28/17 21:26	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1012-1 (7042313-08) Drinking Water (Grab) Sampled: 04/18/17 06:18 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 21:56	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1013-1 (7042313-09) Drinking Water (Grab) Sampled: 04/18/17 06:29 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	28	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:00	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1013-2 (7042313-10) Drinking Water (Grab) Sampled: 04/18/17 06:30 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	15	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:04	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1014-1 (7042313-11) Drinking Water (Grab) Sampled: 04/18/17 06:26 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	20	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:08	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1014-2 (7042313-12) Drinking Water (Grab) Sampled: 04/18/17 06:27 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	12	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:11	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**1015-1 (7042313-13) Drinking Water (Grab) Sampled: 04/18/17 06:36 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:15	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1015-2 (7042313-14) Drinking Water (Grab) Sampled: 04/18/17 06:37 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard  
Arizona Department of Environmental Quality, PHX  
1110 W. Washington Street  
Phoenix, AZ85007

Project: School Lead Testing Screening  
Project Number: Longfellow Elementary School

Reported:  
05/04/17 17:00

**1015-2 (7042313-14) Drinking Water (Grab) Sampled: 04/18/17 06:37 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:19	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1016-1 (7042313-15) Drinking Water (Grab) Sampled: 04/18/17 06:32 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	<5.0	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:23	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

**1016-2 (7042313-16) Drinking Water (Grab) Sampled: 04/18/17 06:32 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	5.5	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:34	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

**1017-1 (7042313-17) Drinking Water (Grab) Sampled: 04/18/17 06:08 Received: 04/24/17 16:00**

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

**Total Metals**

Lead	31	5.0	ug/L	1	B7D1828	04/28/17 13:26	04/28/17 22:38	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

**Sample Condition Upon Receipt:**

Temperature: 20.00 °C  
All samples were received in acceptable condition unless noted otherwise in the case narrative.

**Case Narrative:**

**Holding Times:** All holding times were met unless otherwise qualified.  
**QA/QC Criteria:** All analyses met method requirements unless otherwise qualified.  
**Accreditations:** AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.  
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.  
**Comments:** There were no problems encountered during the processing of the samples, unless otherwise noted.  
All samples were analyzed on a "wet" basis unless designated as "dry weight".  
  
*Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.*

**Notes and Definitions**

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042313-01

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain - Outside
Location of Fixture (example, room number)	Between outside restrooms
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-1
Date of Collection	4-18-17
Time of Collection	6:04 AM
Printed Name of Sample Collector	Giovanni Pataciv
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
	20.0°C Preserved @ lab 4/25/17 10:11:45

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7047313-02

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 7
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1001-2
Date of Collection	4-18-17
Time of Collection	6:07 AM
Printed Name of Sample Collector	Giovanni Palacio
Signature Sample Collector	<i>Giovanni Palacio</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042313-03

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	Washing Sink
Location of Fixture (example, room number)	Kitchen
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002-1
Date of Collection	4-18-17
Time of Collection	10:11 AM
Printed Name of Sample Collector	Giovanni Palacios
Signature Sample Collector	<i>Giovanni Palacios</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145
For relinquishing samples upon delivery to labs only	

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042313-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Outside between the R.R.'s
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1002-2
Date of Collection	4-18-17
Time of Collection	6:13 AM
Printed Name of Sample Collector	Cheryl Ann Palacios
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042313-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain/Sink
Location of Fixture (example, room number)	Room 27
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1003 - 1
Date of Collection	4-14-17
Time of Collection	6:20 AM
Printed Name of Sample Collector	Giovanni Palacios
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
20.0°C	Preserved@lab 4/25/17 1145

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2




ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042313-06

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	Outside Drinking Fountain
Location of Fixture (example, room number)	Outside Room 2-5
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1003-2
Date of Collection	4-18-17
Time of Collection	6:21 AM
Printed Name of Sample Collector	Cecilia Salgado
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ REP on 4/24/17 at 1600 20.0°C Preserved@ lab 4/25/17 1145	
For relinquishing samples upon delivery to labs only	

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

7042313-07

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no flushing** was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1011
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain
Location of Fixture (example, room number)	Inside PE building (1011)
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1011-1
Date of Collection	4-19-17
Time of Collection	6:05 AM
Printed Name of Sample Collector	Giovanni Polanco
Signature Sample Collector	<i>Giovanni Polanco</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145
For relinquishing samples upon delivery to labs only	

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042313-08

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	102
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 103
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1012-1
Date of Collection	4-18-17
Time of Collection	6:18 AM
Printed Name of Sample Collector	Giovanni Palacios
Signature Sample Collector	<i>Giovanni Palacios</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145
For relinquishing samples upon delivery to labs only	

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042313-09

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1013
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 32
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1013-1
Date of Collection	4-18-17
Time of Collection	6:29 AM
Printed Name of Sample Collector	Giovanni Piccini
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ REP on 4/24/17 at 1600	
20.0°C Preserved@ lab 4/25/17 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7047313-10

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1013
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 33
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1013-2
Date of Collection	4-14-17
Time of Collection	6:30 AM
Printed Name of Sample Collector	Gloria M. Salas
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Relieved from ADEQ Rep on 4/24/17 at 1600	
20.0°C Preserved @ lab 4/25/17 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

for experienced sample collectors

7042313-11

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no flushing was done prior to sampling**

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1014
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 30
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1014-1
Date of Collection	4-28-17
Time of Collection	6:26 AM
Printed Name of Sample Collector	Lawrence P. P. P.
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7042313-12

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1014
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 31
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1014-2
Date of Collection	4-18-17
Time of Collection	6:27 AM
Printed Name of Sample Collector	Giovanni Palacio
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
	20.0°C Preserved @ lab 4/25/17 1145

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

7040313-13

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1015
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 36
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1015-1
Date of Collection	4-18-17
Time of Collection	6:36 AM
Printed Name of Sample Collector	Guerrero Palacios
Signature Sample Collector	<i>Guerrero Palacios</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ Rep on 4/24/17 at 1600	
20.0°C Preserved @ lab 4/25/17 1145	
For relinquishing samples upon delivery to labs only	

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2




ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling.

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1015
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 37
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1015-2
Date of Collection	4-18-17
Time of Collection	10:37 AM
Printed Name of Sample Collector	Giovanni Palazzo
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145
For relinquishing samples upon delivery to labs only	

Relinquished date and signature \_\_\_\_\_

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042313-15

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1016
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 34
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1016-1
Date of Collection	4-18-17
Time of Collection	6:32 AM
Printed Name of Sample Collector	Giovanni Pateo
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ REP on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145

*For relinquishing samples upon delivery to labs only*

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no flushing** was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1016
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain / Sink
Location of Fixture (example, room number)	Room 25
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1016-2
Date of Collection	4-18-17
Time of Collection	6:32 AM
Printed Name of Sample Collector	Chadman Palau
Signature Sample Collector	<i>Chadman Palau</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received from ADEQ REP on 4/24/17 at 1600 20.0°C Preserved @ Lab 4/25/17 1145	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

7042313-17

**Collection Log**

*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Longfellow Elementary School
Building (name/number)	1017
Type of Fixture (tap, drinking fountain etc.)	Shower/Eyewash Station
Location of Fixture (example, room number)	Inside Mechanical enclosure
Sample Identification Number ( <b>Write this number on the sample container and on this sheet</b> )	1017-1
Date of Collection	4-19-17
Time of Collection	6:08 AM
Printed Name of Sample Collector	Courteney Palmer
Signature Sample Collector	<i>Courteney Palmer</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received from ADEQ Rep on 4/24/17 at 1600
20.0°C	Preserved @ lab 4/25/17 1145
For relinquishing samples upon delivery to labs only	

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

7042313

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Longfellow Elementary School	1001	A1000	Admin/Class	1961	2
Mesa Unified District	Longfellow Elementary School	1002	A2000	Multipurpose Bldg	1961	2
Mesa Unified District	Longfellow Elementary School	1003	A3000	Classroom	1961	2
Mesa Unified District	Longfellow Elementary School	1010	A10000	Custodial/Kiln	1976	2
Mesa Unified District	Longfellow Elementary School	1011	A11000	MPR	2002	1
Mesa Unified District	Longfellow Elementary School	1012	A12000	Classrooms	2002	1
Mesa Unified District	Longfellow Elementary School	1013	R325 - Moved from Johnson	Classroom	1986	2
Mesa Unified District	Longfellow Elementary School	1014	R287 - Moved from MacArthur	Classroom	1984	2
Mesa Unified District	Longfellow Elementary School	1015	R349 - moved from Jordan	Classrooms	1984	2
Mesa Unified District	Longfellow Elementary School	1017	Mechanical room	Mechanical room	1986	2
Mesa Unified District	Longfellow Elementary School	<del>1018/1016</del> 1015	R337 - Moved from Salk	Classroom	1986	2
Address:	345 S Hall St, Mesa, AZ 85204				Number of Bottles Per Kit:	20