

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Taft Elementary School

Reported:
05/05/17 15:49

Analyte

1001-1 (7042679-01) Drinking Water (Grab) Sampled: 04/21/17 06:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0972	05/01/17 17:00	05/01/17 22:39	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7042679-02) Drinking Water (Grab) Sampled: 04/21/17 06:02 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0972	05/01/17 17:00	05/01/17 22:41	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7042679-03) Drinking Water (Grab) Sampled: 04/21/17 06:12 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0972	05/01/17 17:00	05/01/17 22:44	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-2 (7042679-04) Drinking Water (Grab) Sampled: 04/21/17 06:06 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0972	05/01/17 17:00	05/01/17 22:46	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-1 (7042679-05) Drinking Water (Grab) Sampled: 04/21/17 06:19 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0972	05/01/17 17:00	05/01/17 22:49	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-2 (7042679-06) Drinking Water (Grab) Sampled: 04/21/17 06:22 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:03	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-1 (7042679-07) Drinking Water (Grab) Sampled: 04/21/17 06:23 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 24

1004-1 (7042679-07) Drinking Water (Grab) Sampled: 04/21/17 06:23 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:07	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-2 (7042679-08) Drinking Water (Grab) Sampled: 04/21/17 06:26 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	5.7	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:11	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1005-1 (7042679-09) Drinking Water (Grab) Sampled: 04/21/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:15	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1005-2 (7042679-10) Drinking Water (Grab) Sampled: 04/21/17 06:32 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:18	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1006-1 (7042679-11) Drinking Water (Grab) Sampled: 04/21/17 06:37 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	15	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:22	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1006-2 (7042679-12) Drinking Water (Grab) Sampled: 04/21/17 06:40 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	8.6	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:26	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1011-1 (7042679-13) Drinking Water (Grab) Sampled: 04/21/17 06:50 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:30	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1012-1 (7042679-14) Drinking Water (Grab) Sampled: 04/21/17 06:53 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Taft Elementary School

Reported:
05/05/17 15:49

1012-1 (7042679-14) Drinking Water (Grab) Sampled: 04/21/17 06:53 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.3	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:34	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1012-2 (7042679-15) Drinking Water (Grab) Sampled: 04/21/17 06:57 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:37	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1014-1 (7042679-16) Drinking Water (Grab) Sampled: 04/21/17 07:04 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 11:56	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1017-1 (7042679-17) Drinking Water (Grab) Sampled: 04/21/17 06:59 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 12:00	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1019-1 (7042679-18) Drinking Water (Grab) Sampled: 04/21/17 06:45 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0973	05/02/17 09:32	05/02/17 12:04	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1020-1 (7042679-19) Drinking Water (Grab) Sampled: 04/21/17 06:42 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0974	05/02/17 09:36	05/02/17 13:45	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Sample Condition Upon Receipt:

Temperature: 27.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.


Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1001 - 1
Type of Fixture (tap, drinking fountain etc.)	OUTSIDE DRINKING FOUNTAIN
Location of Fixture (example, room number)	BETWEEN ROOM 7 - 8
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-1
Date of Collection	4/21/17
Time of Collection	6:00
Printed Name of Sample Collector	JOSE B. CESPEDES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Received at lab 4/27/17 @ 1600

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042679-02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1001-2
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 8
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-2
Date of Collection	4/21/17
Time of Collection	6:02
Printed Name of Sample Collector	JOSE G. CESPEDES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042679-03

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1002-1
Type of Fixture (tap, drinking fountain etc.)	OUTSIDE DRINKING FOUNTAIN
Location of Fixture (example, room number)	BETWEEN ROOM 15-14
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-1
Date of Collection	4/21/17
Time of Collection	6:12
Printed Name of Sample Collector	JOSE G. CESPEDES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1002-2
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 16
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-2
Date of Collection	4/21/17
Time of Collection	6:06
Printed Name of Sample Collector	JOSE G CASPEDES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1003-1
Type of Fixture (tap, drinking fountain etc.)	MPB DRINKING FOUNTAIN
Location of Fixture (example, room number)	MPR
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-1
Date of Collection	4/21/17
Time of Collection	6:19
Printed Name of Sample Collector	JOSE G. CESPEDES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1003-2
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	KITCHEN
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-2
Date of Collection	4/21/17
Time of Collection	6:22
Printed Name of Sample Collector	JOSE G CESPEDES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042679-07

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1004 - 1
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 18
Sample Identification Number (Write this number on the sample container and on this sheet)	1004 - 1
Date of Collection	4/21/12
Time of Collection	6:23
Printed Name of Sample Collector	JOSE G CESPEDES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042679-08

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1004-2
Type of Fixture (tap, drinking fountain etc.)	PINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 19
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-2
Date of Collection	4/21/17
Time of Collection	6:26
Printed Name of Sample Collector	JOSE G. CESPEDES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042679-09

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1005-1
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 32
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1
Date of Collection	4/21/17
Time of Collection	6:30
Printed Name of Sample Collector	JOSE G CESPEDES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

7042679 -10

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1005-2
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 33
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-2
Date of Collection	4/21/17
Time of Collection	6:32
Printed Name of Sample Collector	JOSE G. CESPEDES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1006 - 1
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 34
Sample Identification Number (Write this number on the sample container and on this sheet)	1006 - 1
Date of Collection	4/21/17
Time of Collection	6:37
Printed Name of Sample Collector	JOSE G CESPEDES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042679-12

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1006-2
Type of Fixture (tap, drinking fountain etc.)	SINK FOUNTAIN
Location of Fixture (example, room number)	ROOM 35
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-2
Date of Collection	4/21/17
Time of Collection	6:40
Printed Name of Sample Collector	JOSE G CESPEDES
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

704269-13

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1011 - 1
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 38
Sample Identification Number (Write this number on the sample container and on this sheet)	1001 - 1
Date of Collection	4/24/17
Time of Collection	6:50
Printed Name of Sample Collector	JOSE G CESPEDES
Signature Sample Collector	<i>JGC</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1012 - 1
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 41
Sample Identification Number (Write this number on the sample container and on this sheet)	1012 - 1
Date of Collection	4/21/12
Time of Collection	6:53
Printed Name of Sample Collector	JOS E G CESPEDES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1012-2
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 2.40?
Sample Identification Number (Write this number on the sample container and on this sheet)	1012-2
Date of Collection	4/21/17
Time of Collection	6:57
Printed Name of Sample Collector	JOSE G CESPEDES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042679-16

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1014 - 1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	REST ROOM 36
Sample Identification Number (Write this number on the sample container and on this sheet)	1014 - 1
Date of Collection	4/21/17
Time of Collection	7:04
Printed Name of Sample Collector	Jose R. Cepedex
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7012079-17

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1017-1
Type of Fixture (tap, drinking fountain etc.)	OUTSIDE DRINKING FOUNTAIN
Location of Fixture (example, room number)	REST ROOMS
Sample Identification Number (Write this number on the sample container and on this sheet)	1017-1
Date of Collection	4/21/17
Time of Collection	6:59
Printed Name of Sample Collector	JOSE G. CEPEDAS
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1019 - 1
Type of Fixture (tap, drinking fountain etc.)	SINK DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 23
Sample Identification Number (Write this number on the sample container and on this sheet)	1019 - 1
Date of Collection	4/21/17
Time of Collection	6:45
Printed Name of Sample Collector	JOSE G. CEPEDAS
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042679-19

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Taft Elementary School
Building (name/number)	1020-1
Type of Fixture (tap, drinking fountain etc.)	DRINKING FOUNTAIN
Location of Fixture (example, room number)	ROOM 28
Sample Identification Number (Write this number on the sample container and on this sheet)	1020-1
Date of Collection	4/21/17
Time of Collection	6:42
Printed Name of Sample Collector	JOSE G CESPERES
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

70762

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Taft Elementary School	1001	A1000	ADMN/CLASSROO MS	1965	2
Mesa Unified District	Taft Elementary School	1002	A2000	MEDIA/CLASSROO MS	1965	2
Mesa Unified District	Taft Elementary School	1003	A3000	MPR/KITCHEN	1973	2
Mesa Unified District	Taft Elementary School	1004	A4000	CLASSROOMS	1976	2
Mesa Unified District	Taft Elementary School	1005	A5000 / R-320	CLASSROOM	1983	2
Mesa Unified District	Taft Elementary School	1006	A6000 / R-175	CLASSROOM	1986	2
Mesa Unified District	Taft Elementary School	1011	A15000 / R-544	CLASSROOMS	1996	1
Mesa Unified District	Taft Elementary School	1012	A16000 / R-035	CLASSROOMS	1980	2
Mesa Unified District	Taft Elementary School	1013 1017	A17000	REST ROOMS	1996	1
Mesa Unified District	Taft Elementary School	1014 1016	A19000	Classrooms	2001	1
Mesa Unified District	Taft Elementary School	1017 1019	A6000 R-378	Classroom	1986	2
Address:	9800 E Quarterline Rd, Mesa, AZ 85207				Number of Bottles Per Kit:	19