

### Technical Report for

**Arizona Dept. of Environmental Quality**

**School District, Lead in Drinking Water Testing**

**Eisenhower Elementary School/Mesa Unified District**

**SGS Accutest Job Number: LA32791**

**Sampling Date: 04/18/17**

#### Report to:

Arizona Dept. of Environmental Quality  
1110 West Washington Street  
Phoenix, AZ 85007  
db2@azdeq.gov; vs3@azdeq.gov;  
diaz.stephanie@azdeq.gov; margallo.emildavid@azdeq.gov;  
ATTN: David Burchard

**Total number of pages in report: 69**



Test results contained within this data package meet the requirements  
of the National Environmental Laboratory Accreditation Program  
and/or state specific certification programs as applicable.

*Ron Benjamin*  
**Ron Benjamin**  
**Lab Director**

**Client Service contact: Anita Patel 337-237-4775**

Certifications: LDEQ(2048), LDHH(LA150012), AR(14-045-04), AZ(AZ0805), FL(E87657), IL(200082), KY(#31),  
NC(487), SC(73004001), NJ(LA007), TX(T104704186-15-7), WV(257)

This report shall not be reproduced, except in its entirety, without the written approval of SGS Accutest.  
Test results relate only to samples analyzed.

# Table of Contents

-1-

**Section 1: Sample Summary ..... 3**

**Section 2: Summary of Hits ..... 5**

**Section 3: Sample Results ..... 7**

**3.1:** LA32791-1: 1001-1 ..... 8

**3.2:** LA32791-2: 1001-2 ..... 9

**3.3:** LA32791-3: 1003-1 ..... 10

**3.4:** LA32791-4: 1003-2 ..... 11

**3.5:** LA32791-5: 1004-1 ..... 12

**3.6:** LA32791-6: 1004-2 ..... 13

**3.7:** LA32791-7: 1005-1 ..... 14

**3.8:** LA32791-8: 1005-2 ..... 15

**3.9:** LA32791-9: 1010-1 ..... 16

**3.10:** LA32791-10: 1010-2 ..... 17

**3.11:** LA32791-11: 1011-1 ..... 18

**3.12:** LA32791-12: 1011-2 ..... 19

**3.13:** LA32791-13: 1012-1 ..... 20

**3.14:** LA32791-14: 1012-2 ..... 21

**3.15:** LA32791-15: 1014-1 ..... 22

**3.16:** LA32791-16: 1014-2 ..... 23

**3.17:** LA32791-17: 1015-1 ..... 24

**3.18:** LA32791-18: 1015-2 ..... 25

**3.19:** LA32791-19: 1018-1 ..... 26

**3.20:** LA32791-20: 1019-1 ..... 27

**Section 4: Misc. Forms ..... 28**

**4.1:** Chain of Custody ..... 29

**Section 5: Metals Analysis - QC Data Summaries ..... 54**

**5.1:** Prep QC MP7782: Pb ..... 55

**5.2:** Prep QC MP7783: Pb ..... 60

**5.3:** Prep QC MP7784: Pb ..... 65

## Sample Summary

Arizona Dept. of Environmental Quality

Job No: LA32791

School District, Lead in Drinking Water Testing

Project No: Eisenhower Elementary School/Mesa Unified District

Sample Number	Collected Date	Time By	Received	Matrix Code	Type	Client Sample ID
LA32791-1	04/18/17	06:05 TW	04/25/17	DW	Drinking Water	1001-1
LA32791-2	04/18/17	06:05 TW	04/25/17	DW	Drinking Water	1001-2
LA32791-3	04/18/17	06:30 TW	04/25/17	DW	Drinking Water	1003-1
LA32791-4	04/18/17	06:10 TW	04/25/17	DW	Drinking Water	1003-2
LA32791-5	04/18/17	06:12 TW	04/25/17	DW	Drinking Water	1004-1
LA32791-6	04/18/17	06:12 TW	04/25/17	DW	Drinking Water	1004-2
LA32791-7	04/18/17	06:15 TW	04/25/17	DW	Drinking Water	1005-1
LA32791-8	04/18/17	06:15 TW	04/25/17	DW	Drinking Water	1005-2
LA32791-9	04/18/17	06:18 TW	04/25/17	DW	Drinking Water	1010-1
LA32791-10	04/18/17	06:17 TW	04/25/17	DW	Drinking Water	1010-2
LA32791-11	04/18/17	06:20 TW	04/25/17	DW	Drinking Water	1011-1
LA32791-12	04/18/17	06:21 TW	04/25/17	DW	Drinking Water	1011-2
LA32791-13	04/18/17	06:20 TW	04/25/17	DW	Drinking Water	1012-1



Sample Summary  
(continued)

Arizona Dept. of Environmental Quality

Job No: LA32791

School District, Lead in Drinking Water Testing  
Project No: Eisenhower Elementary School/Mesa Unified District

Sample Number	Collected Date	Time By	Received	Matrix Code	Type	Client Sample ID
LA32791-14	04/18/17	06:20 TW	04/25/17	DW	Drinking Water	1012-2
LA32791-15	04/18/17	06:22 TW	04/25/17	DW	Drinking Water	1014-1
LA32791-16	04/18/17	06:25 TW	04/25/17	DW	Drinking Water	1014-2
LA32791-17	04/18/17	06:26 TW	04/25/17	DW	Drinking Water	1015-1
LA32791-18	04/18/17	06:28 TW	04/25/17	DW	Drinking Water	1015-2
LA32791-19	04/18/17	06:30 TW	04/25/17	DW	Drinking Water	1018-1
LA32791-20	04/18/17	06:32 TW	04/25/17	DW	Drinking Water	1019-1

## Summary of Hits

Job Number: LA32791  
Account: Arizona Dept. of Environmental Quality  
Project: School District, Lead in Drinking Water Testing  
Collected: 04/18/17

Lab Sample ID Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
--------------------------	------------------	-----------------	----	-----	-------	--------

LA32791-1 1001-1

No hits reported in this sample.

LA32791-2 1001-2

No hits reported in this sample.

LA32791-3 1003-1

No hits reported in this sample.

LA32791-4 1003-2

Lead	2.8	1.0	ug/l	EPA 200.8
------	-----	-----	------	-----------

LA32791-5 1004-1

Lead	12.9	1.0	ug/l	EPA 200.8
------	------	-----	------	-----------

LA32791-6 1004-2

Lead	2.4	1.0	ug/l	EPA 200.8
------	-----	-----	------	-----------

LA32791-7 1005-1

Lead	4.6	1.0	ug/l	EPA 200.8
------	-----	-----	------	-----------

LA32791-8 1005-2

Lead	3.3	1.0	ug/l	EPA 200.8
------	-----	-----	------	-----------

LA32791-9 1010-1

Lead	7.9	1.0	ug/l	EPA 200.8
------	-----	-----	------	-----------

LA32791-10 1010-2

Lead	6.0	1.0	ug/l	EPA 200.8
------	-----	-----	------	-----------

LA32791-11 1011-1

Lead	8.8	1.0	ug/l	EPA 200.8
------	-----	-----	------	-----------

## Summary of Hits

Job Number: LA32791  
Account: Arizona Dept. of Environmental Quality  
Project: School District, Lead in Drinking Water Testing  
Collected: 04/18/17

Lab Sample ID Analyte	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
LA32791-12	1011-2					
Lead		8.3	1.0		ug/l	EPA 200.8
LA32791-13	1012-1					
Lead		12.2	1.0		ug/l	EPA 200.8
LA32791-14	1012-2					
Lead		21.6	1.0		ug/l	EPA 200.8
LA32791-15	1014-1					
Lead		2.5	1.0		ug/l	EPA 200.8
LA32791-16	1014-2					
Lead		2.3	1.0		ug/l	EPA 200.8
LA32791-17	1015-1					
Lead		5.6	1.0		ug/l	EPA 200.8
LA32791-18	1015-2					
Lead		1.2	1.0		ug/l	EPA 200.8
LA32791-19	1018-1					
Lead		1.7	1.0		ug/l	EPA 200.8
LA32791-20	1019-1					
Lead		1.9	1.0		ug/l	EPA 200.8

## **Sample Results**

---

## **Report of Analysis**

---

Report of Analysis

Client Sample ID:	1001-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-1	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	ND	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7782

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected



Report of Analysis

Client Sample ID:	1001-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-2	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	ND	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7782

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1003-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-3	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	ND	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7782

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1003-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-4	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	2.8	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7782

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1004-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-5	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	12.9	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7782

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1004-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-6	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	2.4	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7782

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1005-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-7	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	4.6	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7782

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1005-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-8	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	3.3	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1010-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-9	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	7.9	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected



Report of Analysis

Client Sample ID:	1010-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-10	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	6.0	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1011-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-11	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	8.8	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1011-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-12	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	8.3	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

## Report of Analysis

<b>Client Sample ID:</b>	1012-1	<b>Date Sampled:</b>	04/18/17
<b>Lab Sample ID:</b>	LA32791-13	<b>Date Received:</b>	04/25/17
<b>Matrix:</b>	DW - Drinking Water	<b>Percent Solids:</b>	n/a
<b>Project:</b>	School District, Lead in Drinking Water Testing		

## Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	12.2	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587

(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1012-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-14	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	21.6	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1014-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-15	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	2.5	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1014-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-16	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	2.3	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

## Report of Analysis

Client Sample ID:	1015-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-17	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

## Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	5.6	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587

(2) Prep QC Batch: MP7783

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected



## Report of Analysis

Client Sample ID:	1015-2	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-18	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

## Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	1.2	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587

(2) Prep QC Batch: MP7784

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1018-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-19	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	1.7	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7784

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

Report of Analysis

Client Sample ID:	1019-1	Date Sampled:	04/18/17
Lab Sample ID:	LA32791-20	Date Received:	04/25/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	School District, Lead in Drinking Water Testing		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	1.9	15	1.0	ug/l	1	05/04/17	05/07/17 RT	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA7587  
(2) Prep QC Batch: MP7784

RL = Reporting Limit  
MCL = Maximum Contamination Level (40 CFR 141)

ND = Not detected

**Misc. Forms****Custody Documents and Other Forms**

---

**Includes the following where applicable:**

- Chain of Custody

LA 32791

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Eisenhower Elementary School	1001	A1000	Admin/MPR/Class	1972	2
Mesa Unified District	Eisenhower Elementary School	1002	A2000 <sup>10024</sup> <sup>1002-3</sup> <sup>&gt; no water</sup>	Media/Computers	1972	2
Mesa Unified District	Eisenhower Elementary School	1003	A3000	Classroom/Workroom	1972	2
Mesa Unified District	Eisenhower Elementary School	1004	A4000	Classroom/Workroom	1972	2
Mesa Unified District	Eisenhower Elementary School	1005	A5000	Classroom/Workroom	1972	2
Mesa Unified District	Eisenhower Elementary School	1010	A10000 R-183	Classroom	1984	2
Mesa Unified District	Eisenhower Elementary School	1011	A11000 R-182	Classroom	1985	2
Mesa Unified District	Eisenhower Elementary School	1012	A12000 R-162	Classroom	1985	2
Mesa Unified District	Eisenhower Elementary School	1014	A14000 R-416	Classroom	1987	2
Mesa Unified District	Eisenhower Elementary School	1015	A15000 R-109	Classroom	1987	2
Mesa Unified District	Eisenhower Elementary School	1018	A18000	Classroom	1999	1
Mesa Unified District	Eisenhower Elementary School	1019	A19000	MPR	2002	1
Address:	848 N Mesa Dr, Mesa, AZ 85201				Number of Bottles Per Kit:	22

1- 250 ml n/p 3wz

22.1 DV260

20  
1  
1

# Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no flushing** was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	MPR
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-1
Date of Collection	4/18/2017
Time of Collection	6:05
Printed Name of Sample Collector	Timothy Ward
Signature Sample Collector	<i>Timothy Ward</i>

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature *4/18/17 8:10*

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

REC: *gdup*

REC: *LA Driver Initials HC*

REC: *Kayla Kidd 4-25-17 2:50p*

REL: *gdup 4-25-17 9:30*

REC: *LA Driver Initials HC*

REL: *22-1 04260*

<http://www.azed.gov/LeadScreeningProg>

10:00

2017

LA32791

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ✓ ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	drinking fountain
Location of Fixture (example, room number)	Admin - office
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-2
Date of Collection	6:05 4/18/2017
Time of Collection	6:05
Printed Name of Sample Collector	Timothy Ward
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no flushing** was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	N/A no water
Location of Fixture (example, room number)	Media
Sample Identification Number (Write this number on the sample container and on this sheet)	
Date of Collection	4/18/2017
Time of Collection	
Printed Name of Sample Collector	Tim Ward
Signature Sample Collector	Tim Ward

Notes Sample collector: no water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no flushing** was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	N/A No water
Location of Fixture (example, room number)	Master center
Sample Identification Number (Write this number on the sample container and on this sheet)	NO 20
Date of Collection	4/18/2017
Time of Collection	
Printed Name of Sample Collector	Tim Hladky
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

NO water

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☑ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain/sinks
Location of Fixture (example, room number)	B-4
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-1
Date of Collection	4/18/2017
Time of Collection	6-6:30
Printed Name of Sample Collector	Timothy Wale
Signature Sample Collector	<i>Timothy Wale</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature \_\_\_\_\_

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling**

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	drinking fountain/sink
Location of Fixture (example, room number)	A-4
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-2
Date of Collection	4/18/2017
Time of Collection	6:10
Printed Name of Sample Collector	Timothy Ward
Signature Sample Collector	<i>Timothy Ward</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1004
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	C-4
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-1
Date of Collection	4/18/2017
Time of Collection	6:12 AM
Printed Name of Sample Collector	T. M. H. H. H.
Signature Sample Collector	[Signature]

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1004
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	D-4
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-2
Date of Collection	6.12 4/18/2017
Time of Collection	6:12
Printed Name of Sample Collector	Timothy Wade
Signature Sample Collector	<i>Timothy Wade</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1005
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	E-3
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1
Date of Collection	4/18/2017
Time of Collection	6:15
Printed Name of Sample Collector	Timothy Wade
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1005
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	F-4
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-2
Date of Collection	4/18/2017
Time of Collection	6:15
Printed Name of Sample Collector	Timothy Ward
Signature Sample Collector	Timothy Ward

8

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no flushing** was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1010
Type of Fixture (tap, drinking fountain etc.)	Fountain/sink
Location of Fixture (example, room number)	F-10
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-1
Date of Collection	4/18/2017
Time of Collection	6:18
Printed Name of Sample Collector	T. Mottley Wood
Signature Sample Collector	<i>T. Mottley Wood</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



LA 32791

# Collection Log for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps  
in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1010
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	F-9
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-2
Date of Collection	4/18/2017
Time of Collection	6:17
Printed Name of Sample Collector	Timothy Ward
Signature Sample Collector	<i>Timothy Ward</i>

10

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

## Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

✓ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1011
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	F7-B
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-1
Date of Collection	4/18/2017
Time of Collection	6:30
Printed Name of Sample Collector	Timothy Ward
Signature Sample Collector	<i>Timothy Ward</i>

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1011
Type of Fixture (tap, drinking fountain etc.)	Drinking fountain/sink
Location of Fixture (example, room number)	7-8A
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-2
Date of Collection	4/18/2017
Time of Collection	6:21
Printed Name of Sample Collector	Timothy Ward
Signature Sample Collector	<i>Timothy Ward</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Mesa Unified District
Eisenhower Elementary School
1012
drinking fountain / sink
F-5
1012-1
4/8/2017
6:20
Timothy Webb
Samuel Webb

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA32791

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1012
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	F-6
Sample Identification Number (Write this number on the sample container and on this sheet)	1012-2
Date of Collection	4/18/2017
Time of Collection	6:20 am
Printed Name of Sample Collector	Timothy Ward
Signature Sample Collector	<i>Timothy Ward</i>

14

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Mesa Unified District
Eisenhower Elementary School
1014
drinking fountain / sink
B-7
1014-1
4/18/2017
6:22
Tim Ward
Sid Ward

Notes Sample collector:

Analyze this drinking water sample for lead
Date and Time Lab received
Signature
Notes:

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1014
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	B-2
Sample Identification Number (Write this number on the sample container and on this sheet)	1014-2
Date of Collection	4/18/2017
Time of Collection	6:25
Printed Name of Sample Collector	Tim Wells
Signature Sample Collector	<i>Tim Wells</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1015
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	B-6
Sample Identification Number (Write this number on the sample container and on this sheet)	1015-1
Date of Collection	4/18/2017
Time of Collection	6:26
Printed Name of Sample Collector	Tim Wade
Signature Sample Collector	<i>Tim Wade</i>

17

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*



LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
*for experienced sample collectors*

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1015
Type of Fixture (tap, drinking fountain etc.)	drinking fountain / sink
Location of Fixture (example, room number)	B-5
Sample Identification Number (Write this number on the sample container and on this sheet)	1015-2
Date of Collection	4/18/2017
Time of Collection	6:28
Printed Name of Sample Collector	Tim Walsh
Signature Sample Collector	<i>Tim Walsh</i>

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

*These samples were collected for lead screening purposes only and cannot be used for compliance.*

LA32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

**Collection Log**  
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

✓ Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Eisenhower Elementary School
Building (name/number)	1018
Type of Fixture (tap, drinking fountain etc.)	Fountain/sink
Location of Fixture (example, room number)	G-2
Sample Identification Number (Write this number on the sample container and on this sheet)	1018-1
Date of Collection	4/18/2017
Time of Collection	6:30
Printed Name of Sample Collector	Tim Walsh
Signature Sample Collector	<i>Tim Walsh</i>

Notes Sample collector:

Analyze this drinking water sample for lead	For Lab use only
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

LA 32791

ADEQ Public School Drinking Water Lead Screening Program  
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

Check this box to confirm that water had not been used at this tap or other taps in the area for 6 hours and no flushing was done prior to sampling

Mesa Unified District
Eisenhower Elementary School
1019
Drinking fountain / sink
K-1
1019-1
4/18/2017
6:32
Tina Walsh
Jessie O'Neal

20

Notes Sample collector:

Analyze this drinking water sample for lead
Date and Time Lab received
Signature
Notes:

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

201

SHIP DATE: 24APR11  
ACTWGT: 45.00 LB  
CAD: 10489527/NET3850

TO: HOLD AT FEDEX- SAMPLES  
ACCUTEST LABORATORIES-LAFAYETTE  
109 COMMISSION BLVD  
LAFAYETTE LA 70508  
(337) 237-4775 REF: ADEQ PROJECT  
INVT: DEPT: 0201

LAUS LFT

3 of 3  
MPS# 7789 7949 9251  
Mstr# 7789 7949 9310

TUE - 25 APR HOLD  
PRIORITY OVERNIGHT  
HLD 70508

HAL 00183 00183

FEDEX

COO'S

ACCUTEST

LA32791: Chain of Custody  
Page 24 of 25

## SGS Accutest Sample Receipt Summary

Job Number: LA32791

Client: ADEQ

Project: EISENHOWER ELEMENTARY

Date / Time Received: 4/25/2017 10:00:00 AM

Delivery Method: FedEx

Airbill #s: 778979499251

Cooler Temps (Initial/Adjusted): #1: (22.1/22.1):

### Cooler Security

	<u>Y</u>	<u>or</u>	<u>N</u>		<u>Y</u>	<u>or</u>	<u>N</u>
1. Custody Seals Present:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	3. COC Present:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. Custody Seals Intact:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	4. Smpl Dates/Time OK	<input checked="" type="checkbox"/>		<input type="checkbox"/>

### Cooler Temperature

	<u>Y</u>	<u>or</u>	<u>N</u>
1. Temp criteria achieved:	<input type="checkbox"/>		<input type="checkbox"/>
2. Thermometer ID:	<u>DV260;</u>		
3. Cooler media:	<u>No Ice</u>		
4. No. Coolers:	<u>1</u>		

### Quality Control Preservation

	<u>Y</u>	<u>or</u>	<u>N</u>	<u>N/A</u>
1. Trip Blank present / cooler:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Trip Blank listed on COC:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>
3. Samples preserved properly:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
4. VOCs headspace free:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>

### Sample Integrity - Documentation

	<u>Y</u>	<u>or</u>	<u>N</u>
1. Sample labels present on bottles:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. Container labeling complete:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
3. Sample container label / COC agree:	<input checked="" type="checkbox"/>		<input type="checkbox"/>

### Sample Integrity - Condition

	<u>Y</u>	<u>or</u>	<u>N</u>
1. Sample recvd within HT:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. All containers accounted for:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
3. Condition of sample:	<u>Intact</u>		

### Sample Integrity - Instructions

	<u>Y</u>	<u>or</u>	<u>N</u>	<u>N/A</u>
1. Analysis requested is clear:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
2. Bottles received for unspecified tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>	
3. Sufficient volume recvd for analysis:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
4. Compositing instructions clear:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>
5. Filtering instructions clear:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>

Comments

LA32791: Chain of Custody

Page 25 of 25

## Metals Analysis

5

### QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Matrix Spike and Duplicate Summaries
- Blank Spike and Lab Control Sample Summaries
- Serial Dilution Summaries

BLANK RESULTS SUMMARY  
Part 2 - Method Blanks

Login Number: LA32791  
Account: ADEQAZP - Arizona Dept. of Environmental Quality  
Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7782  
Matrix Type: DRINKING WATER

Methods: EPA 200.8  
Units: ug/l

Prep Date: 05/04/17

Metal	RL	IDL	MDL	MB raw	final
Aluminum	40	48	26		
Antimony	10	1.6	1.6		
Barium	10	.15	.64		
Beryllium	1.0	.03	.13		
Boron	40	2.3	5		
Calcium	400	27	57		
Lithium	4.0	.1	.21		
Lead	1.0	.045	.26	-0.27	<1.0
Molybdenum	4.0	.3	.87		
Potassium	200	34	18		
Uranium	2.0		.16		

Associated samples MP7782: LA32791-1, LA32791-2, LA32791-3, LA32791-4, LA32791-5, LA32791-6, LA32791-7

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7782  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32790-10 Original MS		Spikelot MPICPMS5 % Rec		QC Limits
Aluminum					
Antimony					
Barium					
Beryllium					
Boron					
Calcium					
Lithium					
Lead	0.45	198	200	98.8	70-130
Molybdenum					
Potassium					
Uranium					

Associated samples MP7782: LA32791-1, LA32791-2, LA32791-3, LA32791-4, LA32791-5, LA32791-6, LA32791-7

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(N) Matrix Spike Rec. outside of QC limits

(anr) Analyte not requested



MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7782  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32790-10 Original MSD	Spikelot MPICPMS5 % Rec	MSD RPD	QC Limit
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	0.45	215	200	107.3
Molybdenum				
Potassium				
Uranium				

Associated samples MP7782: LA32791-1, LA32791-2, LA32791-3, LA32791-4, LA32791-5, LA32791-6, LA32791-7

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(N) Matrix Spike Rec. outside of QC limits

(anr) Analyte not requested

SPIKE BLANK AND LAB CONTROL SAMPLE SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7782  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	BSP Result	Spikelot MPICPMS5	% Rec	QC Limits
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	195	200	97.5	85-115
Molybdenum				
Potassium				
Uranium				

Associated samples MP7782: LA32791-1, LA32791-2, LA32791-3, LA32791-4, LA32791-5, LA32791-6, LA32791-7

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(anr) Analyte not requested

# SERIAL DILUTION RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7782  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32790-10		QC	
	Original	SDL 1:5	%DIF	Limits
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	0.223	0.00	100.0(a)	0-10
Molybdenum				
Potassium				
Uranium				

Associated samples MP7782: LA32791-1, LA32791-2, LA32791-3, LA32791-4, LA32791-5, LA32791-6, LA32791-7

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(anr) Analyte not requested

(a) Percent difference acceptable due to low initial sample concentration (< 50 times IDL).

BLANK RESULTS SUMMARY  
Part 2 - Method Blanks

Login Number: LA32791  
Account: ADEQAZP - Arizona Dept. of Environmental Quality  
Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7783  
Matrix Type: DRINKING WATER

Methods: EPA 200.8  
Units: ug/l

Prep Date: 05/04/17

Metal	RL	IDL	MDL	MB raw	final
Aluminum	40	48	26		
Antimony	10	1.6	1.6		
Barium	10	.15	.64		
Beryllium	1.0	.03	.13		
Boron	40	2.3	5		
Calcium	400	27	57		
Lithium	4.0	.1	.21		
Lead	1.0	.045	.26	-0.28	<1.0
Molybdenum	4.0	.3	.87		
Potassium	200	34	18		
Uranium	2.0		.16		

Associated samples MP7783: LA32791-8, LA32791-9, LA32791-10, LA32791-11, LA32791-12, LA32791-13, LA32791-14, LA32791-15, LA32791-16, LA32791-17

Results < IDL are shown as zero for calculation purposes  
(\*) Outside of QC limits  
(anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7783  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32791-8 Original MS		Spikelot MPICPMS5 % Rec		QC Limits
Aluminum					
Antimony					
Barium					
Beryllium					
Boron					
Calcium					
Lithium					
Lead	3.3	202	200	99.4	70-130
Molybdenum					
Potassium					
Uranium					

Associated samples MP7783: LA32791-8, LA32791-9, LA32791-10, LA32791-11, LA32791-12, LA32791-13, LA32791-14, LA32791-15, LA32791-16, LA32791-17

Results < IDL are shown as zero for calculation purposes  
 (\*) Outside of QC limits  
 (N) Matrix Spike Rec. outside of QC limits  
 (anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7783  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32791-8 Original MSD	Spikelot MPICPMS5 % Rec	MSD RPD	QC Limit
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	3.3	192	200	94.4
			5.1	20
Molybdenum				
Potassium				
Uranium				

Associated samples MP7783: LA32791-8, LA32791-9, LA32791-10, LA32791-11, LA32791-12, LA32791-13, LA32791-14, LA32791-15, LA32791-16, LA32791-17

Results < IDL are shown as zero for calculation purposes  
 (\*) Outside of QC limits  
 (N) Matrix Spike Rec. outside of QC limits  
 (anr) Analyte not requested

SPIKE BLANK AND LAB CONTROL SAMPLE SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7783  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	BSP Result	Spikelot MPICPMS5	% Rec	QC Limits
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	191	200	95.5	85-115
Molybdenum				
Potassium				
Uranium				

Associated samples MP7783: LA32791-8, LA32791-9, LA32791-10, LA32791-11, LA32791-12, LA32791-13, LA32791-14, LA32791-15, LA32791-16, LA32791-17

Results < IDL are shown as zero for calculation purposes  
 (\*) Outside of QC limits  
 (anr) Analyte not requested

# SERIAL DILUTION RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7783  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32791-8 Original	SDL 1:5	%DIF	QC Limits
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	1.64	1.01	38.8*(a)	0-10
Molybdenum				
Potassium				
Uranium				

Associated samples MP7783: LA32791-8, LA32791-9, LA32791-10, LA32791-11, LA32791-12, LA32791-13, LA32791-14, LA32791-15, LA32791-16, LA32791-17

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(anr) Analyte not requested

(a) Percent difference acceptable due to low initial sample concentration.



BLANK RESULTS SUMMARY  
Part 2 - Method Blanks

Login Number: LA32791  
Account: ADEQAZP - Arizona Dept. of Environmental Quality  
Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7784  
Matrix Type: DRINKING WATER

Methods: EPA 200.8  
Units: ug/l

Prep Date: 05/04/17

Metal	RL	IDL	MDL	MB raw	final
Aluminum	40	48	26		
Antimony	10	1.6	1.6		
Barium	10	.15	.64		
Beryllium	1.0	.03	.13		
Boron	40	2.3	5		
Calcium	400	27	57		
Lithium	4.0	.1	.21		
Lead	1.0	.045	.26	-0.26	<1.0
Molybdenum	4.0	.3	.87		
Potassium	200	34	18		
Uranium	2.0		.16		

Associated samples MP7784: LA32791-18, LA32791-19, LA32791-20

Results < IDL are shown as zero for calculation purposes  
(\*) Outside of QC limits  
(anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7784  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32791-18 Original MS		Spikelot MPICPMS5 % Rec		QC Limits
Aluminum					
Antimony					
Barium					
Beryllium					
Boron					
Calcium					
Lithium					
Lead	1.2	212	200	105.4	70-130
Molybdenum					
Potassium					
Uranium					

Associated samples MP7784: LA32791-18, LA32791-19, LA32791-20

Results < IDL are shown as zero for calculation purposes  
 (\*) Outside of QC limits  
 (N) Matrix Spike Rec. outside of QC limits  
 (anr) Analyte not requested

MATRIX SPIKE AND DUPLICATE RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7784  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32791-18 Original MSD	Spikelot MPICPMS5 % Rec	MSD RPD	QC Limit
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	1.2	196	200	97.4
Molybdenum				
Potassium				
Uranium				

Associated samples MP7784: LA32791-18, LA32791-19, LA32791-20

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(N) Matrix Spike Rec. outside of QC limits

(anr) Analyte not requested

SPIKE BLANK AND LAB CONTROL SAMPLE SUMMARY

Login Number: LA32791

Account: ADEQAZP - Arizona Dept. of Environmental Quality  
Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7784

Methods: EPA 200.8

Matrix Type: DRINKING WATER

Units: ug/l

Prep Date:

05/04/17

Metal	BSP Result	Spikelot MPICPMS5	% Rec	QC Limits
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	195	200	97.5	85-115
Molybdenum				
Potassium				
Uranium				

Associated samples MP7784: LA32791-18, LA32791-19, LA32791-20

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(anr) Analyte not requested

SERIAL DILUTION RESULTS SUMMARY

Login Number: LA32791  
 Account: ADEQAZP - Arizona Dept. of Environmental Quality  
 Project: School District, Lead in Drinking Water Testing

QC Batch ID: MP7784  
 Matrix Type: DRINKING WATER

Methods: EPA 200.8  
 Units: ug/l

Prep Date: 05/04/17

Metal	LA32791-18 Original	SDL 1:5	%DIF	QC Limits
Aluminum				
Antimony				
Barium				
Beryllium				
Boron				
Calcium				
Lithium				
Lead	0.610	0.00	100.0(a)	0-10
Molybdenum				
Potassium				
Uranium				

Associated samples MP7784: LA32791-18, LA32791-19, LA32791-20

Results < IDL are shown as zero for calculation purposes

(\*) Outside of QC limits

(anr) Analyte not requested

(a) Percent difference acceptable due to low initial sample concentration (< 50 times IDL).