

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Roosevelt Elementary School

Reported:
05/05/17 16:14

Analyte

1001-1 (7042682-01) Drinking Water (Grab) Sampled: 04/26/17 05:53 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0977	05/02/17 10:33	05/02/17 18:01	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7042682-02) Drinking Water (Grab) Sampled: 04/26/17 05:54 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0977	05/02/17 10:33	05/02/17 18:05	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7042682-03) Drinking Water (Grab) Sampled: 04/26/17 05:56 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0977	05/02/17 10:33	05/02/17 18:09	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-2 (7042682-04) Drinking Water (Grab) Sampled: 04/26/17 06:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0977	05/02/17 10:33	05/02/17 18:12	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-1 (7042682-05) Drinking Water (Grab) Sampled: 04/26/17 06:03 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	35	5.0	ug/L	1	B7E0977	05/02/17 10:33	05/02/17 18:16	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1003-2 (7042682-06) Drinking Water (Grab) Sampled: 04/26/17 06:05 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	15	5.0	ug/L	1	B7E0978	05/02/17 10:35	05/02/17 18:47	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1004-1 (7042682-07) Drinking Water (Grab) Sampled: 04/26/17 06:10 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 17

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Roosevelt Elementary School

Reported:
05/05/17 16:14

1004-1 (7042682-07) Drinking Water (Grab) Sampled: 04/26/17 06:10 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	15	5.0	ug/L	1	B7E0978	05/02/17 10:35	05/02/17 18:50	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

1004-2 (7042682-08) Drinking Water (Grab) Sampled: 04/26/17 06:08 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0978	05/02/17 10:35	05/02/17 18:54	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1005-1 (7042682-09) Drinking Water (Grab) Sampled: 04/26/17 06:15 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0978	05/02/17 10:35	05/02/17 18:58	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1005-2 (7042682-10) Drinking Water (Grab) Sampled: 04/26/17 06:12 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.9	5.0	ug/L	1	B7E0978	05/02/17 10:35	05/02/17 19:02	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1014-1 (7042682-11) Drinking Water (Grab) Sampled: 04/26/17 06:18 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0978	05/02/17 10:35	05/02/17 19:13	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1015-1 (7042682-12) Drinking Water (Grab) Sampled: 04/26/17 06:20 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0978	05/02/17 10:35	05/02/17 19:17	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1016-1 (7042682-13) Drinking Water (Grab) Sampled: 04/26/17 06:23 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0978	05/02/17 10:35	05/02/17 19:21	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Sample Condition Upon Receipt:

Temperature: 27.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1001-1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Kitchen
Sample Identification Number (Write this number on the sample container and on this sheet)	1001 - 1
Date of Collection	4-26-17
Time of Collection	5:53 AM
Printed Name of Sample Collector	RON ROBINSON
Signature Sample Collector	


Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received @ lab 4/27/17 @ 1600	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.




ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042682-02

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1001-7
Type of Fixture (tap, drinking fountain etc.)	Drinking Fountain
Location of Fixture (example, room number)	M.P.E.
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-7
Date of Collection	4-26-17
Time of Collection	5:54 AM
Printed Name of Sample Collector	Bon Robinson
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682-03

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1002-1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Media
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-1
Date of Collection	4-26-17
Time of Collection	5:56 AM
Printed Name of Sample Collector	RON ROBINSON
Signature Sample Collector	Ron R

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682-04

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1002-2
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	Media
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-2
Date of Collection	4-26-17
Time of Collection	600 AM
Printed Name of Sample Collector	ROBINSON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682-05

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and no flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1003-1
Type of Fixture (tap, drinking fountain, etc.)	SINK
Location of Fixture (example, room number)	B-2
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-1
Date of Collection	4-26-17
Time of Collection	6:03 AM
Printed Name of Sample Collector	RON ROBINSON
Signature Sample Collector	Ron P

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682 - 06

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1003-7
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	B-6
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-7
Date of Collection	4-26-17
Time of Collection	6:05 AM
Printed Name of Sample Collector	RON ROBINSON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682-07

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1004-1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	C-4
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-1
Date of Collection	4-26-17
Time of Collection	6:10 AM
Printed Name of Sample Collector	PON ROBINSON
Signature Sample Collector	<i>Pon Robinson</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682-08

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1004-2
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	C-WORK ROOM
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-2
Date of Collection	4-26-17
Time of Collection	008 AM
Printed Name of Sample Collector	REN ROBINSON
Signature Sample Collector	<i>Ren Robinson</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7042682-09

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1005-1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	A-5
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1
Date of Collection	4-26-17
Time of Collection	6:55 AM
Printed Name of Sample Collector	Ryan Robinson
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682-10

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1005-7
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	A - WORK ROOM
Sample Identification Number (Write this number on the sample container and on this sheet)	10057
Date of Collection	4-26-17
Time of Collection	6:12 AM
Printed Name of Sample Collector	Don Robinson
Signature Sample Collector	<i>Don Robinson</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042682 -11

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1014-1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	D-4
Sample Identification Number (Write this number on the sample container and on this sheet)	1014-1
Date of Collection	4-26-17
Time of Collection	6:18 AM
Printed Name of Sample Collector	RON ROBINSON
Signature Sample Collector	Ron Robinson

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1015-1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	E-6
Sample Identification Number (Write this number on the sample container and on this sheet)	1015-1
Date of Collection	4-20-17
Time of Collection	6:20 AM
Printed Name of Sample Collector	RON ROBINSON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Roosevelt Elementary School
Building (name/number)	1016-1
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	F-Boys RR
Sample Identification Number (Write this number on the sample container and on this sheet)	1016-1
Date of Collection	4-26-17
Time of Collection	6:23 AM
Printed Name of Sample Collector	RON ROBINSON
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Roosevelt Elementary School	1001	A1000	Admin/MPR	1972	2
Mesa Unified District	Roosevelt Elementary School	1002	A2000	Media/Classroom	1972	2
Mesa Unified District	Roosevelt Elementary School	1003	A3000	Classroom	1972	2
Mesa Unified District	Roosevelt Elementary School	1004	A4000	Classroom	1972	2
Mesa Unified District	Roosevelt Elementary School	1005	A5000	Classroom	1972	2
Mesa Unified District	Roosevelt Elementary School	1015	A15000	Classrooms	2002	1
Mesa Unified District	Roosevelt Elementary School	1016	A16000	Restrooms	2002	1
Mesa Unified District	Roosevelt Elementary School	1017 1014	A17000	Classroom	2002	1
Address:	828 S Valencia, Mesa, AZ 85202				Number of Bottles Per Kit:	13

egorehol