

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: Redbird Elementary School

Reported:
06/09/17 13:23

Analyte

1 Confirmation- First Draw (7060130-01) Drinking Water (Grab) Sampled: 05/25/17 06:39 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	380	5.0	ug/L	1	B7F1171	06/08/17 15:15	06/08/17 19:51	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

2 Confirmation - Flush (7060130-02) Drinking Water (Grab) Sampled: 05/25/17 06:40 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1171	06/08/17 15:15	06/08/17 19:53	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

3 Confirmation - First Draw Day Two (7060130-03) Drinking Water (Grab) Sampled: 05/26/17 06:45 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	36	5.0	ug/L	1	B7F1171	06/08/17 15:15	06/08/17 19:56	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 25.00 °C
All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.
QA/QC Criteria: All analyses met method requirements unless otherwise qualified.
Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.
Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.
Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Notes and Definitions

Reported:
06/09/17 13:23

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	
RELINQUISHING AGENT SIGNATURE:	
SIGNATORY NAME PRINTED:	

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	5/31/17
TIME LAB RECEIVED:	11:00
LAB SIGNATURE:	W
LAB SIGNATORY NAME PRINTED:	Vicki A. Newman
NOTES:	25.0°C pH 7