

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Confirmation (RUSH)
Project Number: Robson Elementary School

Reported:
06/07/17 16:43

Analyte

1 Confirmation- First Draw (7060131-01) Drinking Water (Grab) Sampled: 05/24/17 08:15 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	8.1	5.0	ug/L	1	B7F1055	06/06/17 14:03	06/06/17 21:07	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

2 Confirmation - Flush (7060131-02) Drinking Water (Grab) Sampled: 05/24/17 08:16 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7F1055	06/06/17 14:03	06/06/17 21:10	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

3 Confirmation - First Draw Day Two (7060131-03) Drinking Water (Grab) Sampled: 05/25/17 06:25 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	13	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 21:41	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

4 Confirmation- First Draw (7060131-04) Drinking Water (Grab) Sampled: 05/25/17 06:30 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	22	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 21:45	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

5 Confirmation- Flush (7060131-05) Drinking Water (Grab) Sampled: 05/25/17 06:31 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	53	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 21:48	EPA 200.8
------	----	-----	------	---	---------	----------------	----------------	-----------

6 Confirmation- First Draw Day Two (7060131-06) Drinking Water (Grab) Sampled: 05/26/17 06:15 Received: 05/31/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.8	5.0	ug/L	1	B7F1056	06/06/17 14:18	06/06/17 21:52	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 4

Sample Condition Upon Receipt:

Temperature: 25.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: **AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.**

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.

All samples were analyzed on a "wet" basis unless designated as "dry weight".

Notes and Definitions

7060131

Sample Collector Name and Phone Number:

James L. L.

472-6000

[illegible]

RUSH
06/10/71/7

These samples were collected for screening purposes only and are not to be used for compliance determinations

- 03-P06 Sample date and time switched, used chair
109 in 6/21/17

For relinquishing samples upon delivery to labs only

DATE RELINQUISHED:	
RELINQUISHING AGENT SIGNATURE:	
SIGNATORY NAME PRINTED:	

For Lab Use Only

ANALYZE THIS DRINKING WATER SAMPLE FOR LEAD

DATE LAB RECEIVED:	5/31/17
TIME LAB RECEIVED:	11:00
LAB SIGNATURE:	W
LAB SIGNATORY NAME PRINTED:	Victoria Neuman
NOTES:	25.0°C pttv