

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Madison Elementary School

Reported:
05/05/17 15:12

Analyte

1001-1 (7042669-01) Drinking Water (Grab) Sampled: 04/21/17 05:05 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0960	05/01/17 17:03	05/02/17 03:04	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7042669-02) Drinking Water (Grab) Sampled: 04/21/17 05:01 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0960	05/01/17 17:03	05/02/17 03:07	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-1 (7042669-03) Drinking Water (Grab) Sampled: 04/21/17 05:10 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0960	05/01/17 17:03	05/02/17 03:11	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-1 (7042669-04) Drinking Water (Grab) Sampled: 04/21/17 05:05 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0961	05/01/17 17:05	05/02/17 03:42	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 27.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Legend Technical Services of Arizona, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Client Services Representative

Phone Number: (602) 324-6100

Page 1 of 7

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

70424609

- 01

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Mesa Unified District
Madison Elementary School
1001
SINK
A100
1001-1
4-21-17
5:05am
Marcos Torres

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received Lab 1600 by ADEQ Rep 4/27/17	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7042669 -02

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Madison Elementary School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	T-2
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-1
Date of Collection	4.21.17
Time of Collection	5:01am
Printed Name of Sample Collector	Marcos Torres
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Recvd @ Lab 4/27/17 @ 1400 by ADEQ Rep

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Madison Elementary School
Building (name/number)	1004
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	TL
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-1
Date of Collection	4.21.17
Time of Collection	5:05am
Printed Name of Sample Collector	Marcel Torres
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	Rec'd Lab 4/27/17 1600 by ADEQ Rep

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Madison Elementary School	1001	A1000	ADMIN/MPP/MEDI	1988	1
Mesa Unified District	Madison Elementary School	1002	A2000 / R-520	A/CLASS	1995	1
Mesa Unified District	Madison Elementary School	1003	A3000 / R-556	CLASSROOM	1996	1
Mesa Unified District	Madison Elementary School	1004	A4000 / R-496	Classrooms	1990	1
Address:	849 S Sunnyvale, Mesa, AZ 85206					Number of Bottles Per Kit: 4

70426069

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Madison Elementary School
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	SINK
Location of Fixture (example, room number)	T4
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-1
Date of Collection	4.21.17
Time of Collection	5:10am
Printed Name of Sample Collector	Marcos Torres
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Recvd @ Lab 1000 4/27/17 by ADEQ Rep	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.