

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Poston Junior High School

Reported:
05/05/17 16:36

Analyte

1001-1 (7042697-01) Drinking Water (Grab) Sampled: 04/18/17 07:10 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 19:46	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7042697-02) Drinking Water (Grab) Sampled: 04/19/17 07:15 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 19:50	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7042697-03) Drinking Water (Grab) Sampled: 04/18/17 07:05 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 19:54	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-2 (7042697-04) Drinking Water (Grab) Sampled: 04/19/17 07:10 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 19:57	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-1 (7042697-05) Drinking Water (Grab) Sampled: 04/18/17 07:16 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:09	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-2 (7042697-06) Drinking Water (Grab) Sampled: 04/19/17 07:20 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:13	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-1 (7042697-07) Drinking Water (Grab) Sampled: 04/18/17 07:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.



Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 29

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Poston Junior High School

Reported:
05/05/17 16:36

1004-1 (7042697-07) Drinking Water (Grab) Sampled: 04/18/17 07:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:24	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-2 (7042697-08) Drinking Water (Grab) Sampled: 04/19/17 07:05 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:28	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1005-1 (7042697-09) Drinking Water (Grab) Sampled: 04/18/17 06:55 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:32	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1005-2 (7042697-10) Drinking Water (Grab) Sampled: 04/19/17 07:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	7.8	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:35	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1006-1 (7042697-11) Drinking Water (Grab) Sampled: 04/18/17 07:25 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:39	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1006-2 (7042697-12) Drinking Water (Grab) Sampled: 04/19/17 07:25 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:43	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1007-1 (7042697-13) Drinking Water (Grab) Sampled: 04/18/17 06:50 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:54	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1007-2 (7042697-14) Drinking Water (Grab) Sampled: 04/19/17 06:55 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

1007-2 (7042697-14) Drinking Water (Grab) Sampled: 04/19/17 06:55 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 20:58	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1009-1 (7042697-15) Drinking Water (Grab) Sampled: 04/18/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	8.1	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 21:02	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1009-2 (7042697-16) Drinking Water (Grab) Sampled: 04/19/17 06:30 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0983	05/02/17 10:43	05/03/17 21:06	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010-1 (7042697-17) Drinking Water (Grab) Sampled: 04/18/17 06:35 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0984	05/02/17 10:45	05/03/17 05:07	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010-2 (7042697-18) Drinking Water (Grab) Sampled: 04/19/17 06:35 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	6.7	5.0	ug/L	1	B7E0984	05/02/17 10:45	05/03/17 05:10	EPA 200.8
------	-----	-----	------	---	---------	----------------	----------------	-----------

1011-1 (7042697-19) Drinking Water (Grab) Sampled: 04/18/17 06:40 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0984	05/02/17 10:45	05/03/17 05:14	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1011-2 (7042697-20) Drinking Water (Grab) Sampled: 04/19/17 06:40 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0984	05/02/17 10:45	05/03/17 05:18	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1012-1 (7042697-21) Drinking Water (Grab) Sampled: 04/18/17 06:43 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Poston Junior High School

Reported:
05/05/17 16:36

1012-1 (7042697-21) Drinking Water (Grab) Sampled: 04/18/17 06:43 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0984	05/02/17 10:45	05/03/17 05:22	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1012-2 (7042697-22) Drinking Water (Grab) Sampled: 04/19/17 06:45 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0984	05/02/17 10:45	05/03/17 05:26	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1020-1 (7042697-23) Drinking Water (Grab) Sampled: 04/18/17 06:45 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0984	05/02/17 10:45	05/03/17 05:29	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1020-2 (7042697-24) Drinking Water (Grab) Sampled: 04/19/17 06:50 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E0984	05/02/17 10:45	05/03/17 05:33	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 27.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-01

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	OFFICE 1001
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-1
Date of Collection	4-18-17
Time of Collection	07:10
Printed Name of Sample Collector	Randy Martinez
Signature Sample Collector	<i>Randy Martinez</i>

Notes Sample collector:

Received 4/27/17 1600 @ lab


27.2°C

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.



<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

701269702

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1001
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	OFFICE 77411
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-2
Date of Collection	4.19.17
Time of Collection	07:15
Printed Name of Sample Collector	Randy MARRIOTT
Signature Sample Collector	Randy Marriott

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

704269703

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1002
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CENTER OF POD
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-1
Date of Collection	4-18-17
Time of Collection	07:05
Printed Name of Sample Collector	Randy MacCott
Signature Sample Collector	Randy MacCott

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)

Mesa Unified District
Poston Junior High School
1002
FOUNTAIN
FOOD CENTER
1002-2
4.19.17
7:40
Randy Mappiga
Randy Mappiga

has 1002-2 written on label used to tag in W 4/28/17

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CENTER OF POD
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-1
Date of Collection	4/18/17
Time of Collection	07:16
Printed Name of Sample Collector	Randy Markion
Signature Sample Collector	Randy Markion

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-04

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1003
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CENTER POD
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-2
Date of Collection	4.19.17
Time of Collection	07:20
Printed Name of Sample Collector	Randy M. [Signature]
Signature Sample Collector	Randy M. [Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1003 1004
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CENTER P.O.D.
Sample Identification Number (Write this number on the sample container and on this sheet)	-1004-1
Date of Collection	4/18/17
Time of Collection	07:00
Printed Name of Sample Collector	Randy MAGRIOT
Signature Sample Collector	<i>Randy Magriot</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-08

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1004
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	FOOD CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-2
Date of Collection	4.18.17
Time of Collection	07:05
Printed Name of Sample Collector	Bundy Mackintosh
Signature Sample Collector	<i>Bundy Mackintosh</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-09

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1005
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	DOO CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1
Date of Collection	4.18.17
Time of Collection	6:55
Printed Name of Sample Collector	Randy Morrison
Signature Sample Collector	<i>Randy Morrison</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-10

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1005
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	POD CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	1.005-2
Date of Collection	4/19/17
Time of Collection	02:00
Printed Name of Sample Collector	Randy Haggerty
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-11

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CYM
Sample Identification Number (Write this number on the sample container and on this sheet)	1006 - 1
Date of Collection	4-18-17
Time of Collection	7:25
Printed Name of Sample Collector	Randy
Signature Sample Collector	<i>Randy</i> <i>Margaret</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1006
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Gym
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-2
Date of Collection	4.19
Time of Collection	07:25
Printed Name of Sample Collector	Randy Maggitt
Signature Sample Collector	Randy Maggitt

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-13

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1000 1007
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	ATHLETICUM
Sample Identification Number (Write this number on the sample container and on this sheet)	7042697-13
Date of Collection	4-18-17
Time of Collection	06:50
Printed Name of Sample Collector	Randy W. Wiggins
Signature Sample Collector	Randy Wiggins

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042097-14

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1007
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Auditorium
Sample Identification Number (Write this number on the sample container and on this sheet)	1007-2
Date of Collection	4.18.17
Time of Collection	6:55
Printed Name of Sample Collector	Randy M. H.
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-15

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1009
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	PUD CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	1009 - 1
Date of Collection	4-18-17
Time of Collection	06:30
Printed Name of Sample Collector	Randy Macgoff
Signature Sample Collector	<i>[Signature]</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042687-16

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1009
Type of Fixture (tap, drinking fountain etc.)	Fountain
Location of Fixture (example, room number)	Red Center
Sample Identification Number (Write this number on the sample container and on this sheet)	1009-2
Date of Collection	4-19-17
Time of Collection	4:30
Printed Name of Sample Collector	Randy Magallon
Signature Sample Collector	<i>Randy Magallon</i>

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-17

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1010
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	PDD CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	1010-1
Date of Collection	4-18-17
Time of Collection	0635
Printed Name of Sample Collector	Randy
Signature Sample Collector	Margaret

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-18

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1010
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CENTER POD
Sample Identification Number (Write this number on the sample container and on this sheet)	- 10-10-2
Date of Collection	4-18-17
Time of Collection	6:35
Printed Name of Sample Collector	Randy Morrison
Signature Sample Collector	[Signature]

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-19

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1011
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	POD CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-1
Date of Collection	4-18-17
Time of Collection	6:40
Printed Name of Sample Collector	Randy Mangione
Signature Sample Collector	Randy Mangione

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-20

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1011
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CENTRAL POD
Sample Identification Number (Write this number on the sample container and on this sheet)	1011-2
Date of Collection	4.18.17
Time of Collection	6:40
Printed Name of Sample Collector	Randy Mappio
Signature Sample Collector	Randy Mappio

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

70420817-21

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1012
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	POP CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	---1012-1
Date of Collection	4-18-17
Time of Collection	6:43
Printed Name of Sample Collector	Randy Morrison
Signature Sample Collector	Randy Morrison

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-22

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1012
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	POD CENTER
Sample Identification Number (Write this number on the sample container and on this sheet)	1012-2
Date of Collection	4.19.17
Time of Collection	6:45
Printed Name of Sample Collector	Randy Maggioni
Signature Sample Collector	Randy Maggioni

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-23

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1020 - 1
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CATERINA
Sample Identification Number (Write this number on the sample container and on this sheet)	1020 - 1
Date of Collection	4-18-17
Time of Collection	6:45
Printed Name of Sample Collector	Randy Marriott
Signature Sample Collector	Randy Marriott

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042697-24

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

- ☐ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Poston Junior High School
Building (name/number)	1020 - 2
Type of Fixture (tap, drinking fountain etc.)	FOUNTAIN
Location of Fixture (example, room number)	CATERINA
Sample Identification Number (Write this number on the sample container and on this sheet)	1020-2
Date of Collection	4.19.17
Time of Collection	6:50
Printed Name of Sample Collector	Randy Martinez
Signature Sample Collector	Randy Martinez

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7042697

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Poston Junior High School	1001	A1000	Admin		2
Mesa Unified District	Poston Junior High School	1002	A2000	Classroom		2
Mesa Unified District	Poston Junior High School	1003	A3000	Classroom		2
Mesa Unified District	Poston Junior High School	1004	A4000	Classroom		2
Mesa Unified District	Poston Junior High School	1005	A5000	Classroom		2
Mesa Unified District	Poston Junior High School	1006	A6000	Gym, PE		2
Mesa Unified District	Poston Junior High School	1007	A7000	Auditorium, Cafeteria		2
Mesa Unified District	Poston Junior High School	1008	A8000	Media Center		2
Mesa Unified District	Poston Junior High School	1009	A9000	Classroom		2
Mesa Unified District	Poston Junior High School	1010	A10000	Classroom		2
Mesa Unified District	Poston Junior High School	1011	A11000	Classroom		2
Mesa Unified District	Poston Junior High School	1012	A12000	Industrial Arts		2
Mesa Unified District	Poston Junior High School	1013	A13000 R-083	Classroom		2
Mesa Unified District	Poston Junior High School	1014	A14000 R-408	Classroom		2
Mesa Unified District	Poston Junior High School	1015	A15000 R-553	Classroom		2
Mesa Unified District	Poston Junior High School	1016	A16000 R-464	Classroom		2
Mesa Unified District	Poston Junior High School	1017	A17000 R-420	Classroom		2
Mesa Unified District	Poston Junior High School	1018	Boiler Room	Equipment		2
Mesa Unified District	Poston Junior High School	1019	A19000 R507	Classroom		2
Mesa Unified District	Poston Junior High School	1020	A20000 - R458	Classroom		2
Address: 2433 E Adobe, Mesa, AZ 85213					Number of Bottles Per Kit:	25/40

16 NO water