

David A. Burchard
Arizona Department of Environmental Quality,
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Taylor Junior High School

Reported:
05/18/17 12:39

Analyte

1001-1 (7050768-01) Drinking Water (Grab) Sampled: 04/26/17 06:05 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 19:28	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7050768-02) Drinking Water (Grab) Sampled: 04/26/17 06:05 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 19:31	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7050768-03) Drinking Water (Grab) Sampled: 04/26/17 06:15 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 19:35	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-2 (7050768-04) Drinking Water (Grab) Sampled: 04/26/17 06:15 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 19:39	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-1 Shop (7050768-05) Drinking Water (Grab) Sampled: 04/26/17 06:25 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 19:43	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-2 Art (7050768-06) Drinking Water (Grab) Sampled: 04/26/17 06:25 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 20:02	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-1 (7050768-07) Drinking Water (Grab) Sampled: 04/26/17 06:45 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.

Anna Teter

Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

David A. Burchard
Arizona Department of Environmental Quality,
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Taylor Junior High School

Reported:
05/18/17 12:39

1004-1 (7050768-07) Drinking Water (Grab) Sampled: 04/26/17 06:45 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 20:06	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-2 (7050768-08) Drinking Water (Grab) Sampled: 04/26/17 06:45 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 20:10	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1005-1 (7050768-09) Drinking Water (Grab) Sampled: 04/26/17 06:55 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 20:13	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1005-2 (7050768-10) Drinking Water (Grab) Sampled: 04/26/17 06:55 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 20:17	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1010-1 (7050768-11) Drinking Water (Grab) Sampled: 04/26/17 07:30 Received: 05/03/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1493	05/16/17 14:16	05/16/17 20:21	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 20.00 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted. All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard
Arizona Department of Environmental Quality,
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Taylor Junior High School

Reported:
05/18/17 12:39

Notes and Definitions

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

1050768-01

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	1001
Location of Fixture (example, room number)	DRINKING FOUNTAIN
Sample Identification Number (Write this number on the sample container and on this sheet)	LUNCH ROOM
Date of Collection	1001-1
Time of Collection	4/26/17
Printed Name of Sample Collector	6:05
Signature Sample Collector	JEFF KINSMAN

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received@ lab 5/3/17 1000 20.0°C	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7050768-02

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	41001
Location of Fixture (example, room number)	D.F.
Sample Identification Number (Write this number on the sample container and on this sheet)	LUNCH ROOM
Date of Collection	1001-2
Time of Collection	4/26/17
Printed Name of Sample Collector	6:05
Signature Sample Collector	JEFF KINSMAN
	JWK

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

70507608-03

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	A2000 GYM 1002
Location of Fixture (example, room number)	DF
Sample Identification Number (Write this number on the sample container and on this sheet)	GYM
Date of Collection	2001 1002-1
Time of Collection	4/26/17
Printed Name of Sample Collector	6:15 A.M.
Signature Sample Collector	JEFF KUSMAN
	JAK

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050768-1

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	2000 GYM 1002
Location of Fixture (example, room number)	DE GYM
Sample Identification Number (Write this number on the sample container and on this sheet)	2000-2 1002-2
Date of Collection	4/26/17
Time of Collection	6:15 AM
Printed Name of Sample Collector	JEFF KINSMAN
Signature Sample Collector	JEFF KINSMAN

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050768-05

Collection Log

for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	1003 WOOD SHOP / ACT
Location of Fixture (example, room number)	D.F.
Sample Identification Number (Write this number on the sample container and on this sheet)	WOOD SHOP
Date of Collection	1003-1 SHOP
Time of Collection	4/26/17
Printed Name of Sample Collector	6:25 AM
Signature Sample Collector	JEFF KINSMAN
	JUK

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050768-06

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	1003 ADD SHOP / ART
Location of Fixture (example, room number)	D.F. ART ROOM
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-2 ART
Date of Collection	4/26/17
Time of Collection	6:25 AM
Printed Name of Sample Collector	JEFF KINSLEY
Signature Sample Collector	

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

705078-07

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain/etc.)	Aud. 1004
Location of Fixture (example, room number)	DF
Sample Identification Number (Write this number on the sample container and on this sheet)	Aud.
Date of Collection	1004 -1
Time of Collection	4/26/17
Printed Name of Sample Collector	6:45 am
Signature Sample Collector	Jeff Lindsay JEFF LINDSAY

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

7050768-08

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	Aud. 1004
Location of Fixture (example, room number)	D.F.
Sample Identification Number (Write this number on the sample container and on this sheet)	Aud
Date of Collection	1004-2
Time of Collection	4/26/17
Printed Name of Sample Collector	6:45 am
Signature Sample Collector	JEFF KINSMAN

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.


ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


7050768-09

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	1005 P7
Location of Fixture (example, room number)	TAP
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1 P7
Date of Collection	4/26/17
Time of Collection	6:55 A.M.
Printed Name of Sample Collector	JEFF KINSMA
Signature Sample Collector	

Notes Sample collector: 

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____


These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log


Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	1005 PB
Location of Fixture (example, room number)	TAJ
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-2 PB
Date of Collection	4/26/17
Time of Collection	6:55 A.M.
Printed Name of Sample Collector	JEFF KINSMAN
Signature Sample Collector	

Notes Sample collector:



For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

★ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
Building (name/number)	Taylor Junior High School
Type of Fixture (tap, drinking fountain etc.)	1010 REST ROOM OUTSIDE
Location of Fixture (example, room number)	DRINKING FOUNTAIN
Sample Identification Number (Write this number on the sample container and on this sheet)	OUTSIDE RESTROOMS
Date of Collection	1010-1
Time of Collection	4/26/17
Printed Name of Sample Collector	7:30
Signature Sample Collector	JEFF KINSMAN

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

7050768

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Taylor Junior High School	1001	A1000	Admin, Cafeteria, Class	1981	2
Mesa Unified District	Taylor Junior High School	1002	A2000	Gym, PE	1981	2
Mesa Unified District	Taylor Junior High School	1003	A3000	Industrial Arts	1981	2
Mesa Unified District	Taylor Junior High School	1004	A4000	Auditorium, Class	1981	2
Mesa Unified District	Taylor Junior High School	1005	A5000 R-327	Classroom	1985	2
Mesa Unified District	Taylor Junior High School	1006	A6000 R-431 <i>no north</i>	Classroom	1984	2
Mesa Unified District	Taylor Junior High School	1007	A7000 R-191 <i>no north</i>	Classroom	1986	2
Mesa Unified District	Taylor Junior High School	1008	A8000 R-343 <i>no north</i>	Classroom	1986	2
Mesa Unified District	Taylor Junior High School	1009	A9000 R-031 <i>no north</i>	Classroom	1991	1
Mesa Unified District	Taylor Junior High School	1010	A10000	Restroom	1996	1
Address:	705 S 32nd St, Mesa, AZ 85204				Number of Bottles Per Kit:	18