

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ 85007

Project: School Lead Testing Screening
Project Number: Mountain View High School

Reported:
05/10/17 15:11

Analyte

1001-1 (7042715-01) Drinking Water (Grab) Sampled: 04/22/17 08:55 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1216	05/08/17 10:30	05/08/17 15:36	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1001-2 (7042715-02) Drinking Water (Grab) Sampled: 04/22/17 09:17 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:10	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-1 (7042715-03) Drinking Water (Grab) Sampled: 04/22/17 09:21 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:13	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1002-2 (7042715-04) Drinking Water (Grab) Sampled: 04/22/17 09:26 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:25	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-1 (7042715-05) Drinking Water (Grab) Sampled: 04/22/17 09:32 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:29	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1003-2 (7042715-06) Drinking Water (Grab) Sampled: 04/22/17 09:36 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:32	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1004-1 (7042715-07) Drinking Water (Grab) Sampled: 04/22/17 09:41 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
---------	--------	-----	-------	----------	-------	----------	----------	--------	-------

Legend Technical Services of Arizona, Inc.



Client Services Representative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Phone Number: (602) 324-6100

Page 1 of 22

1004-1 (7042715-07) Drinking Water (Grab) Sampled: 04/22/17 09:41 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:36	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1004-2 (7042715-08) Drinking Water (Grab) Sampled: 04/22/17 09:43 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:40	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1005-1 (7042715-09) Drinking Water (Grab) Sampled: 04/22/17 09:49 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:44	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1005-2 (7042715-10) Drinking Water (Grab) Sampled: 04/22/17 09:53 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	29	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:48	EPA 200.8	
------	----	-----	------	---	---------	----------------	----------------	-----------	--

1006-1 (7042715-11) Drinking Water (Grab) Sampled: 04/22/17 10:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 00:51	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1006-2 (7042715-12) Drinking Water (Grab) Sampled: 04/22/17 10:00 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 01:11	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1021 (7042715-13) Drinking Water (Grab) Sampled: 04/22/17 10:26 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 01:14	EPA 200.8	
------	------	-----	------	---	---------	----------------	----------------	-----------	--

1022 (7042715-14) Drinking Water (Grab) Sampled: 04/26/17 06:40 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

David A. Burchard
Arizona Department of Environmental Quality, PHX
1110 W. Washington Street
Phoenix, AZ85007

Project: School Lead Testing Screening
Project Number: Mountain View High School

Reported:
05/10/17 15:11

1022 (7042715-14) Drinking Water (Grab) Sampled: 04/26/17 06:40 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 01:18	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1024 (7042715-15) Drinking Water (Grab) Sampled: 04/26/17 06:20 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 01:22	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1025 (7042715-16) Drinking Water (Grab) Sampled: 04/22/17 10:16 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 01:26	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

1026 (7042715-17) Drinking Water (Grab) Sampled: 04/22/17 10:12 Received: 04/27/17 16:00

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Legend Technical Services of Arizona, Inc.									

Total Metals

Lead	<5.0	5.0	ug/L	1	B7E1159	05/03/17 16:44	05/05/17 01:30	EPA 200.8
------	------	-----	------	---	---------	----------------	----------------	-----------

Sample Condition Upon Receipt:

Temperature: 27.20 °C

All samples were received in acceptable condition unless noted otherwise in the case narrative.

Case Narrative:

Holding Times: All holding times were met unless otherwise qualified.

QA/QC Criteria: All analyses met method requirements unless otherwise qualified.

Accreditations: AZ(PHX)0004, AZ(TUC)0004, AIHA#102982, CDC ELITE Member.

Accreditation is applicable only to the test methods specified on each scope of accreditation held by LEGEND.

Comments: There were no problems encountered during the processing of the samples, unless otherwise noted.
All samples were analyzed on a "wet" basis unless designated as "dry weight".

Lead samples are preserved with Nitric acid upon receipt at the laboratory. However, some samples were analyzed prior to the 16 hour preservation waiting period due to urgency of analysis, per the client's request. Results are not for compliance purpose.

Notes and Definitions

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-01

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District
School Name
Building (name/number)
Type of Fixture (tap, drinking fountain etc.)
Location of Fixture (example, room number)
Sample Identification Number (**Write this number on the sample container and on this sheet**)
Date of Collection
Time of Collection
Printed Name of Sample Collector
Signature Sample Collector

Mesa Unified District
Mountain View High School
1001-1
Water Fountain
Upstairs outside North Between Restrooms 2005
1001-1
4/22/17
8:55 AM
Marco Van Brown
MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes: Received 4/27/17 1600g 27.2°C @lab	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-02

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1001-2
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	Cafeteria 1001S
Sample Identification Number (Write this number on the sample container and on this sheet)	1001-2
Date of Collection	4/22/17
Time of Collection	9:17am
Printed Name of Sample Collector	Wesley Van Brown
Signature Sample Collector	WVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-03

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1002-1
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Entrance Hallway 300's
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-1
Date of Collection	4/22/17
Time of Collection	9:21 AM
Printed Name of Sample Collector	Marco Van Bram
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-01

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1002-2
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	311
Sample Identification Number (Write this number on the sample container and on this sheet)	1002-2
Date of Collection	4/22/17
Time of Collection	9:26 AM
Printed Name of Sample Collector	Marco Van Broom
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-05

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1003-1
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	South Lobby Auditorium 400's
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-1
Date of Collection	4/22/17
Time of Collection	9:32 am
Printed Name of Sample Collector	Marco Van Brun
Signature Sample Collector	MVJ

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-06

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1003-2
Type of Fixture (tap, drinking fountain etc.)	Water fountain
Location of Fixture (example, room number)	North Lobby Auditorium 400's
Sample Identification Number (Write this number on the sample container and on this sheet)	1003-2
Date of Collection	4/22/17
Time of Collection	8:30 am
Printed Name of Sample Collector	Marcel Van Braum
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-07

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1004-1
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Hallway Science Annex
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-1
Date of Collection	5/22/17
Time of Collection	9:41 am
Printed Name of Sample Collector	Marco Van Brown
Signature Sample Collector	WVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1004-2
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	SA 2 East sink
Sample Identification Number (Write this number on the sample container and on this sheet)	1004-2
Date of Collection	4/22
Time of Collection	9:43 am
Printed Name of Sample Collector	Marco Van Brown
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-09

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1005-1
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Girls Locker Room / Gym
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-1
Date of Collection	4/22/17
Time of Collection	9:49am
Printed Name of Sample Collector	Marco Van Brown
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-10

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1005-2
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Boys Locker Room/Gym
Sample Identification Number (Write this number on the sample container and on this sheet)	1005-2
Date of Collection	4/22/17
Time of Collection	9:53 AM
Printed Name of Sample Collector	Marco Van Brown
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1006-1
Type of Fixture (tap, drinking fountain etc.)	water fountain
Location of Fixture (example, room number)	Hallway East Courtyard Sports Annex
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-1
Date of Collection	4/22
Time of Collection	10:00 am
Printed Name of Sample Collector	Marcus Van Brown
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-12

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1006-Z
Type of Fixture (tap, drinking fountain etc.)	Sink
Location of Fixture (example, room number)	Varsity locker room Sports Annex
Sample Identification Number (Write this number on the sample container and on this sheet)	1006-Z
Date of Collection	4/22/17
Time of Collection	10:00 am
Printed Name of Sample Collector	Marco Van Brown
Signature Sample Collector	WVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

7042715-13

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1021
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	North Canyon West side Hallway 1005
Sample Identification Number (Write this number on the sample container and on this sheet)	1021
Date of Collection	4/22
Time of Collection	10:26 am
Printed Name of Sample Collector	Marcos Van Brown
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1022
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	Weight room Annex
Sample Identification Number (Write this number on the sample container and on this sheet)	1022
Date of Collection	4/26/17
Time of Collection	6:40
Printed Name of Sample Collector	Marco Van Brown
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1024
Type of Fixture (tap, drinking fountain etc.)	Water fountain
Location of Fixture (example, room number)	North West fixture 8005
Sample Identification Number (Write this number on the sample container and on this sheet)	1024
Date of Collection	4/26
Time of Collection	6:20 AM
Printed Name of Sample Collector	Marco Van Brown
Signature Sample Collector	MVB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeg.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1025
Type of Fixture (tap, drinking fountain etc.)	Water Fountain
Location of Fixture (example, room number)	outside Concession Home
Sample Identification Number (Write this number on the sample container and on this sheet)	1025
Date of Collection	4/22/17
Time of Collection	10:16 am
Printed Name of Sample Collector	marco Jan Brown
Signature Sample Collector	MJB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

ADEQ Public School Drinking Water Lead Screening Program
Sampling Plan & Collection Log

Collection Log
for experienced sample collectors

Complete copy of this form for each sample collected. Your drinking water sample cannot be tested unless a copy of this form is shipped to the lab with each sample. In addition, the sample cannot be tested unless the Sample Identification Number matches the number on the sample container label.

☒ Check this box to confirm that **water had not been used at this tap or other taps in the area for 6 hours** and **no** flushing was done prior to sampling

Name of School District	Mesa Unified District
School Name	Mountain View High School
Building (name/number)	1026
Type of Fixture (tap, drinking fountain etc.)	outs. water fountain
Location of Fixture (example, room number)	outside concessions VEHOR
Sample Identification Number (Write this number on the sample container and on this sheet)	1026--
Date of Collection	4/22/17
Time of Collection	10:12 AM
Printed Name of Sample Collector	Marce Van Brown
Signature Sample Collector	MAB

Notes Sample collector:

For Lab use only	
Analyze this drinking water sample for lead	
Date and Time Lab received	
Signature	
Notes:	

For relinquishing samples upon delivery to labs only

Relinquished date and signature _____

These samples were collected for lead screening purposes only and cannot be used for compliance.

<http://www.azdeq.gov/LeadScreeningProg>

Page 2 of 2

7042715

District	School	Building No	Building Desc	Building Use	Year Built	Number of Bottles Per Building
Mesa Unified District	Mountain View High School	1001	A1000	Admin, Media, Cafeteria, Class	1976	2 ✓
Mesa Unified District	Mountain View High School	1002	A2000	Industrial Arts	1976	2 ✓
Mesa Unified District	Mountain View High School	1003	A3000	Auditorium, Music	1976	2 ✓
Mesa Unified District	Mountain View High School	1004	A4000	VocAg	1979	2 ✓
Mesa Unified District	Mountain View High School	1005	A5000	Gym, PE	1976	2 ✓
Mesa Unified District	Mountain View High School	1006	A6000	PE Annex	1980	2 ✓
Mesa Unified District	Mountain View High School	1011	A11000 - R211 <i>Cont. find</i>	Classroom	1986	2 ✓
Mesa Unified District	Mountain View High School	1013	A13000 - R474 <i>Cont. find</i>	Classroom	1992	1 ✓
Mesa Unified District	Mountain View High School	1019	A23000 - R476	Classroom	1994	1 <i>No water</i>
Mesa Unified District	Mountain View High School	1021	A22000	Classrooms	2003	1 ✓
Mesa Unified District	Mountain View High School	1022	Weight Room	PE Classroom	2012	1 ?
Mesa Unified District	Mountain View High School	1023	Storage Building	PE Storage	2012	1 ? <i>cont. find</i>
Mesa Unified District	Mountain View High School	1024	A21000 <i>800's</i>	Classrooms	2012	1 ?
Mesa Unified District	Mountain View High School	1025	Concession 1	Concessions	2011	1 ✓
Mesa Unified District	Mountain View High School	1026	Concession 2	Concessions	2011	1 ✓
Address: 2700 E Brown Rd, Mesa, AZ 85213					Number of Bottles Per Kit:	22

17

